EXAMPLE REPORT

Transformer Test Report

IEC 60076-5 short-circuit / IEC 60076-4 lightning impulse - redacted sample

Project:	[REDACTED - sample]
Client:	[REDACTED - sample]
Manufacturer:	[REDACTED - sample]
Serial number:	[REDACTED - sample]
Standards:	IEC 60076-5 sec.10 / IEC 60076-4 sec.7
Test date:	2026-Q2

Description

HV/LV rating - 100 / 33 kV

Short-circuit current Isc - 25 kA / 2 s

Peak withstand ip - 1.82 x sqrt(2) x Isc

Lightning impulse (1.2/50 us) - 650 kV BIL

Switching impulse (250/2500 us) - 525 kV SIL

Example report. These magnitudes illustrate the format. Actual magnitudes vary per project. Device, customer, and site names are withheld. This file is not a test certificate.