

KavachAI Investigation Report

Query: Investigate Pump P-102 and determine whether its condition has deteriorated.

Status: attention_required | Confidence: 91% | Verification: verified

Key Findings

Increasing vibration: Jan 2.1 → Apr 2.8 → Jul 3.7 mm/s (+76%) [supported]

Exceeds attention threshold: Current 3.7 mm/s > spec 3.0 mm/s [supported]

Conclusion

The available evidence indicates a condition change over the observed period. Engineering inspection is recommended. The evidence does NOT establish imminent failure.