

KavachAI Investigation Report

Sovereign Industrial Agentic AI Workbench · Confidential Plant Operations

Query: Investigate about P-102

Status: **ATTENTION REQUIRED** | Confidence: **95%** | Verification: **VERIFIED**

Key Findings & Grounded Evidence

1. Increasing Operating Temperature

[SUPPORTED]

The temperature of Pump P-102 has risen from 68°C in January 2026 to 71°C in April 2026, indicating a significant increase in operating temperature.

Evidence: P&ID; Drawing • Document, p. 1

2. Vibration Level Fluctuation

[SUPPORTED]

The vibration level of Pump P-102 has fluctuated from 2.1 mm/s in January 2026 to 2.8 mm/s in April 2026, suggesting potential issues with the pump's operation.

Evidence: P&ID; Drawing • Document, p. 1

Synthesized Conclusion

Engineering Summary:

The available evidence indicates a condition change over the observed period. Engineering inspection is recommended. The evidence does NOT establish imminent failure.