

KavachAI Investigation Report

Sovereign Industrial Agentic AI Workbench · Confidential Plant Operations

Query: Investigate Pump P-102 and determine whether its condition has deteriorated.

Status: ATTENTION REQUIRED | **Confidence:** 95% | **Verification:** VERIFIED

Key Findings & Grounded Evidence

1. Pump P-102 operates within vibration threshold limits

[SUPPORTED]

Continuous acceptable vibration velocity (RMS) is below 2.8 mm/s, which is below the attention threshold of 3.0 mm/s for continuous operation of Pump P-102.

Evidence: P&ID; Drawing • Document, p. 1

Synthesized Conclusion

Engineering Summary:

The available evidence indicates a condition change over the observed period. Engineering inspection is recommended. The evidence does NOT establish imminent failure.

CONFIDENTIAL · Verified by KavachAI On-Premise Inference Engine · Zero External Network Transmission