JOHANSSON ENGINEERING

05 — Round Checklist

Print multiple copies. You need one for every round (12-17 per year). Take this to the site, check every vessel, mark OK or X, sign and file.

Date	
Round type	Monthly / Quarterly
Performed by	
Program ID	SP-

Site Checks

#	CHECK	OK	X	NOTES
1	Access to all vessels clear and safe			
2	Lighting adequate			
3	No unusual sounds or smells			
4	Area around vessels clean and tidy			
5	Emergency equipment accessible			

Vessel: Nr ___ ID: _____ Type: _____

Readings: Pressure _____ bar | Temperature _____ C

#	THE 6 MANDATORY CHECKS	OK	X
1	Works properly — no abnormal noise, vibration, or behaviour		
2	No leaks at flanges, valves, connections		
3	No damage — no dents, corrosion, cracks, impact marks		
4	No other faults or deviations		
5	Correctly marked — nameplate readable, labels in place		
6	Inspections up to date — certificate not expired		

#	ADDITIONAL CHECKS	OK	X
7	Safety valve seal intact, not blocked		
8	Insulation intact (if applicable)		
9	Supports and foundation solid		
10	Drain valve works		

Notes: _____

Vessel: Nr ___ ID: _____ Type: _____

Readings: Pressure _____ bar | Temperature _____ C

#	THE 6 MANDATORY CHECKS	OK	X
1	Works properly — no abnormal noise, vibration, or behaviour		
2	No leaks at flanges, valves, connections		
3	No damage — no dents, corrosion, cracks, impact marks		
4	No other faults or deviations		
5	Correctly marked — nameplate readable, labels in place		
6	Inspections up to date — certificate not expired		

#	ADDITIONAL CHECKS	OK	X
7	Safety valve seal intact, not blocked		
8	Insulation intact (if applicable)		
9	Supports and foundation solid		
10	Drain valve works		

Notes: _____

Vessel: Nr ___ ID: _____ Type: _____

Readings: Pressure _____ bar | Temperature _____ C

#	THE 6 MANDATORY CHECKS	OK	X
1	Works properly — no abnormal noise, vibration, or behaviour		
2	No leaks at flanges, valves, connections		
3	No damage — no dents, corrosion, cracks, impact marks		
4	No other faults or deviations		
5	Correctly marked — nameplate readable, labels in place		
6	Inspections up to date — certificate not expired		

#	ADDITIONAL CHECKS	OK	X
7	Safety valve seal intact, not blocked		
8	Insulation intact (if applicable)		
9	Supports and foundation solid		
10	Drain valve works		

Notes: _____

(Print extra copies for more vessels)

Findings

#	VESSEL	WHAT IS WRONG	HOW SERIOUS	ACTION NEEDED
1			C / Ma / Mi / O	
2			C / Ma / Mi / O	
3			C / Ma / Mi / O	

> C = Critical (stop now) | Ma = Major (fix within 30 days) | Mi = Minor (fix within 90 days) | O = Observation (watch it)

Previous Findings

FROM WHEN	WHAT WAS IT	FIXED NOW?
		Yes / No
		Yes / No
		Yes / No

Round Complete

Vessels checked	___ of ___
Findings this round	___
Old findings closed	___
Overall condition	Good / OK / Needs attention
Signature	
Date	
Next round	