JOHANSSON ENGINEERING

Equipment Inventory — Gothenburg Workshop

Document No.	JDS-LOG-MEC-006
Revision	B
Date	2026-04-10
Status	CURRENT
Author	N. Johansson
Project	JDS-PRJ-MEC-002
Client	Example Workshop AB
Site	Gothenburg Workshop

1. Purpose

This register is the master inventory of all pressurised vessels at Gothenburg Workshop. Classification, risk class, and inspection intervals have been **automatically calculated** per AFS 2017:3 (consolidated) using `jds-classify.py`.

2. Classification Summary

RISK CLASS	COUNT	INSPECTION REGIME
Class A	3	Accredited body: ext. 24 mo, int. 72 mo, press. test 144 mo
Class B	1	Accredited (int.) / own (ext.): ext. 36 mo, int. 72 mo
Below B	0	Own inspection: ext. 72 mo
Simple PV	0	No mandatory periodic inspection
Not classified	0	Below regulatory threshold
Total	**7**	

3. Vessel Identification

VESSEL ID	DESCRIPTION	LOCATION	MANUFACTURER	YEAR	SERIAL NO.
PV-001	Main air receiver	Compressor room	Atlas Copco	2015	AC-2015-4521
PV-002	Workshop air receiver	Workshop B	Kaeser	2018	KS-2018-7892
PV-003	Steam boiler	Boiler house	Bosch	2010	BO-2010-3341
PV-004	Refrigeration receiver	Engine room	Bitzer	2019	BZ-2019-0087
PV-005	Hydraulic accumulator	Workshop A	Parker	2020	PK-2020-1155
PV-006	Expansion vessel	Heating system	Flamco	2021	FL-2021-6629
PV-007	Sandblast receiver	Yard	Clemco	2012	CL-2012-9944

4. Technical Data

VESSEL ID	PS (BAR)	TS MAX (°C)	VOLUME (L)	PS×V (BAR·L)	MEDIUM
PV-001	11.0	40	1000	11,000	compressed air
PV-002	8.0	50	250	2,000	compressed air
PV-003	13.0	180	2000	26,000	steam
PV-004	25.0	60	200	5,000	ammonia
PV-005	250.0	80	10	2,500	hydraulic oil
PV-006	3.0	90	25	75	water
PV-007	10.0	50	500	5,000	compressed air

5. Regulatory Classification (Auto-Generated)

> Classification calculated automatically by `jds-classify.py` per AFS 2017:3.

VESSEL ID	FLUID GRP	PED CAT.	RISK CLASS	INSPECTOR	CE	DOC
PV-001	2	IV	**A**	Accredited body (Type A)	Yes	Yes
PV-002	2	II	**Exempt (air/N2)**	N/A	Yes	Yes
PV-003	2	IV	**A**	Accredited body (Type A)	Yes	Yes
PV-004	1	IV	**A**	Accredited body (Type A)	Yes	Yes
PV-005	2	II	**B**	Accredited body (Type A or B)	Yes	Yes
PV-006	2	Art. 4.3	**Below threshold**	N/A	Yes	Yes
PV-007	2	II	**Exempt (air/N2)**	N/A	Yes	No

6. Inspection Schedule (Auto-Generated)

> Intervals and next due dates calculated automatically from classification and last inspection.

VESSEL ID	EXT. (MO)	INT. (MO)	PRESS. (MO)	LAST INSP.	NEXT EXT.	NEXT INT.
PV-001	48	48	—	2024-06-15	2028-06-15	2028-06-15
PV-002	—	—	—	2025-01-20	—	—
PV-003	24	48	—	2023-09-01	2025-09-01	2027-09-01
PV-004	24	48	—	2025-03-10	2027-03-10	2029-03-10
PV-005	24	—	—	2024-11-30	2026-11-30	—
PV-006	—	—	—	—	—	—
PV-007	—	—	—	2023-04-22	—	—

OVERDUE INSPECTIONS

VESSEL ID	TYPE	WAS DUE	DAYS OVERDUE
PV-003	External	2025-09-01	**221**

7. Safety Devices

DEVICE ID	TYPE	PROTECTS	SET PRESSURE (BAR)	LAST TEST	NEXT TEST
SV-001	Safety valve	PV-001			
SV-003	Safety valve	PV-003			
SV-004	Safety valve	PV-004			
SV-005	Safety valve	PV-005			

8. Documentation Checklist

Vessels PV-001 to PV-006

CHECK	PV-001	PV-002	PV-003	PV-004	PV-005	PV-006
Registered in inventory						
Nameplate photo on file						
EU DoC on file						
Risk class confirmed						
Safety devices documented						
Current certificate on file						

Vessels PV-007 to PV-007

CHECK	PV-007
Registered in inventory	
Nameplate photo on file	
EU DoC on file	
Risk class confirmed	
Safety devices documented	
Current certificate on file	

9. Next Step

This inventory is **Step 1** of the Vessel Supervision System.

```
[INVENTORY]  →  PROGRAM  →  ROUND  →  REVIEW
 (you are       (next)
  here)
```

To generate the supervision program from this inventory, run:

```
python3 scripts/jds-classify.py --program --from [this-file.md] --output [program.md]
```

The script will read this inventory and create a supervision program pre-filled with all vessels, risk-based check schedules, and inspection intervals.

Revision History

REV	DATE	AUTHOR	DESCRIPTION
A	2026-04-10	N. Johansson	Initial inventory — 7 vessels classified