JOHANSSON ENGINEERING

# 04 — What to Check and How Often

This is your supervision plan. It lists the checks you must perform, how often, and who does them. The law requires these checks — fill in the interval for each vessel based on its risk class.

## The 6 Mandatory Checks

> Every supervision round must cover these six points. They are required by law (AFS 2017:3, 2 Kap. §6).

| # | YOU MUST CHECK THAT... | INTERVAL |
|---|---|---|
| 1 | The equipment **works properly** | __ months |
| 2 | **No leaks** have occurred | __ months |
| 3 | No **damage** from external or internal causes | __ months |
| 4 | No **other faults** or deviations | __ months |
| 5 | Equipment is **correctly marked** (labels, warnings) | __ months |
| 6 | Required **inspections have been done** on time | __ months |

> **Typical intervals:** Leak checks: 1 month. Condition/function: 3 months (Class B) or 12 months (Class A). Labels and inspections: 12 months.

## Additional Checks

| # | ALSO CHECK THAT... | INTERVAL |
|---|---|---|
| 7 | Safety valves and devices **work correctly** | __ months |
| 8 | **Documentation** and certificates are on file | 12 months |
| 9 | **Previous findings** have been addressed | __ months |
| 10 | **Lifetime calculations** are up to date (if applicable) | 12 months |

## Who Does What

| ROLE | NAME | WHAT THEY DO |
|---|---|---|
| Round supervisor | | Performs rounds (Doc 05) |
| Program manager | | Annual review (Doc 07), books inspections |
| Backup | | Covers when supervisor is absent |

## Annual Calendar

| MONTH | ROUND | SPECIAL |
|---|---|---|
| Jan | Monthly | Review plan for the year |
| Feb | Monthly | |
| Mar | Quarterly | |
| Apr | Monthly | |
| May | Monthly | |
| Jun | Quarterly | |
| Jul | Monthly | |
| Aug | Monthly | |
| Sep | Quarterly | |
| Oct | Monthly | |
| Nov | Monthly | |
| Dec | Quarterly + Annual | Annual review (Doc 07) |

## If You Find Something Wrong

| SEVERITY | WHAT IT MEANS | WHAT TO DO | HOW FAST |
|---|---|---|---|
| **Critical** | Immediate danger | Shut down, notify operator now | Immediate |
| **Major** | Will get worse | Plan repair, monitor closely | 30 days |
| **Minor** | Noted, not urgent | Monitor, fix when convenient | 90 days |
| **Observation** | Worth watching | Note it, check next round | Next round |

# Approval

| | |
|---|---|
| **Prepared by** | |
| **Signature** | |
| **Date** | |
| | |
| **Approved by (operator)** | |
| **Signature** | |
| **Date** | |
| | |
| **Next review due** | |

> Non-compliance penalty: 10,000 — 100,000 SEK (AFS 2017:3, 4 Kap. §17).