JOHANSSON ENGINEERING

04 — What to Check and How Often

Note: This is your supervision plan. It lists the checks you must perform, how often, and who does them. The law requires these checks — fill in the interval for each vessel based on its risk class.

The 6 Mandatory Checks

Important: Every supervision round must cover these six points. They are required by law (AFS 2017:3, 2 Kap. §6).

#	YOU MUST CHECK THAT...	INTERVAL
1	The equipment **works properly**	__ months
2	**No leaks** have occurred	__ months
3	No **damage** from external or internal causes	__ months
4	No **other faults** or deviations	__ months
5	Equipment is **correctly marked** (labels, warnings)	__ months
6	Required **inspections have been done** on time	__ months

> **Typical intervals:** Leak checks: 1 month. Condition/function: 3 months (Class B) or 12 months (Class A). Labels and inspections: 12 months.

Additional Checks

#	ALSO CHECK THAT...	INTERVAL
7	Safety valves and devices **work correctly**	__ months
8	**Documentation** and certificates are on file	12 months
9	**Previous findings** have been addressed	__ months
10	**Lifetime calculations** are up to date (if applicable)	12 months

Who Does What

ROLE	NAME	WHAT THEY DO
Round supervisor		Performs rounds (Doc 05)
Program manager		Annual review (Doc 07), books inspections
Backup		Covers when supervisor is absent

Annual Calendar

MONTH	ROUND	SPECIAL
Jan	Monthly	Review plan for the year
Feb	Monthly	
Mar	Quarterly	
Apr	Monthly	
May	Monthly	
Jun	Quarterly	
Jul	Monthly	
Aug	Monthly	
Sep	Quarterly	
Oct	Monthly	
Nov	Monthly	
Dec	Quarterly + Annual	Annual review (Doc 07)

If You Find Something Wrong

Warning: A **Critical** finding means immediate danger. Shut down the vessel, isolate it, and notify the operator and coordination person immediately. Do not re-pressurise until the issue is resolved.

SEVERITY	WHAT IT MEANS	WHAT TO DO	HOW FAST
Critical	Immediate danger	Shut down, notify operator now	Immediate
Major	Will get worse	Plan repair, monitor closely	30 days
Minor	Noted, not urgent	Monitor, fix when convenient	90 days
Observation	Worth watching	Note it, check next round	Next round

Approval

Prepared by	
Signature	
Date	
Approved by (operator)	
Signature	
Date	
Next review due	

Warning: Non-compliance penalty: **10,000 — 100,000 SEK** (AFS 2017:3, 4 Kap. §17).