

## **Abstract**

Power stability regulation and high installation costs are major barriers to adoption of renewable energy resources in permanently islanded remote microgrids. In general it will be shown for these remote microgrids which combinations of bus architectures and converter topologies provide optimal system stability and cost. This will be achieved by simulating a hypothetical geothermal-diesel hybrid microgrid at Pilgrim Hot Springs using various conversion topologies. The systems will be modelled from a short time dynamic stability perspective using PSpice and/or MATLAB and longer-term average energy standpoint using MATLAB. A stability analysis will be conducted using the long and short term simulation models which evaluate system voltage and frequency under different conversion topologies. A cost analysis will also be conducted to compare the economic viability of operating the different systems in remote communities. It is expected the system with greatest stability will not be the most cost-effective, but that there is a system which provides stable power within reasonable tolerances at optimal cost.

# Chapter 1

## Introduction

### 1.1 Problem Statement

...

### 1.2 Microgrid Description

Microgrids are electrical systems composed of sources and loads within a well defined electrical boundary. Energy storage is often incorporated into systems as well, but not necessarily. Many microgrids are connected to a larger grid but with the ability to become separated, or islanded, while still maintaining some or all of the loads.

Approximately 70% of the population of Alaska is connected to a single grid called the Railbelt. [1] The Railbelt stretches over 600 miles from the Homer on the Kenai Peninsula to the greater Fairbanks area in the interior and includes most communities on the road system in between. The remaining communities and villages are effectively permanently islanded microgrids.

#### 1.2.1 Sources

Microgrid power is typically generated by Distributed Energy Resources (DER). This can include renewable resources such as solar photovoltaics, wind turbine generators, and geothermal as well as and non-renewable sources such diesel generators and natural gas microturbines.

Diesel generators use the combustion of diesel fuel to spin an alternator. These generators are prolific in rural Alaska generally being used as the prime mover to regulate grid frequency and voltage. Due to their widespread use,

significant energy cost savings can be generated by reducing fuel consumption through efficiency improvements and use of alternate energy sources.

Geothermal generators are heat engines and can operate similarly to traditional coal and nuclear plants. Heat causes a working fluid to thermally expand and change phases thus spinning a turbine. The primary difference is that geothermal systems get heat from the Earth as opposed to combustion or nuclear reactions. Geothermal generators can be divided into high heat and low heat categories. High heat geothermal systems work with temperatures at and above the boiling point of water which means water can be used as the working fluid. Low heat systems operate at temperatures below the boiling point of water therefore must use a refrigerant as an alternative working fluid.

Address wind & solar too.

### **1.2.2 Loads**

Well designed microgrids are designed around expected loads.

Describe dispatchable loads and give some examples.

### **1.2.3 Storage**

Energy storage is beneficial to microgrid operation because it allows generation to be spread over time. Such devices can include batteries, flywheels, supercapacitors, pumped hydro, and more. These devices have different storage duration and discharge times making different storage technologies advantageous in different situations. The discharge of bulk energy storage over the course of many hours allows for load leveling and provides spinning reserve for the grid. Load peak shaving typically involves a discharge time from minutes to several hours. Energy storage discharge over seconds and subseconds is generally done to improve power quality. [2]

Define spinning reserve somewhere

### **1.2.4 Control**

A microgrid control system ties all the other components together. Control systems monitor maintain voltage and frequency of the grid while ensuring sufficient active and reactive power is supplied to the loads.

# Bibliography

- [1] “Alaska Railbelt Cooperative Transmission & Electric Company.” <http://arctec.coop/>. [Online; accessed 2016-05-09].
- [2] S. M. Schoenung and W. V. Hassenzahl, “Long- vs . Short-Term Energy Storage Technologies Analysis A Life-Cycle Cost Study A Study for the DOE Energy Storage Systems Program,” tech. rep., Sandia National Laboratories, 2003.