

INSTRUMENT LIST

Part: Turbine package

Siemens Energy is a trademark licensed by Siemens AG

2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project		Document title INSTRUMENT LIST	Final			
1	Final	03.07.2025	Ledina	Worked by	Ledina							
0	Final	12.02.2025	Ledina	Checked by	Soukenik							
Rev.	Text	Date	Name			Machine No.	6342		Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2	Sheet 1 Sheets 20

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degree of protection	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.		
1	LBA10CP020 1560-PIT-6321	EMERGENCY STOP VALVE INLET PRESSURE	PRESSURE TRANSMITTER	AO/P	CJJ10	IP65	½"NPT, 2-WIRE TECHNIC	0 1450 psi(g)	SIEMENS 7MF0300-1VE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A		
2	LBA10CP021 1560-PIT-6322	EMERGENCY STOP VALVE INLET PRESSURE	PRESSURE TRANSMITTER	AO/P	CJJ10	IP65	½"NPT, 2-WIRE TECHNIC	0 1450 psi(g)	SIEMENS 7MF0300-1VE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A		
3	LBA10CP022 1560-PIT-6323	EMERGENCY STOP VALVE INLET PRESSURE	PRESSURE TRANSMITTER	AO/P	CJJ10	IP65	½"NPT, 2-WIRE TECHNIC	0 1450 psi(g)	SIEMENS 7MF0300-1VE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A		
4	LBA10CT020 1560-TIT-6256	EMERGENCY STOP VALVE INLET TEMPERATURE	THERMOCOUPLE WITH TRANSMITTER	AO/P	CJJ10	IP65	K, 2-WIRE TECHNIC, PC 1" NPT, IC ½" NPT, U=140 mm	32 1112 °F	SIEMENS 7MC7500-1JB26-9GK1-Z E10+N2D+T34+Y01(0-600°C)+Y15+Y33+Y33+Y33+Y45(260mm)		1		
5	LBA10CT021 1560-TIT-6257	EMERGENCY STOP VALVE INLET TEMPERATURE	THERMOCOUPLE WITH TRANSMITTER	AO/P	CJJ10	IP65	K, 2-WIRE TECHNIC, PC 1" NPT, IC ½" NPT, U=140 mm	32 1112 °F	SIEMENS 7MC7500-1JB26-9GK1-Z E10+N2D+T34+Y01(0-600°C)+Y15+Y33+Y33+Y33+Y45(260mm)		1		
6	LBA10CT022 1560-TIT-6258	EMERGENCY STOP VALVE INLET TEMPERATURE	THERMOCOUPLE WITH TRANSMITTER	AO/P	CJJ10	IP65	K, 2-WIRE TECHNIC, PC 1" NPT, IC ½" NPT, U=140 mm	32 1112 °F	SIEMENS 7MC7500-1JB26-9GK1-Z E10+N2D+T34+Y01(0-600°C)+Y15+Y33+Y33+Y33+Y45(260mm)		1		
7	LBB10CG050 1560-ZI-6275	ADMISSION STEAM CONTROL VALVE POSITION	POSITIONER	AO/P	LBB10GA122	IP65	2-WIRE TECHNIC	0 100 %	Pepper+Fuchs ENA36IL-R06DA5-0013I42-RC2	Connected via junction box: LBB10GA121	1		
8	LBB10CG210 1560-ZIO-6283	ADMISSION STEAM ESV OPEN POSITION	POSITION SENSOR	NAMUR	LBB10GA030	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl+Fuchs SJ3,5-SN		1		
9	LBB10CG211 1560-ZIC-6284	ADMISSION STEAM ESV CLOSED POSITION	POSITION SENSOR	NAMUR	LBB10GA030	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl+Fuchs SJ3,5-SN		1		
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project Machine No. 6342  Document title INSTRUMENT LIST		Final					
1	Final	03.07.2025	Ledina	Worked by	Ledina								
0	Final	12.02.2025	Ledina	Checked by	Soukenik			Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev.	2	Sheet	2
Rev.	Text	Date	Name							2		Sheets	20

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.		
10	LBB10CG212 1560-ZIC-6285	ADMISSION STEAM ESV CLOSED POSITION	POSITION SENSOR	NAMUR	LBB10GA030	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl+Fuchs SJ3,5-SN		1		
11	LBB10CP010 1560-PIT-6320	ADMISSION STEAM INLET PRESSURE	PRESSURE TRANSMITTER	AO/P	CJJ10	IP65	½"NPT, 2-WIRE TECHNIC	0 232 psi(g)	SIEMENS 7MF0300-1QE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A		
12	LBB10CT010 1560-TIT-6255	ADMISSION STEAM INLET TEMPERATURE	THERMOCOUPLE WITH TRANSMITTER	AO/P	CJJ10	IP65	K, 2-WIRE TECHNIC, PC 1" NPT, IC ½" NPT, U=140 mm	32 752 °F	SIEMENS 7MC7500-1JB26-9GK1-Z E10+N2D+T34+Y01(0-400°C)+Y15+Y33+Y33+Y33+Y45(260mm)		1		
13	LBD10CG010 1560-ZI-6276	EXTRACTION STEAM NON RETURN VALVE POSITION	POSITION TRANSMITTER	AO/A	TERMINALS	IP67	3-WIRE TECHNIC	0 100 %	Pepperl+Fuchs PMI360DV-F130-IU-V15		A		
14	LBD10CG210 1560-ZIC-6368	EXTRACTION STEAM NON RETURN VALVE CLOSED POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl+Fuchs NJ2-12GM-N-V1		1		
15	LBD10CG211 1560-ZIO-6369	EXTRACTION STEAM NON RETURN VALVE OPEN POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl+Fuchs NJ2-12GM-N-V1		1		
16	LBD10CP010 1560-PIT-6316	EXTRACTION PRESSURE	PRESSURE TRANSMITTER	AO/P	CJJ10	IP65	½"NPT, 2-WIRE TECHNIC	-12,18 132,82 psi(g)	SIEMENS 7MF0320-1RE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		1		
17	LBD10CP220 1560-PS-6300	EXTRACTION PRESSURE	PRESSURE SWITCH	SPDT	CJJ10	IP65	½"NPT, CONTACT LOAD 24V/0,5A	0 145 psi(g)	WIKA MW1-XX-U4-0/145 psig-½"NPT-M20x1,5-93,4psig-rising		1		
18	LBD10CP221 1560-PS-6301	EXTRACTION PRESSURE	PRESSURE SWITCH	SPDT	CJJ10	IP65	½"NPT, CONTACT LOAD 24V/0,5A	0 145 psi(g)	WIKA MW1-XX-U4-0/145 psig-½"NPT-M20x1,5-93,4psig-rising		1		
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project Machine No. 6342  Document title INSTRUMENT LIST		Final					
1	Final	03.07.2025	Ledina	Worked by	Ledina								
0	Final	12.02.2025	Ledina	Checked by	Soukenik			Doc. number		6342-4DC-407	Rev.	Sheet	3
Rev.	Text	Date	Name							1500-IN-VEN-4523-EXP-0401	2	Sheets	20

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.		
19	LBD10CP222 1560-PS-6303	EXTRACTION PRESSURE	PRESSURE SWITCH	SPDT	CJJ10	IP65	½"NPT, CONTACT LOAD 24V/0,5A	0 145 psi(g)	WIKA MW1-XX-U4-0/145 psig-½"NPT- M20x1,5-93,4psig-rising		1		
20	LBD10CT010 1560-TE-6235	EXTRACTION TEMPERATURE	RTD	Pt100	CJJ10	IP65	Pt100, 3-WIRE RTD, PC 1" NPT, IC ½" NPT, U=140 mm	32 752 °F	SIEMENS 7MC7500-1JB26-3GC1-Z E10+Y15+Y33+Y33+Y33		1		
21	LCE10CG210 1560-ZIC-6366	EXHAUST STEAM INJECTION CLOSED POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
22	LCE10CG211 1560-ZIO-6367	EXHAUST STEAM INJECTION OPEN POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
23	LCE20CG010 1560-ZI-6522	SEAL STEAM CONDENSATE INJECTION CV POSITION	POSITIONER	AO/P	TERMINALS	IP66	2-WIRE TECHNIC	0 100 %	SIEMENS SIPART PS2		A		
24	LCE80CG210 1560-ZIC-6350	FLASH PIPE CONDENSATE INJECTION VALVE CLOSED POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
25	LCE80CG211 1560-ZIO-6351	FLASH PIPE CONDENSATE INJECTION VALVE OPEN POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
26	MAA10CG050 1560-ZI-6270	CONTROL VALVE 1 POSITION	POSITION TRANSMITTER	AO/A	24VDC MAA10GA121	IP67		0 3,94 in	MTS TEMPOSONICS RH5-M-A-0100M-01-D60-1-A-1-0-1		0		
27	MAA10CG060 1560-ZI-6271	CONTROL VALVE 2 POSITION	POSITION TRANSMITTER	AO/A	24VDC MAA10GA121	IP67		0 3,94 in	MTS TEMPOSONICS RH5-M-A-0100M-01-D60-1-A-1-0-1		0		
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project Machine No. 6342  Document title INSTRUMENT LIST		Final					
1	Final	03.07.2025	Ledina	Worked by	Ledina								
0	Final	12.02.2025	Ledina	Checked by	Soukenik								
Rev.	Text	Date	Name										
								Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev.	2	Sheet	4
												Sheets	20

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degree of protection	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.		
28	MAA10CG070 1560-ZI-6272	CONTROL VALVE 3 POSITION	POSITION TRANSMITTER	AO/A	24VDC MAA10GA122	IP67		0 3,94 in	MTS TEMPOSONICS RH5-M-A-0100M-01-D60-1-A-1-0-1		0		
29	MAA10CG080 1560-ZI-6273	CONTROL VALVE 4 POSITION	POSITION TRANSMITTER	AO/A	24VDC MAA10GA122	IP67		0 3,94 in	MTS TEMPOSONICS RH5-M-A-0100M-01-D60-1-A-1-0-1		0		
30	MAA10CG210 1560-ZIC-6260	EMERGENCY STOP VALVE 1 CLOSED POSITION	POSITION SWITCH	SPDT	24V DC MAA10GA030	IP67	CONTACT LOAD 250V DC/0,25A	- -	HONEYWELL BZ-2RW822244-A2		A		
31	MAA10CG211 1560-ZIO-6281	EMERGENCY STOP VALVE 1 OPEN POSITION	POSITION SWITCH	SPDT	24V DC MAA10GA030	IP67	CONTACT LOAD 250V DC/0,25A	- -	HONEYWELL BZ-2RW822244-A2		A		
32	MAA10CG213 1560-ZIC-6282	EMERGENCY STOP VALVE 1 CLOSED POSITION	POSITION SWITCH	SPDT	24V DC MAA10GA030	IP67	CONTACT LOAD 250V DC/0,25A	- -	HONEYWELL BZ-2RW822244-A2		A		
33	MAA10CG215 1560-ZIC-6352	ESV DRAIN VALVE CLOSED POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
34	MAA10CG216 1560-ZIO-6353	ESV DRAIN VALVE OPEN POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
35	MAA10CG220 1560-ZIC-6357	CONTROL VALVE INLET MAIN STEAM DRAIN VALVE CLOSED POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
36	MAA10CG221 1560-ZIO-6358	CONTROL VALVE INLET MAIN STEAM DRAIN VALVE OPEN POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project  Machine No. 6342		Document title INSTRUMENT LIST	Final				
1	Final	03.07.2025	Ledina	Worked by	Ledina								
0	Final	12.02.2025	Ledina	Checked by	Soukenik								
Rev.	Text	Date	Name										
									Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2	Sheet 5 Sheets 20	

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.		
37	MAA10CP020 1560-PIT-6330A	HP STAGE GROUP INLET PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA041	IP65	½"NPT, 2-WIRE TECHNIC	-12,18 857,8 psi(g)	SIEMENS 7MF0320-1VE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		2		
38	MAA10CP021 1560-PIT-6330B	HP STAGE GROUP INLET PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA041	IP65	½"NPT, 2-WIRE TECHNIC	-12,18 857,8 psi(g)	SIEMENS 7MF0320-1VE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		2		
39	MAA10CP022 1560-PIT-6330C	HP STAGE GROUP INLET PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA041	IP65	½"NPT, 2-WIRE TECHNIC	-12,18 857,8 psi(g)	SIEMENS 7MF0320-1VE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		2		
40	MAA11CG210 1560-ZIC-6371	BALANCE PISTON AK1 DRAIN VALVE CLOSED POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
41	MAA11CG211 1560-ZIO-6372	BALANCE PISTON AK1 DRAIN VALVE OPEN POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
42	MAA12CG210 1560-ZIC-6361	DRAIN OF TURBINE CONTROL STAGE CLOSED POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
43	MAA12CG211 1560-ZIO-6362	DRAIN OF TURBINE CONTROL STAGE OPEN POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
44	MAA13CG210 1560-ZIC-6363	TURBINE CASING DRAIN VALVE CLOSED POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
45	MAA13CG211 1560-ZIO-6364	TURBINE CASING DRAIN VALVE OPEN POSITION	POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project Machine No. 6342  Document title INSTRUMENT LIST		Final					
1	Final	03.07.2025	Ledina	Worked by	Ledina								
0	Final	12.02.2025	Ledina	Checked by	Soukenik			Doc. number		6342-4DC-407	Rev.	Sheet	6
Rev.	Text	Date	Name					1500-IN-VEN-4523-EXP-0401		2	Sheets	20	

No.	Item No	Designation				Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.		
46	MAA14CG210 1560-ZIC-6365	ADMISSION STEAM DRAIN VALVE CLOSED POSITION				POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
47	MAA14CG211 1560-ZIO-6370	ADMISSION STEAM DRAIN VALVE OPEN POSITION				POSITION SENSOR	NAMUR	CONNECTOR	IP67	2-WIRE INDUCTIVE SENSOR	- -	Pepperl-Fuchs NJ4-12GM-N		1		
48	MAA15CT010 1560-TE-6250	CASING FLANGE 50% TEMPERATURE				THERMOCOUPLE WITH TRANSMITTER	AO/P	MAA10GA040	IP65	K, 2-WIRE TECHNIC, Ø6mm, 3000mm	32 1112 °F	SIEMENS 7MC7500-1NX06-0GK1-Z E10+G50+T34+Y01+Y15+Y33+Y33 +Y33+Y44(3000mm)+Y99		1		
49	MAA15CT011 1560-TE-6251	CASING FLANGE 100% TEMPERATURE				THERMOCOUPLE WITH TRANSMITTER	AO/P	MAA10GA040	IP65	K, 2-WIRE TECHNIC, Ø6mm, 3000mm	32 1112 °F	SIEMENS 7MC7500-1NX06-0GK1-Z E10+G50+T34+Y01+Y15+Y33+Y33 +Y33+Y44(3000mm)+Y99		1		
50	MAA15CT050 1560-TE-6253	CASING WALL UPPER HALF TEMPERATURE				THERMOCOUPLE WITH TRANSMITTER	AO/P	MAA10GA040	IP65	K, 2-WIRE TECHNIC, Ø6mm, 3000mm	32 1112 °F	SIEMENS 7MC7500-1NX06-0GK1-Z E10+G50+T34+Y01+Y15+Y33+Y33 +Y33+Y44(3000mm)+Y99		1		
51	MAA15CT060 1560-TE-6254	CASING WALL LOWER HALF TEMPERATURE				THERMOCOUPLE WITH TRANSMITTER	AO/P	MAA10GA040	IP65	K, 2-WIRE TECHNIC, Ø6mm, 3000mm	32 1112 °F	SIEMENS 7MC7500-1NX06-0GK1-Z E10+G50+T34+Y01+Y15+Y33+Y33 +Y33+Y44(3000mm)+Y99		1		
52	MAC10CG010 1560-ZI-6274	ROTARY SLIDE VALVE POSITION				POSITION TRANSMITTER	AO/A	24VDC MAA10GA123	IP67		0 3,94 in	MTS TEMPOSONICS RH5-M-A-0100M-01-D60-1-A-1-0-1		0		
53	MAC10CP040 1560-PIT-6333	LAST STAGE INLET PRESSURE				PRESSURE TRANSMITTER	AO/P	MAA10GA041	IP65	½"NPT, 2-WIRE TECHNIC	0 58 psi(a)	SIEMENS 7MF0320-1PE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		2		
54	MAC10CP041 1560-PIT-6334	LAST STAGE INLET PRESSURE				PRESSURE TRANSMITTER	AO/P	MAA10GA041	IP65	½"NPT, 2-WIRE TECHNIC	0 58 psi(a)	SIEMENS 7MF0320-1PE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		2		
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project  Machine No. 6342		Document title INSTRUMENT LIST		Final						
1	Final	03.07.2025	Ledina	Worked by	Ledina											
0	Final	12.02.2025	Ledina	Checked by	Soukenik					Doc. number		6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev.	2	Sheet	7
Rev.	Text	Date	Name												Sheets	20

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degree of protection	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.
55	MAC10CP050 1560-PIT-6317A	EXHAUST STEAM PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA040	IP65	½"NPT, 2-WIRE TECHNIC	0 23,2 psi(a)	SIEMENS 7MF0320-1PE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A
56	MAC10CP051 1560-PIT-6317B	EXHAUST STEAM PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA040	IP65	½"NPT, 2-WIRE TECHNIC	0 23,2 psi(a)	SIEMENS 7MF0320-1PE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A
57	MAC10CP052 1560-PIT-6317C	EXHAUST STEAM PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA040	IP65	½"NPT, 2-WIRE TECHNIC	0 23,2 psi(a)	SIEMENS 7MF0320-1PE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A
58	MAC10CT050 1560-TE-6232A	EXHAUST STEAM TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	Pt100, 3-WIRE RTD, (Ø6mm, M18x1,5, 260mm)	32 392 °F	SIEMENS 7MC7500-1UC26-9GC1-Z E10+N2D+Y15+Y33+Y33+Y33+Y45(260mm)		1
59	MAC10CT051 1560-TE-6232B	EXHAUST STEAM TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	Pt100, 3-WIRE RTD, (Ø6mm, M18x1,5, 260mm)	32 392 °F	SIEMENS 7MC7500-1UC26-9GC1-Z E10+N2D+Y15+Y33+Y33+Y33+Y45(260mm)		1
60	MAC10CT052 1560-TE-6232C	EXHAUST STEAM TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	Pt100, 3-WIRE RTD, (Ø6mm, M18x1,5, 260mm)	32 392 °F	SIEMENS 7MC7500-1UC26-9GC1-Z E10+N2D+Y15+Y33+Y33+Y33+Y45(260mm)		1
61	MAD10CG010 1560-ZT-6290A	FRONT END TURBINE AXIAL SHAFT POSITION	DRIVER		MAA10GA150		FOR CABLE L=5m	- -	EMERSON EZ1000		1
62	MAD10CG010 1560-ZE-6290A	FRONT END TURBINE AXIAL SHAFT POSITION	EDDY CURRENT PROBE		CONNECTOR	IP65	THREAD M10x1	19,7 98,4 mils	EMERSON EZ1080-03-00-050		1
63	MAD10CG011 1560-ZT-6290B	FRONT END TURBINE AXIAL SHAFT POSITION	DRIVER		MAA10GA150		FOR CABLE L=5m	- -	EMERSON EZ1000		1
2	Final	13.08.2025	Ledina	Date	16.12.2024			Document title INSTRUMENT LIST	Final		
1	Final	03.07.2025	Ledina	Worked by	Ledina						
0	Final	12.02.2025	Ledina	Checked by	Soukenik						
Rev.	Text	Date	Name						Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2 Sheets 20
Thacker Pass Project						Machine No. 6342					

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.		
64	MAD10CG011 1560-ZE-6290B	FRONT END TURBINE AXIAL SHAFT POSITION	EDDY CURRENT PROBE		CONNECTOR	IP65	THREAD M10x1	19,7 98,4 mils	EMERSON EZ1080-03-00-050		1		
65	MAD10CG012 1560-ZT-6290C	FRONT END TURBINE AXIAL SHAFT POSITION	DRIVER		MAA10GA150		FOR CABLE L=5m	- -	EMERSON EZ1000		1		
66	MAD10CG012 1560-ZE-6290C	FRONT END TURBINE AXIAL SHAFT POSITION	EDDY CURRENT PROBE		CONNECTOR	IP65	THREAD M10x1	19,7 98,4 mils	EMERSON EZ1080-03-00-050		1		
67	MAD10CS010 1560-SE-6390A	TURBINE SPEED	HALL PROBE		MAA10GA010	IP67	THREAD M12x1, SENSITIVE ON LEADING EDGE	1,5 2,1 mm	BRAUN A5S07C50R1-5m		A		
68	MAD10CS011 1560-SE-6390B	TURBINE SPEED	HALL PROBE		MAA10GA010	IP67	THREAD M12x1, SENSITIVE ON LEADING EDGE	1,5 2,1 mm	BRAUN A5S07C50R1-5m		A		
69	MAD10CS012 1560-SE-6390C	TURBINE SPEED	HALL PROBE		MAA10GA010	IP67	THREAD M12x1, SENSITIVE ON LEADING EDGE	1,5 2,1 mm	BRAUN A5S07C50R1-5m		A		
70	MAD10CT010 1560-TE-6202	FRONT END TURBINE RADIAL BEARING TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DITTMER 4.91.00.XX	TOGETHER WITH 1560-TE-6205	0		
71	MAD10CT011 1560-TE-6205	FRONT END TURBINE RADIAL BEARING TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DITTMER 4.91.00.XX	TOGETHER WITH 1560-TE-6202	0		
72	MAD10CT020 1560-TE-6203	LOADED SIDE AXIAL BEARING TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DITTMER 4.91.00.XX	TOGETHER WITH 1560-TE-6206	0		
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project Machine No. 6342  Document title INSTRUMENT LIST		Final					
1	Final	03.07.2025	Ledina	Worked by	Ledina								
0	Final	12.02.2025	Ledina	Checked by	Soukenik			Doc. number	6342-4DC-407	Rev.	2	Sheet	9
Rev.	Text	Date	Name					1500-IN-VEN-4523-EXP-0401				Sheets	20

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.		
73	MAD10CT021 1560-TE-6206	LOADED SIDE AXIAL BEARING TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DITTMER 4.91.00.XX	TOGETHER WITH 1560- TE-6203	0		
74	MAD10CT030 1560-TE-6204	UNLOADED SIDE AXIAL BEARING TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DITTMER 4.91.00.XX	TOGETHER WITH 1560- TE-6207	0		
75	MAD10CT031 1560-TE-6207	UNLOADED SIDE AXIAL BEARING TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DITTMER 4.91.00.XX	TOGETHER WITH 1560- TE-6204	0		
76	MAD10CY011 1560-VT-6293	FRONT END TURBINE X-AXIS SHAFT VIBRATION	DRIVER		MAA10GA150		FOR CABLE L=5m	- -	EMERSON EZ1000		1		
77	MAD10CY011 1560-VE-6293	FRONT END TURBINE X-AXIS SHAFT VIBRATION	EDDY CURRENT PROBE		CONNECTOR	IP65	THREAD M10x1	19,7 98,4 mils	EMERSON EZ1080-03-00-050		1		
78	MAD10CY012 1560-VT-6294	FRONT END TURBINE Y-AXIS SHAFT VIBRATION	DRIVER		MAA10GA150		FOR CABLE L=5m	- -	EMERSON EZ1000		1		
79	MAD10CY012 1560-VE-6294	FRONT END TURBINE Y-AXIS SHAFT VIBRATION	EDDY CURRENT PROBE		CONNECTOR	IP65	THREAD M10x1	19,7 98,4 mils	EMERSON EZ1080-03-00-050		1		
80	MAD20CT010 1560-TE-6208	REAR END TURBINE RADIAL BEARING TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DITTMER 4.91.00.XX	TOGETHER WITH 1560- TE-6209	0		
81	MAD20CT011 1560-TE-6209	REAR END TURBINE RADIAL BEARING TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DITTMER 4.91.00.XX	TOGETHER WITH 1560- TE-6208	0		
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project Machine No. 6342  Document title INSTRUMENT LIST		Final					
1	Final	03.07.2025	Ledina	Worked by	Ledina								
0	Final	12.02.2025	Ledina	Checked by	Soukenik			Doc. number		6342-4DC-407	Rev.	Sheet	10
Rev.	Text	Date	Name							1500-IN-VEN-4523-EXP-0401	2	Sheets	20

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.	
82	MAD20CY011 1560-VT-6295	REAR END TURBINE X-AXIS SHAFT VIBRATION	DRIVER		MAA10GA060		FOR CABLE L=5m	- -	EMERSON EZ1000		1	
83	MAD20CY011 1560-VE-6295	REAR END TURBINE X-AXIS SHAFT VIBRATION	EDDY CURRENT PROBE		CONNECTOR	IP65	THREAD M10x1	19,7 98,4 mils	EMERSON EZ1080-03-00-050		1	
84	MAD20CY012 1560-VT-6296	REAR END TURBINE Y-AXIS SHAFT VIBRATION	DRIVER		MAA10GA060		FOR CABLE L=5m	- -	EMERSON EZ1000		1	
85	MAD20CY012 1560-VE-6296	REAR END TURBINE Y-AXIS SHAFT VIBRATION	EDDY CURRENT PROBE		CONNECTOR	IP65	THREAD M10x1	19,7 98,4 mils	EMERSON EZ1080-03-00-050		1	
86	MAD30CT010 1560-TE-6210	TURBINE END PINION BEARING TEMPERATURE	RTD	Pt100	MAA10GA200	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DELIVERED BY WIKOV	TOGETHER WITH 1560-TE-6214	0	
87	MAD30CT011 1560-TE-6214	TURBINE END PINION BEARING TEMPERATURE	RTD	Pt100	MAA10GA200	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DELIVERED BY WIKOV	TOGETHER WITH 1560-TE-6210	0	
88	MAD40CT010 1560-TE-6211	GENERATOR END PINION BEARING TEMPERATURE	RTD	Pt100	MAA10GA200	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DELIVERED BY WIKOV	TOGETHER WITH 1560-TE-6215	0	
89	MAD40CT011 1560-TE-6215	GENERATOR END PINION BEARING TEMPERATURE	RTD	Pt100	MAA10GA200	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DELIVERED BY WIKOV	TOGETHER WITH 1560-TE-6211	0	
90	MAD40CY010 1560-ST-6297	GEARBOX PINION KEYPHASOR	DRIVER		MAA10GA070		FOR CABLE L=5m	- -	EMERSON EZ1000		1	
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project 		Document title INSTRUMENT LIST	Final			
1	Final	03.07.2025	Ledina	Worked by	Ledina							
0	Final	12.02.2025	Ledina	Checked by	Soukenik							
Rev.	Text	Date	Name									
Machine No. 6342								Doc. number 6342-4DC-407 1500-IN-VEN-4523-EXP-0401		Rev. 2	Sheet 11 Sheets 20	

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.	
91	MAD40CY010 1560-SE-6297	GEARBOX PINION KEYPHASOR	EDDY CURRENT PROBE		CONNECTOR	IP65	THREAD M10x1	19,7 98,4 mils	EMERSON EZ1080-03-00-050		1	
92	MAD50CT010 1560-TE-6212	TURBINE END WHEEL BEARING TEMPERATURE	RTD	Pt100	MAA10GA200	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DELIVERED BY WIKOV	TOGETHER WITH 1560- TE-6216	0	
93	MAD50CT011 1560-TE-6216	TURBINE END WHEEL BEARING TEMPERATURE	RTD	Pt100	MAA10GA200	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DELIVERED BY WIKOV	TOGETHER WITH 1560- TE-6212	0	
94	MAD50CY010 1560-ST-6298	GEARBOX WHEEL KEYPHASOR	DRIVER		MAA10GA070		FOR CABLE L=5m	- -	EMERSON EZ1000		1	
95	MAD50CY010 1560-SE-6298	GEARBOX WHEEL KEYPHASOR	EDDY CURRENT PROBE		CONNECTOR	IP65	THREAD M10x1	19,7 98,4 mils	EMERSON EZ1080-03-00-050		1	
96	MAD60CT010 1560-TE-6213	GENERATOR END WHEEL BEARING TEMPERATURE	RTD	Pt100	MAA10GA200	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DELIVERED BY WIKOV	TOGETHER WITH 1560- TE-6217	0	
97	MAD60CT011 1560-TE-6217	GENERATOR END WHEEL BEARING TEMPERATURE	RTD	Pt100	MAA10GA200	IP65	2×Pt100, 3-WIRE RTD	32 392 °F	DELIVERED BY WIKOV	TOGETHER WITH 1560- TE-6213	0	
98	MAK10CY010 1560-VT-6380	GEARBOX VERTICAL CASING VIBRATION	ACCELEROMETER		MAA10GA070		THREAD M8x1	0 1 in/s	EMERSON 780A		1	
99	MAK10CY020 1560-VT-6381	GEARBOX HORIZONTAL CASING VIBRATION	ACCELEROMETER		MAA10GA070		THREAD M8x1	0 1 in/s	EMERSON 780A		1	
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project  Machine No. 6342		Document title INSTRUMENT LIST	Final			
1	Final	03.07.2025	Ledina	Worked by	Ledina							
0	Final	12.02.2025	Ledina	Checked by	Soukenik							
Rev.	Text	Date	Name							Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.		
100	MAK40CG210 1560-ZIC-6286	COVER HOOD CLOSED POSITION	POSITION SWITCH	SPDT	24V DC MAA10GA200	IP66	CONTACT LOAD 30V DC/0,2A	- -	Microprecision MP601-L02-C00 M8 WITH 5 M		2		
101	MAL15CT010 1560-TE-6236	FLASH PIPE TEMPERATURE	RTD	Pt100	CJJ10	IP65	Pt100, 3-WIRE RTD, PC 1" NPT, IC ½" NPT, U=260 mm	32 752 °F	SIEMENS 7MC7500-1JC26-3GC1-Z E10+Y15+Y33+Y33+Y33		1		
102	MAL20CL010 1560-LI-6278A	DRAIN TANK LEVEL	FLOAT SENSOR	AO/P	CJJ10	IP65	2-WIRE TECHNIC	0 57,09 in	KSR KUEBLER BNA-EN25/16/B1-MG-AVK5-T32S- L1500-M1350-V60x2-MRA-ZVSS185		1		
103	MAL20CL011 1560-LI-6278B	DRAIN TANK LEVEL	FLOAT SENSOR	AO/P	CJJ10	IP65	2-WIRE TECHNIC	0 57,09 in	KSR KUEBLER BNA-EN25/16/B1-MG-AVK5-T32S- L1500-M1350-V60x2-ZVSS185		1		
104	MAL20CL012 1560-LI-6278C	DRAIN TANK LEVEL	FLOAT SENSOR	AO/P	CJJ10	IP65	2-WIRE TECHNIC	0 57,09 in	KSR KUEBLER BNA-EN25/16/B1-MG-AVK5-T32S- L1500-M1350-V60x2-ZVSS185		1		
105	MAM10CL210 1560-LSH-6345	GLAND STEAM CONDENSER CONDENSATE LEVEL IN SIPHON	LEVEL VIBRATION TYPE	DO/A	24V DC CJJ10	IP65	3-WIRE TECHNIC	- - -	SIEMENS SITRANS LVL200 (7ML5746-5AA13- 1AA0-Z/C05+Y17)		1		
106	MAV10CL010 1560-LI-6262A	LUBE OIL TANK LEVEL	FLOAT SENSOR	AO/P	MAA10GA240	IP65	2-WIRE TECHNIC	0 27,56 in	EKOREX BVC-61.13.16	TOGETHER WITH 1560- TIT-6261	0		
107	MAV10CL011 1560-LI-6262B	LUBE OIL TANK LEVEL	FLOAT SENSOR	AO/P	MAA10GA240	IP65	2-WIRE TECHNIC	0 27,56 in	EKOREX BVC-61.13.16		A		
108	MAV10CL012 1560-LI-6262C	LUBE OIL TANK LEVEL	FLOAT SENSOR	AO/P	MAA10GA240	IP65	2-WIRE TECHNIC	0 27,56 in	EKOREX BVC-61.13.16		A		
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project  Machine No. 6342		Document title INSTRUMENT LIST	Final				
1	Final	03.07.2025	Ledina	Worked by	Ledina								
0	Final	12.02.2025	Ledina	Checked by	Soukenik								
Rev.	Text	Date	Name										
									Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2	Sheet 13 Sheets 20	

No.	Item No	Designation				Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.
109	MAV10CT010 1560-TIT-6261	LUBE OIL TANK TEMPERATURE				RTD WITH TRANSMITTER	AO/P	MAA10GA240	IP65	Pt100, 2-WIRE TECHNIC	32 212 °F	EKOREX BVC-61.13.16	TOGETHER WITH 1560-LI-6262A	0
110	MAV10CT020 1560-TE-6231	LUBE OIL TANK HEATING TEMPERATURE				RTD	Pt100	MAA10GA290		Pt100, 3-WIRE RTD	32 212 °F	OMEGA Engineering, Inc. PR-10-2-100-1/4-6-E		A
111	MAV35CP010 1560-PDIT-6324	LUBE OIL FILTER DIFFERENTIAL PRESSURE				DIFFERENTIAL PRESSURE TRANSMITTER	AO/P	MAA10GA240	IP65	2-WIRE TECHNIC	0 23,2 psi	SIEMENS 7MF0340-1ML01-5AF2-Z A00+C11+E01+H02+Y01+Y15+Y32		A
112	MAV40CP010 1560-PIT-6325A	LUBE OIL PRESSURE				PRESSURE TRANSMITTER	AO/P	MAA10GA240	IP65	½"NPT, 2-WIRE TECHNIC	0 58 psi(g)	SIEMENS 7MF0300-1NE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A
113	MAV40CP011 1560-PIT-6325B	LUBE OIL PRESSURE				PRESSURE TRANSMITTER	AO/P	MAA10GA240	IP65	½"NPT, 2-WIRE TECHNIC	0 58 psi(g)	SIEMENS 7MF0300-1NE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A
114	MAV40CP012 1560-PIT-6325C	LUBE OIL PRESSURE				PRESSURE TRANSMITTER	AO/P	MAA10GA240	IP65	½"NPT, 2-WIRE TECHNIC	0 58 psi(g)	SIEMENS 7MF0300-1NE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A
115	MAV40CT010 1560-TE-6237A	LUBE OIL TEMPERATURE				RTD	Pt100	MAA10GA290	IP65	Pt100, 3-WIRE RTD, PC ½" NPT, U=160mm	32 212 °F	SIEMENS 7MC7511-1JB04-1GC1-Z C12+E10+Y15+Y33+Y33+Y33		1
116	MAV40CT011 1560-TE-6237B	LUBE OIL TEMPERATURE				RTD	Pt100	MAA10GA290	IP65	Pt100, 3-WIRE RTD, PC ½" NPT, U=160mm	32 212 °F	SIEMENS 7MC7511-1JB04-1GC1-Z C12+E10+Y15+Y33+Y33+Y33		1
117	MAV40CT012 1560-TE-6237C	LUBE OIL TEMPERATURE				RTD	Pt100	MAA10GA290	IP65	Pt100, 3-WIRE RTD, PC ½" NPT, U=160mm	32 212 °F	SIEMENS 7MC7511-1JB04-1GC1-Z C12+E10+Y15+Y33+Y33+Y33		1
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project			Document title INSTRUMENT LIST	Final				
1	Final	03.07.2025	Ledina	Worked by	Ledina									
0	Final	12.02.2025	Ledina	Checked by	Soukenik									
Rev.	Text	Date	Name			Machine No.	6342			Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2	Sheet Sheets	14 20

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.			
118	MAV70CP020 1560-PIT-6328	JACKING OIL CONTROL VALVE BLOCK INLET PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA240	IP65	½"NPT, 2-WIRE TECHNIC	0 3625 psi(g)	SIEMENS 7MF0300-1WE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A			
119	MAW20CG010 1560-ZY-6265	SEAL STEAM CONTROL VALVE POSITION	POSITIONER	AO/P	TERMINALS	IP66	2-WIRE TECHNIC	0 100 %	SIEMENS SIPART PS2		A			
120	MAW40CP010 1560-PIT-6329	REAR END SEAL STEAM PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA041	IP65	½"NPT, 2-WIRE TECHNIC	0 3,63 psi(g)	SIEMENS 7MF0300-1FE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		2			
121	MAW40CT010 1560-TE-6247	REAR END SEAL STEAM TEMPERATURE	RTD	Pt100	MAA10GA190	IP65	Pt100, 3-WIRE RTD, PC 1" NPT, IC ½" NPT, U=140 mm	32 752 °F	SIEMENS 7MC7500-1JB26-3GC1-Z E10+Y15+Y33+Y33+Y33		2			
122	MAX10CL010 1560-ZE-6299	CONTROL OIL TANK LEVEL	FLOAT SENSOR	AO/P	MAA10GA220	IP65	2-WIRE TECHNIC	0 11,61 in	EKOREX BVC-62.13.14		1			
123	MAX10CT010 1560-TE-6201	CONTROL OIL TANK TEMPERATURE	RTD	Pt100	MAA10GA220	IP65	Pt100, 3-WIRE RTD	32 212 °F	JSP T1070 06 F2 B00 L545 H1 S5 D3 + J99(1/2"NPT)		1			
124	MAX30CP010 1560-PDIT-6310	CONTROL OIL FILTER DIFFERENTIAL PRESSURE	DIFFERENTIAL PRESSURE TRANSMITTER	AO/P	MAA10GA220	IP65	2-WIRE TECHNIC	0 116 psi	SIEMENS 7MF0350-1RL01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A			
125	MAX40CP010 1560-PIT-6311	TRIP OIL TEST PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA220	IP65	½"NPT, 2-WIRE TECHNIC	0 3625 psi(g)	SIEMENS 7MF0300-1WE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A			
126	MAX40CP020 1560-PIT-6312A	TRIP OIL PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA220	IP65	½"NPT, 2-WIRE TECHNIC	0 3625 psi(g)	SIEMENS 7MF0300-1WE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A			
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project  Machine No. 6342		Document title INSTRUMENT LIST	Final					
1	Final	03.07.2025	Ledina	Worked by	Ledina									
0	Final	12.02.2025	Ledina	Checked by	Soukenik									
Rev.	Text	Date	Name						Machine No.	6342		Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev.
													Sheets	20

No.	Item No	Designation				Measuring Instrument	Signal	Power supply Cable connection	Degree of protection	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.
127	MAX40CP021 1560-PIT-6312B	TRIP OIL PRESSURE				PRESSURE TRANSMITTER	AO/P	MAA10GA220	IP65	½"NPT, 2-WIRE TECHNIC	0 3625 psi(g)	SIEMENS 7MF0300-1WE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A
128	MAX40CP022 1560-PIT-6312C	TRIP OIL PRESSURE				PRESSURE TRANSMITTER	AO/P	MAA10GA220	IP65	½"NPT, 2-WIRE TECHNIC	0 3625 psi(g)	SIEMENS 7MF0300-1WE01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A
129	MAX51CP020 1560-PDIT-6315	CONTROL OIL COOLER FILTER DIFFERENTIAL PRESSURE				DIFFERENTIAL PRESSURE TRANSMITTER	AO/P	MAA10GA220	IP65	2-WIRE TECHNIC	0 116 psi	SIEMENS 7MF0350-1RL01-5AF1-Z A00+C11+E01+H02+Y01+Y15+Y32		A
130	MKA10CL210 1560-LSH-6343	TURBINE END GENERATOR PAN LEAKAGE WATER LEVEL				LEVEL VIBRATION TYPE	DO/A	24V DC MKA10GA020	IP65	3-WIRE TECHNIC	- -	SIEMENS SITRANS LVL100		1
131	MKA10CL220 1560-LSH-6340	EXCITER END GENERATOR PAN LEAKAGE WATER LEVEL				LEVEL VIBRATION TYPE	DO/A	24V DC MKA10GA020	IP65	3-WIRE TECHNIC	- -	SIEMENS SITRANS LVL100		1
132	MKA10CL221 1560-LSH-6341	TURBINE END GENERATOR PAN 3 LEAKAGE WATER LEVEL Canceled				LEVEL VIBRATION TYPE	DO/A	24V DC MKA10GA020	IP65	3-WIRE TECHNIC	- -	SIEMENS SITRANS LVL100		2
133	MKA10CL222 1560-LSH-6342	TURBINE END GENERATOR PAN 4 LEAKAGE WATER LEVEL Canceled				LEVEL VIBRATION TYPE	DO/A	24V DC MKA10GA020	IP65	3-WIRE TECHNIC	- -	SIEMENS SITRANS LVL100		2
134	MKA10CT010 1560-TE-6222	STATOR WINDING PHASE U TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	TECHNO CONTROLS PT100 3W/SIMPLEX		1
135	MKA10CT011 1560-TE-6223	STATOR WINDING PHASE U TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	TECHNO CONTROLS PT100 3W/SIMPLEX		1
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project 			Document title INSTRUMENT LIST		Final			
1	Final	03.07.2025	Ledina	Worked by	Ledina									
0	Final	12.02.2025	Ledina	Checked by	Soukenik									
Rev.	Text	Date	Name			Machine No.	6342				Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2	Sheet 16 Sheets 20

No.	Item No	Designation				Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.
136	MKA10CT012 1560-TE-6228	STATOR WINDING PHASE U TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	TECHNO CONTROLS PT100 3W/SIMPLEX		1
137	MKA10CT020 1560-TE-6224	STATOR WINDING PHASE V TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	TECHNO CONTROLS PT100 3W/SIMPLEX		1
138	MKA10CT021 1560-TE-6225	STATOR WINDING PHASE V TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	TECHNO CONTROLS PT100 3W/SIMPLEX		1
139	MKA10CT022 1560-TE-6229	STATOR WINDING PHASE V TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	TECHNO CONTROLS PT100 3W/SIMPLEX		1
140	MKA10CT030 1560-TE-6226	STATOR WINDING PHASE W TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	TECHNO CONTROLS PT100 3W/SIMPLEX		1
141	MKA10CT031 1560-TE-6227	STATOR WINDING PHASE W TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	TECHNO CONTROLS PT100 3W/SIMPLEX		1
142	MKA10CT032 1560-TE-6230	STATOR WINDING PHASE W TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	TECHNO CONTROLS PT100 3W/SIMPLEX		1
143	MKA10CT050 1560-TE-6240A	TURBINE END GENERATOR COLD AIR TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6WIDUPLEX		1
144	MKA10CT051 1560-TE-6240B	TURBINE END GENERATOR COLD AIR TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6WIDUPLEX		1
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project				Document title INSTRUMENT LIST	Final			
1	Final	03.07.2025	Ledina	Worked by	Ledina									
0	Final	12.02.2025	Ledina	Checked by	Soukenik									
Rev.	Text	Date	Name			Machine No.	6342				Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2	Sheet 17 Sheets 20

No.	Item No	Designation				Measuring Instrument	Signal	Power supply Cable connection	Degre e of prote ction	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.	
145	MKA10CT052 1560-TE-6240C	TURBINE END GENERATOR COLD AIR TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6W/DUPLEX		1	
146	MKA10CT055 1560-TE-6241A	EXCITER END GENERATOR COLD AIR TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6W/DUPLEX		1	
147	MKA10CT056 1560-TE-6241B	EXCITER END GENERATOR COLD AIR TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6W/DUPLEX		1	
148	MKA10CT057 1560-TE-6241C	EXCITER END GENERATOR COLD AIR TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6W/DUPLEX		1	
149	MKA10CT060 1560-TE-6246	TURBINE END GENERATOR HOT AIR TEMPERATURE				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6W/DUPLEX		1	
150	MKD10CT010 1560-TE-6218	TURBINE END GENERATOR RADIAL BEARING TEMP				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6W/DUPLEX	TOGETHER WITH 1560-TE-6220	1	
151	MKD10CT011 1560-TE-6220	TURBINE END GENERATOR RADIAL BEARING TEMP				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6W/DUPLEX	TOGETHER WITH 1560-TE-6218	1	
152	MKD10CY020 1560-VT-6382	TURBINE END GENERATOR HORIZONTAL BEARING VIBRATION				ACCELEROMETER		MKD10GE010		THREAD M8x1	0 1 in/s	EMERSON 780A		1	
153	MKD20CT010 1560-TE-6219	EXCITER END GENERATOR RADIAL BEARING TEMP				RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6W/DUPLEX	TOGETHER WITH 1560-TE-6221	1	
2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project Machine No. 6342 			Document title INSTRUMENT LIST		Final				
1	Final	03.07.2025	Ledina	Worked by	Ledina										
0	Final	12.02.2025	Ledina	Checked by	Soukenik										
Rev.	Text	Date	Name												
											Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2	Sheet 18 Sheets 20	

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degree of protection	Technical data	Range From To Unit	Manufacturer - type	Remarks	Rev.
154	MKD20CT011 1560-TE-6221	EXCITER END GENERATOR RADIAL BEARING TEMP	RTD	Pt100	MKA10GA010	IP65	Pt100, 3-WIRE RTD	32 392 °F	WIKA PT100 6W/DUPLEX	TOGETHER WITH 1560-TE-6219	1
155	MKD20CY020 1560-VT-6383	EXCITER END GENERATOR HORIZONTAL BEARING VIBRATION	ACCELEROMETER		MKD10GE010		THREAD M8x1	0 1 in/s	EMERSON 780A		1

2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project		Document title INSTRUMENT LIST	Final		
1	Final	03.07.2025	Ledina	Worked by	Ledina						
0	Final	12.02.2025	Ledina	Checked by	Soukenik						
Rev.	Text	Date	Name			Machine No. 6342			Doc. number 6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2	Sheet 19 Sheets 20

Legend

No.	Item No	Designation	Measuring Instrument	Signal	Power supply Cable connection	Degree of protection	Technical data	Range From To Unit	Manufacturer - type	Remarks	Revision
	MAV40CP010 1560-PIT-6325A	LUBE OIL PRESSURE	PRESSURE TRANSMITTER	AO/P	MAA10GA2 40	IP65	½"NPT, 2-WIRE TECHNIC	0 58 psi(g)	SIEMENS 7MF0300-1NE01-5AF1-Z A00+C11+E01+H02+Y01+Y1 5+Y32		1

- 1 Sequence number

2 Loop designation acc. to KKS (ISA)

3 Name of measuring loop

4 Type (part) of measuring instrument

5 Type of signal
AO/A, AO/P, DI, DO
A analog signal 4-20mA
D digital signal 24V
O output from instrument
I input to instrument
/A activ signal
(contact normally open)
/P pasiv signal
K thermocouple K (NiCrNi), acc. to IEC 584I
- 6 Power supply for instrument

7 Junction Box or Cable Gland

8 Degree of electrical protection

9 Technical description

10 Range of measuring value

11 Manufacturer and type number of instrument

12 Number of revision

2	Final	13.08.2025	Ledina	Date	16.12.2024	Thacker Pass Project		Document title INSTRUMENT LIST	Final			
1	Final	03.07.2025	Ledina	Worked by	Ledina							
0	Final	12.02.2025	Ledina	Checked by	Soukenik							
Rev.	Text	Date	Name			Machine No.	6342		Doc. number	6342-4DC-407 1500-IN-VEN-4523-EXP-0401	Rev. 2	Sheet 20 Sheets 20