

PT. REPOWER ASIA INDONESIA

FORM CECKLIST MEKANIKAL - ELEKTRIKAL

TGL/BLN/THN: 18 / 5 / 2020

NO	PEKERJAAN M & E	STATUS			PERMASALAHAN	TGL PERBAIKAN	KETERANGAN
		B	C	R			
I	AREA LUAR						
1	Panel pompa air	✓			Reson of motor	18-5-2020	Baru diperbaiki
2	Lampu pos satpam	✓					
3	Lampu parkir		X				
4	Lampu teras	✓					
5	Outdoor unit AC	✓					
6	Kran	✓					
II	LANTAI SATU						
1	Panel Meter (Volt + Ampere)	✓			TR: 380V ST: 380V RI: 380V		
2	MCB	✓					
3	Lampu down light	✓			Lampu mati 1 per		
4	Stop kontak	✓					220V
5	Saklar	✓					
6	Indoor unit AC	✓			Test running, set off 18:00		
7	Closet	✓					
8	Wastafel	✓					
9	Kran	✓					
10	Plumbing	✓					
III	LANTAI DUA						
1	Panel	✓					
2	MCB	✓					
3	Lampu down light	✓			Lampu mati 4 per		
4	Stop kontak	✓					220V
5	Saklar	✓					
6	Indoor unit AC	✓			Test Running, set off 18:00		
7	Closet	✓					
8	Wastafel	✓					
9	Kran	✓					
10	Plumbing	✓					
11	Outdoor unit	✓					
IV	LANTAI TIGA						
1	Panel	✓					
2	MCB	✓					
3	Lampu down light	✓			Lampu mati 3 per		
4	Stop kontak	✓					220V
5	Saklar	✓					
6	Indoor unit AC	✓			Test Running, set off 18:00		
7	Closet	✓					
8	Wastafel	✓					
9	Kran	✓					
10	Plumbing	✓					
11	Outdoor unit	✓					

V	LANTAI EMPAT					
1	Panel	✓				
2	MCB	✓				
3	Lampu down light	✓			Lampu mdr 2 pc	
4	Stop kontak	✓				220V
5	Saklar	✓				
6	Indoor unit AC	✓			Tes Running. Set off 10.00	
7	Closet	✓				
8	Wastafel	✓				
9	Kran	✓				
10	Plumbing	✓				
11	Outdoor unit	✓				
VI	LANTAI LIMA					
1	Panel	✓				
2	MCB	✓				
3	Lampu down light	✓			Lampu mdr 2 pc	
4	Stop kontak	✓				220V
5	Saklar	✓				
6	Indoor unit AC	✓			Tes Running. Set off 10.00	
7	Closet	✓				
8	Wastafel	✓				
9	Kran	✓				
10	Plumbing	✓				
11	Outdoor unit	✓				

KETERANGAN:

- Tes Running semua unit AC tiap lantai
- Perbaikan pompa air


B: Baik

C: Ada/Tidak

R: Rusak

Dibuat

Diketahui



(Wiyono)

(

)