PT. REPOWER ASIA INDONESIA

FORM CECKLIST MEKANIKAL - ELEKTRIKAL

TGL/BLN/THN: 11 / 6 / 2020

NO	PEKERJAAN M & E	STATUS				TGL	VETERALIE
		В	С	R	PERMASALAHAN	PERBAIKAN	KETERANGAN
1	AREA LUAR						*
1	Panel pompa air	V			manual un		
2	Lampu pos satpam	V					
3	Lampu parkir		×				
4	Lampu teras	V					
5	Outdoor unit AC	V					
6	Kran	~					
II	LANTAI SATU		-				
1	Panel Meter (Volt + Ampere)	~			TR: 380 V ST: 380 V RS: 380V		
	MCB	V					
3	Lampu down light	1			Lampy mati 3 pcs		
	Stop kontak	L			2011/24		200 V
PARTIE AND A	Saklar	V					
735 7	Indoor unit AC	-			Set off 18.00		
distance of	Closet	V			// //		
	Wastafel	1					
	Kran						
-	Plumbing	-					
	Transition 18	-					
III	LANTAI DUA						
	Panel	V					
	MCB						
	Lampu down light	~			Lange mati 4 pes		
	Stop kontak	レ			p /s cs		220 V
_	Saklar	V					2200
	Indoor unit AC	-					
		レレ					
_	Closet	-					
_	Wastafel	V					
-	Kran	V					
_	Plumbing	~					
-	Outdoor unit	~		181			
_	LANTAI TIGA						
_	Panel	~					
	MCB	_		BILL	, ,		
	Lampu down light	-		-	Lampu mati 3 pcs	11-6-2020	partion 1pg
	Stop kontak	-					2201
	Saklar	-					
	Indoor unit AC	1		S. T			
7	Closet	V					
8	Wastafel	~					
9	Kran	V					
10	Plumbing	~					
	Outdoor unit	V					

7				
V	LANTAI EMPAT			
1	Panel	V		
2	MCB			
3	Lampu down light		1-	
	Stop kontak		Lampu moti 2 pcs	
5	Saklar			220 V
6	Indoor unit AC			
	Closet		Set off 18.00	
	Wastafel			
	Kran	V		
	Plumbing	V		
	Outdoor unit	~		
	LANTAI LIMA	~		
	Panel			
-	MCB			
-		V		
	Lampu down light		lampe meti 2 per	
	Stop kontak	V		22.0
	Saklar	_		
	Indoor unit AC	_		
	Closet	~		
	Wastafel			
-	Kran			
	Plumbing			
11	Outdoor unit			
V.	KETERANGAN:	- Penggan	162 Lampy mushola	(1pu)
N.	B: Baik			

C: Ada/Tidak

R: Rusak

Dibuat

Diketahui

(Wiyono)