

FORM CECKLIST MEKANIKAL - ELEKTRIKAL

TGL/BLN/THN: 2 / 4 / 2020

NO	PEKERJAAN M & E	STATUS			PERMASALAHAN	TGL PERBAIKAN	KETERANGAN
		B	C	R			
I	AREA LUAR						
1	Panel pompa air	✓			manual on		7/4 x 07
2	Lampu pos satpam	✓					
3	Lampu parkir		x				
4	Lampu teras	✓					
5	Outdoor unit AC	✓					
6	Kran	✓					
II	LANTAI SATU						
1	Panel Meter (Volt + Ampere)	✓			TR: 300V ST: 380V PS: 380V		
2	MCB	✓					
3	Lampu down light	✓			Lampu mati 1 pcs		
4	Stop kontak	✓					220V
5	Saklar	✓					
6	Indoor unit AC	✓					
7	Closet	✓					
8	Wastafel	✓					
9	Kran	✓					
10	Plumbing	✓					
III	LANTAI DUA						
1	Panel	✓			TR: 380V ST: 380V PS: 380V		
2	MCB	✓					
3	Lampu down light	✓			Lampu mati 4 pcs		
4	Stop kontak	✓					220V
5	Saklar	✓					
6	Indoor unit AC	✓			See off 18.00		
7	Closet	✓					
8	Wastafel	✓					
9	Kran	✓					
10	Plumbing	✓					
11	Outdoor unit	✓					
IV	LANTAI TIGA						
1	Panel	✓					
2	MCB	✓					
3	Lampu down light	✓			Lampu mati 3 pcs		
4	Stop kontak	✓					220V
5	Saklar	✓					
6	Indoor unit AC	✓			See off 18.00		
7	Closet	✓					
8	Wastafel	✓					
9	Kran	✓					
10	Plumbing	✓					
11	Outdoor unit	✓					

V	LANTAI EMPAT					
1	Panel	✓				
2	MCB	✓				
3	Lampu down light	✓			Lampu mati 2 pcs	
4	Stop kontak	✓				220V
5	Saklar	✓				
6	Indoor unit AC	✓			Set Off 10.00	
7	Closet	✓				
8	Wastafel	✓				
9	Kran	✓				
10	Plumbing	✓				
11	Outdoor unit	✓				
VI	LANTAI LIMA					
1	Panel	✓				
2	MCB	✓				
3	Lampu down light	✓			Lampu mati 2 pcs	
4	Stop kontak	✓				220V
5	Saklar	✓				
6	Indoor unit AC	✓			Set off 10.00	
7	Closet	✓				
8	Wastafel	✓				
9	Kran	✓				
10	Plumbing	✓				
11	Outdoor unit	✓				

KETERANGAN:

B: Baik
C: Ada/Tidak
R: Rusak

- mapping instalasi listrik existing Lt 5.
- Merapikan instalasi Kabel listrik dan jaringan.
- Lampu mati total 12 pcs

Dibuat

Diketahui



(Wiyono)

()