AQUACHECK
Trusted Quality Check Partner

AQUACHECK LABORATORIES LIMITED
P.O. Box 216 - 00300
Westlands Commercial Centre
Ring Road Parklands,Nairobi kenya
Email:aquachecklab@gmail.com
TEL: 0755596064/0734933819

TEST REPORT

SAMPLE DESCRIPTION: TREATED EFFLUENT
SUBMITTED BY: SOLPIA KENYA LTD
CONTACT PERSON: WAWERU,0721347076
SAMPLED BY: CLIENT
SAMPLING LOCATION: EAST GATE RD,OFF MOMBASA RD

SAMPLING DATE: 08/01/2026
RECEIVED ON: 12/01/2026
ANALYSIS DATE: 12/01/2026
REPORT ISSUED ON: 13/01/2026
SAMPLE LAB ID: QT/1396/2026

TEST	METHOD	RESULTS	NEMA STANDARD FOR EFFLUENT WATER ; FIFTH SCHEDULE. Maximum levels Permissible.	REMARKS
pH	**Direct Method**	**11.0**	**6.0-9.0**	**NON-COMPLIANT**
Color (Pt. Co.APHA)	**APHA Platinum-Cobalt Method:8025**	**259**	**<40**	**NON-COMPLIANT**
Total Suspended Solids mg/L	HACH Method:8006	33	250	COMPLIANT
Turbidity(NTU)	Absorptometric Method: 8237	20	NS	NS
Total Dissolved Solids mg/L	Direct Method	1484	2000	COMPLIANT
Conductivity µS/cm	APHA 2510B	2110	NS	NS
COD mg/L	**APHA 5220D**	**3220**	**1000**	**NON-COMPLIANT**

NS: No Set Standard, ND: Not Detected,COD:Chemical Oxygen Demand, USEPA: United States Environmental Protection Agency, APHA: American Public Health Association. NEMA: National Environmental Management Authority.

DISCLAIMER

These results only apply to the sample submitted and the recommendations/comments are only based on the tested parameters, The laboratory will not be held responsible for any sampling errors, which may include improper collection techniques, contamination during the sampling process, or inadequate sample representation.
The test report shall not be reproduced without the written approval of Aquacheck Laboratories Ltd.

COMMENTS.

Most tested parameters **EXCEPT** pH,colour and COD are within the set specifications for discharge into the public sewer based on the legal notice No.120 of EMCA,2006. Further treatment is therefore recommended.

VICTOR MUTAI
Water Chemist

KIPKEMOI JOSPHAT
Lab analyst

13 JAN 2026