AQUACHECK
Trusted Quality Check Partner

AQUACHECK LABORATORIES LIMITED
P.O. Box 216 - 00300
Westlands Commercial Centre
Ring Road Parklands,Nairobi kenya
Email: aquachecklab@gmail.com
TEL: 0755596064/0734933819

TEST REPORT

SAMPLE DESCRIPTION: TREATED EFFLUENT
SUBMITTED BY: APOLLO TOURS AND TRAVEL LTD
CONTACT PERSON: LAWRENCE,0720863294
SAMPLED BY: APOLLO TOURS AND TRAVEL LTD
SAMPLING LOCATION: NAIROBI

SAMPLING DATE: 10/03/2026
RECEIVED ON: 10/03/2026
ANALYSIS DATE: 10/03/2026
REPORT ISSUED ON: 19/03/2026
SAMPLE LAB ID: QT/1518/2026

TEST	METHOD	RESULTS	NEMA STANDARD FOR EFFLUENT WATER ; THIRD SCHEDULE. Maximum levels Permissible.	REMARKS
pH	Direct Method	8.1	6.5-8.5	COMPLIANT
Color (Pt. Co.APHA)	**APHA Platinum-Cobalt Method:8025**	**13200**	**15**	**NON-COMPLIANT**
Total Suspended Solids mg/L	**HACH Method:8006**	**1660**	**30**	**NON-COMPLIANT**
COD mg/L	**APHA 5220D**	**1058**	**50**	**NON-COMPLIANT**
BOD mg/L	**Oxitop: Respirometric Method**	**559**	**30**	**NON-COMPLIANT**
Free Residual Chlorine mg/L	DPD Method:8021	ND	0.1	COMPLIANT
Copper as Cu^{2+} mg/L	Bicinchoninate Method:8506	0.009	1	COMPLIANT
Ammonia as NH_3-N mg/L	Salicylate Method:8155	0.33	100	COMPLIANT
Oil & Grease mg/L	EPA 1664A	<0.001	Nil	COMPLIANT
Total coliforms (counts/100 ml)	**ISO 4832**	**TNTC**	**100**	**NON-COMPLIANT**

NS: No Set Standard, ND: Not Detectable,TNTC:Too numerous to count, USEPA: United States Environmental Protection Agency, APHA: American Public Health Association. NEMA: National Environmental Management Authority.

DISCLAIMER

These results only apply to the sample submitted and the recommendations/comments are only based on the tested parameters. The laboratory will not be held responsible for any sampling errors, which may include improper collection techniques, contamination during the sampling process, or inadequate sample representation.

The test report shall not be reproduced without the written approval of Aquacheck Laboratories Ltd.

COMMENTS.

The parameters ; Colour,suspended solids,COD, BOD and total coliforms does not meet the set specifications for discharge into the environment based on the legal notice No.120 of EMCA,2006. Treatment is therefore recommended.

VICTOR MUTAI
Water Chemist

AQUACHECK LABORATORIES LTD
19 MAR 2026
P.O. Box 216 - 00300, NAIROBI

KIPKEMOI JOSPHAT
Lab analyst