AQUACHECK
Trusted Quality Check Partner

AQUACHECK LABORATORIES LIMITED
P.O. Box 216 – 00300, NAIROBI
Westlands Commercial Centre
Off Ring Road, Parklands Rd
Email: aquachecklab@gmail.com
Website:www.aquachecklab.com
TEL: 0755596064/0734933819

TEST REPORT

SAMPLE DESCRIPTION: FILTERED WATER
SUBMITTED BY: CHURRASCO GAUCHO LTD
CLIENT CONTACT: JONNY-0715414141
SAMPLED BY: AQUACHECK LABORATORIES LTD
SAMPLING LOCATION: GALANA PLAZA-GALANA ROAD,KILIMANI

SAMPLING DATE: 19/02/2026
RECEIVED ON: 19/02/2026
ANALYSIS DATE: 19/02/2026
REPORT ISSUED ON: 23/02/2026
SAMPLE LAB ID: QT/1479/2026

PHYSIO-CHEMICAL TEST	METHOD	RESULTS	KS EAS 12:2018 Treated Potable water limit	REMARKS
pH	Direct Method	8.7	6.5-8.5	COMPLIANT
Color (Pt. Co.APHA)	Hach Method: 8025	ND	15	COMPLIANT
Turbidity(NTU)	Absorptometric Method: 8237	ND	5	COMPLIANT
Total Suspended Solids mg/L	Hach method: 8006	ND	ND	COMPLIANT
Total Dissolved Solids mg/L	Direct Method	147	1000	COMPLIANT
Conductivity µS/cm	Direct Method	210	1500	COMPLIANT
P. Alkalinity as $CaCo_3$ mg/L	APHA Method: 2320 B	24	NS	NS
Total Alkalinity as $CaCo_3$ mg/L	APHA method: 2340 C	88	NS	NS
Fluoride as F mg/L	**SPADNS Method: 8029**	**6.8**	**1.5**	**NON-COMPLIANT**
Iron as Fe mg/L	Ferrover method:8008	ND	0.3	COMPLIANT
Chloride as CL mg/L	APHA 4500- CL^- B	17.7	250	COMPLIANT
Nitrate as NO_3^- mg/L	Cadmium reduction:8039	7.2	45	COMPLIANT
Sulphates as SO_4 mg/L	SulfaVer 4 Method: 8051	15.7	400	COMPLIANT
Ammonia as NH_3-N mg/L	Salicylate Method:8155	0.05	0.5	COMPLIANT
Zinc as Zn mg/L	Zincon Method:8009	0.07	5	COMPLIANT
Phosphates as PO_4^{3-} mg/L	Orthophosphate Method: 8048	0.1	2.2	COMPLIANT
Carbonates as $CaCo_3$ mg/L	APHA method: 2340 B	48	NS	COMPLIANT
Bicarbonates as $CaCo_3$ mg/L	APHA method: 2340 B	40	NS	COMPLIANT
Calcium as Ca mg/L	APHA method: 3500 - Ca B	2.4	150	COMPLIANT
Magnesium as Mg mg/L	APHA method: 3500 - Mg B	0.5	100	COMPLIANT
Calcium hardness as $CaCo_3$ mg/L	APHA method: 3500 - Ca B	6	NS	NS
Magnesium hardness as $CaCo_3$ mg/L	APHA method: 3500 - Mg B	2	NS	NS
Total Hardness as $CaCo_3$ mg/L	APHA method: 2340 C	8	300	COMPLIANT
Silica as SiO_2 mg/L	Silicomolybdate method:8185	33	NS	NS
MICROBIOLOGICAL TEST				
E.coli CFU/ 100ml sample	KS ISO 9308-1:2014	ND	Not Detectable	COMPLIANT
Total coliforms, CFU/100ml sample	KS ISO 9308-1:2014	ND	Not Detectable	COMPLIANT
Total viable countCFU/ml sample@37°C	KS ISO 6222:1999	1	50	COMPLIANT
Pseudomonas aeruginosa cfu/100ml sample	KS ISO 16266:2006	ND	Not Detectable	COMPLIANT
Salmonella spp CFU/ 100ml sample	KS ISO 6340:1995	ND	Not Detectable	COMPLIANT
Streptococcus faecalis CFU/ 100ml sample	KS ISO 7899-2:1984	ND	Not Detectable	COMPLIANT

NS: No Set Standard, ND: Not Detectable, TNTC: Too Numerous to count, KS: Kenya Standard, EAS: East African Standard, APHA: American Public Health Association, potable water: water that is safe and suitable for human consumption, CFU: Colony forming units.SPP: species, ISO: International Organisation for Standardisation.

DISCLAIMER

These results only apply to the sample submitted and the recommendations/comments are only based on the tested parameters.
The test report shall not be reproduced without the written approval of Aquacheck Laboratories Ltd.

COMMENTS.

The sample does not comply with KS EAS 12:2018 specifications for treated potable water. The Fluoride exceeded the set limit. Further treatment is therefore recommended.

VICTOR MUTAI
Water Chemist

AQUACHECK LABORATORIES LTD
23 FEB 2026
P.O. Box 216 - 00300, NAIROBI

KIPKEMOI JOSPHAT
Lab analyst