



POWERFACTORY

# PowerFactory 2024

## Technical Reference

### Synchronous Machine

ElmSym, TypSym

PF2024

**POWER SYSTEM SOLUTIONS**  
MADE IN GERMANY

**Publisher:**

DIGSILENT GmbH  
Heinrich-Hertz-Straße 9  
72810 Gomaringen / Germany  
Tel.: +49 (0) 7072-9168-0  
Fax: +49 (0) 7072-9168-88  
info@digsilent.de

Please visit our homepage at:  
<https://www.digsilent.de>

**Copyright © 2024 DIGSILENT GmbH**

All rights reserved. No part of this  
publication may be reproduced or  
distributed in any form without written  
permission of DIGSILENT GmbH.

January 9, 2024  
PowerFactory 2024  
Revision 1

# Contents

|          |                                                                |           |
|----------|----------------------------------------------------------------|-----------|
| <b>1</b> | <b>General Description</b>                                     | <b>1</b>  |
| <b>2</b> | <b>Load Flow Analysis</b>                                      | <b>2</b>  |
| 2.1      | Reactive Power/Voltage Control . . . . .                       | 2         |
| 2.1.1    | Const. V . . . . .                                             | 2         |
| 2.1.2    | Voltage Q-Droop control . . . . .                              | 3         |
| 2.1.3    | Voltage Iq-Droop . . . . .                                     | 4         |
| 2.1.4    | Const. Q . . . . .                                             | 6         |
| 2.1.5    | Q(P)-Characteristic . . . . .                                  | 6         |
| 2.1.6    | Const. cosphi . . . . .                                        | 7         |
| 2.2      | Reactive Power Limits . . . . .                                | 7         |
| 2.2.1    | Fixed reactive power limits . . . . .                          | 8         |
| 2.2.2    | Capability Curve . . . . .                                     | 8         |
| 2.2.2.1  | Base capability curve . . . . .                                | 8         |
| 2.3      | Active Power Control and Balancing . . . . .                   | 9         |
| 2.3.1    | Fixed Active Power . . . . .                                   | 9         |
| 2.3.2    | Reference Machine . . . . .                                    | 9         |
| 2.3.2.1  | Force voltage angle control (const. phi) . . . . .             | 10        |
| 2.3.3    | Primary Frequency Bias . . . . .                               | 10        |
| 2.3.4    | External Secondary Controller . . . . .                        | 11        |
| 2.3.5    | Inertial Power Flow . . . . .                                  | 11        |
| 2.3.6    | Active Power: Operational Limits, Ratings . . . . .            | 11        |
| 2.4      | Wind Speed Input for Wind Generators . . . . .                 | 12        |
| 2.5      | Spinning if circuit breaker is open . . . . .                  | 12        |
| 2.6      | Permanent magnet synchronous machine Load Flow model . . . . . | 13        |
| <b>3</b> | <b>Short-Circuit Analysis</b>                                  | <b>14</b> |
| 3.1      | Calculation of transient and subtransient reactances . . . . . | 14        |
| 3.2      | Short-Circuit According to IEC 60909 or VDE 102/103 . . . . .  | 14        |
| 3.3      | Complete Short Circuit Method . . . . .                        | 15        |

|          |                                                                                    |           |
|----------|------------------------------------------------------------------------------------|-----------|
| 3.3.1    | Single phase machine model . . . . .                                               | 16        |
| 3.4      | ANSI-C37 Short-Circuit . . . . .                                                   | 16        |
| 3.5      | IEC 61363 Short-Circuit . . . . .                                                  | 16        |
| <b>4</b> | <b>Optimal Power Flow</b>                                                          | <b>18</b> |
| 4.1      | OPF Controls . . . . .                                                             | 18        |
| 4.2      | Constraints: Active / Reactive Power Limits . . . . .                              | 18        |
| 4.3      | Operating Cost . . . . .                                                           | 18        |
| <b>5</b> | <b>Harmonic Analysis</b>                                                           | <b>19</b> |
| 5.1      | Frequency dependency . . . . .                                                     | 19        |
| 5.2      | Impedance calculation . . . . .                                                    | 20        |
| 5.2.1    | Calculation using standard parameters . . . . .                                    | 20        |
| 5.2.2    | Calculation using frequency transfer functions (operational inductances) . . . . . | 20        |
| 5.2.3    | Impedance calculation for the single-phase model . . . . .                         | 22        |
| 5.2.4    | Flicker . . . . .                                                                  | 23        |
| <b>6</b> | <b>RMS/EMT Simulation</b>                                                          | <b>24</b> |
| 6.1      | <i>PowerFactory</i> Standard Model . . . . .                                       | 24        |
| 6.1.1    | Input Parameters . . . . .                                                         | 25        |
| 6.1.1.1  | Conversion of Short-Circuit to Equivalent Circuit Parameters . . . . .             | 27        |
| 6.1.2    | Equations for the standard model in <i>PowerFactory</i> . . . . .                  | 28        |
| 6.1.2.1  | Equations for the RMS model . . . . .                                              | 30        |
| 6.1.2.2  | Equations for the EMT model . . . . .                                              | 33        |
| 6.1.2.3  | Mechanical Equations . . . . .                                                     | 34        |
| 6.1.2.4  | Mechanical Torque . . . . .                                                        | 35        |
| 6.1.2.5  | Damping Torque . . . . .                                                           | 35        |
| 6.1.2.6  | Acceleration Time Constant . . . . .                                               | 36        |
| 6.1.2.7  | Initialisation of the mechanical parameters . . . . .                              | 37        |
| 6.1.3    | Rotor angle definitions . . . . .                                                  | 37        |
| 6.1.3.1  | Out of step detection . . . . .                                                    | 39        |
| 6.1.4    | Saturation . . . . .                                                               | 39        |

|         |                                                                 |    |
|---------|-----------------------------------------------------------------|----|
| 6.1.4.1 | Saturation coefficient calculation . . . . .                    | 41 |
| 6.1.4.2 | Options for calculating the saturation factors . . . . .        | 42 |
| 6.1.5   | Excitation system interfacing . . . . .                         | 43 |
| 6.1.5.1 | Excitation system base modes in <i>PowerFactory</i> . . . . .   | 44 |
| 6.1.6   | Delta Speed Input Signal . . . . .                              | 45 |
| 6.1.7   | Integrated AVR for Motor Starting . . . . .                     | 46 |
| 6.1.8   | Inputs/Outputs/State Variables of the Dynamic Model . . . . .   | 46 |
| 6.1.8.1 | Stability Model (RMS) . . . . .                                 | 46 |
| 6.1.8.2 | EMT-Model . . . . .                                             | 47 |
| 6.2     | GENQEC model . . . . .                                          | 49 |
| 6.2.1   | Input parameters and conversion . . . . .                       | 49 |
| 6.2.1.1 | Conversion of Parameters . . . . .                              | 50 |
| 6.2.2   | Model equations . . . . .                                       | 51 |
| 6.2.2.1 | Equations for the RMS model . . . . .                           | 51 |
| 6.2.2.2 | Equations for the EMT model . . . . .                           | 53 |
| 6.2.2.3 | Mechanical Equations, Rotor Angles and Delta Speed Input Signal | 53 |
| 6.2.3   | Saturation . . . . .                                            | 53 |
| 6.2.4   | Excitation system interfacing . . . . .                         | 53 |
| 6.2.5   | Integrated AVR for Motor Starting . . . . .                     | 54 |
| 6.2.6   | Inputs/Outputs/State Variables of the Dynamic Model . . . . .   | 54 |
| 6.2.6.1 | Stability Model (RMS) . . . . .                                 | 54 |
| 6.2.6.2 | EMT-Model . . . . .                                             | 55 |
| 6.3     | Model 3.3 . . . . .                                             | 56 |
| 6.3.1   | Input parameters and conversion . . . . .                       | 56 |
| 6.3.2   | Model equations . . . . .                                       | 57 |
| 6.3.2.1 | Equations for the RMS model . . . . .                           | 59 |
| 6.3.2.2 | Equations for the EMT model . . . . .                           | 59 |
| 6.3.2.3 | Mechanical Equations, Rotor Angles and Delta Speed Input Signal | 60 |
| 6.3.3   | Saturation . . . . .                                            | 60 |
| 6.3.4   | Excitation system interfacing . . . . .                         | 60 |
| 6.3.5   | Integrated AVR for Motor Starting . . . . .                     | 60 |

|         |                                                                 |    |
|---------|-----------------------------------------------------------------|----|
| 6.3.6   | Inputs/Outputs/State Variables of the Dynamic Model . . . . .   | 61 |
| 6.3.6.1 | Stability Model (RMS) . . . . .                                 | 61 |
| 6.3.6.2 | EMT-Model . . . . .                                             | 62 |
| 6.4     | Permanent magnet model . . . . .                                | 63 |
| 6.4.1   | Equations for the RMS model . . . . .                           | 63 |
| 6.4.2   | Equations for the EMT model . . . . .                           | 63 |
| 6.4.3   | Inputs/Outputs/State Variables of the Dynamic Model . . . . .   | 64 |
| 6.4.3.1 | Stability Model (RMS) . . . . .                                 | 64 |
| 6.4.3.2 | EMT-Model . . . . .                                             | 64 |
| 6.5     | Classical Model . . . . .                                       | 66 |
| 6.5.1   | Equations for the RMS model . . . . .                           | 66 |
| 6.5.2   | Equations for the EMT model . . . . .                           | 67 |
| 6.5.3   | Integrated AVR for Motor Starting . . . . .                     | 67 |
| 6.5.4   | Inputs/Outputs/State Variables of the Dynamic Model . . . . .   | 67 |
| 6.5.4.1 | Stability Model (RMS) . . . . .                                 | 67 |
| 6.5.4.2 | EMT-Model . . . . .                                             | 68 |
| 6.6     | Asynchronous starting model . . . . .                           | 70 |
| 6.6.1   | Input parameters . . . . .                                      | 71 |
| 6.6.2   | Model equations . . . . .                                       | 71 |
| 6.6.2.1 | Equations for the RMS model . . . . .                           | 73 |
| 6.6.2.2 | Equations for the EMT model . . . . .                           | 73 |
| 6.6.2.3 | Mechanical Equations, Rotor Angles and Delta Speed Input Signal | 74 |
| 6.6.2.4 | Saturation and parameter dependency . . . . .                   | 74 |
| 6.6.2.5 | Excitation system interfacing . . . . .                         | 75 |
| 6.6.3   | Integrated AVR for Motor Starting . . . . .                     | 75 |
| 6.6.4   | Inputs/Outputs/State Variables of the Dynamic Model . . . . .   | 75 |
| 6.6.4.1 | Stability Model (RMS) . . . . .                                 | 75 |
| 6.6.4.2 | EMT-Model . . . . .                                             | 76 |
| 6.7     | Single-phase model . . . . .                                    | 78 |
| 6.7.1   | Input Parameters . . . . .                                      | 78 |
| 6.7.2   | Model equations . . . . .                                       | 78 |

|          |                                                                 |           |
|----------|-----------------------------------------------------------------|-----------|
| 6.7.2.1  | Equations for the RMS model . . . . .                           | 78        |
| 6.7.2.2  | Equations for the EMT model . . . . .                           | 80        |
| 6.7.2.3  | Mechanical Equations, Rotor Angles and Delta Speed Input Signal | 81        |
| 6.7.3    | Saturation . . . . .                                            | 81        |
| 6.7.4    | Excitation system interfacing . . . . .                         | 81        |
| 6.7.5    | Inputs/Outputs/State Variables of the Dynamic Model . . . . .   | 81        |
| 6.7.5.1  | Stability Model (RMS) . . . . .                                 | 81        |
| 6.7.5.2  | EMT-Model . . . . .                                             | 82        |
| <b>7</b> | <b>References</b>                                               | <b>83</b> |
|          | <b>Appendices</b>                                               | <b>84</b> |
| <b>A</b> | <b>Base values for single- and three-phase machines</b>         | <b>84</b> |
| <b>B</b> | <b>Additional calculation parameters (RMS/EMT simulation)</b>   | <b>85</b> |
|          | <b>List of Figures</b>                                          | <b>87</b> |
|          | <b>List of Tables</b>                                           | <b>88</b> |

## 1 General Description

This document describes the *PowerFactory* synchronous machine models, as used for the various steady-state and dynamic power system analysis functions in *PowerFactory*.



## 2 Load Flow Analysis

In the Load Flow Analysis we distinguish between a model where the reactive power can be controlled and a model where the reactive power is a function of the active power. The first model is described in the following subsections. The latter model is used to represent the permanent magnet synchronous machine model and is described in subsection 2.6.

Typically, in load flow calculations, the controlled operation of a synchronous generator is modelled. Figure 2.1 shows the basic concept of a controlled synchronous machine modelled for load flow analysis.




Figure 2.1: Basic concept of a controlled synchronous machine

### 2.1 Reactive Power/Voltage Control

The *PowerFactory* model of the synchronous machine, offers the following options for defining the Local Controller:

- Const. V
- Voltage Q-Droop
- Voltage I<sub>q</sub>-Droop
- Const. Q
- Q(P)-Characteristic
- Const. cosφ<sub>i</sub>

#### 2.1.1 Const. V

The Local Controller defined as “Const. V” is typically used for large synchronous generators at large power stations which operate in voltage control mode (“PV” mode).

When enabling this option, the generator will control the voltage directly at its terminals. As basis for the controlled p.u. value, the voltage of the connected terminal is used. For more complex control schemes, i.e. controlling the voltage at a remote bus bar or controlling the

voltage at one bus bar using more than one generator, a *Station Controller* model needs to be defined.

In this case, the Station Controller adds an offset to the reactive power operating point specified in the synchronous generator element:

$$Q = Q_0 + K \cdot \Delta Q_{SCO} \quad (1)$$

For more details about the *Station Controller*, refer to the [Technical Reference of the Station Controller](#).

### 2.1.2 Voltage Q-Droop control

Figure 2.2 describe the voltage control and droop function.

The droop control corresponds to a proportional control. This means the amount of reactive power is calculated in proportion to the deviation from the voltage set-point entered in the element. The droop control can be used if several voltage controlling machines are placed close together.




Figure 2.2: Voltage Q-Droop Control

When set to voltage q-droop control, a droop value can be entered. The voltage at the local busbar is then controlled according to the equations below. The equation is shown graphically in Figure 2.3. When the load option *Consider reactive power limits* is enabled, the voltage limits  $usp_{max}$  and  $usp_{min}$  are considered.

It can be inferred that a droop value of 1% and a voltage deviation of 0.01 p.u. result in an additional reactive power of 100% of the rated apparent power of the generator. Similarly, a droop value of 2% and the same voltage deviation of 0.01 p.u. result in an additional reactive power of 50% of the rated apparent power of the generator.

$$u' = u_{setpoint} + du_{setpoint} - \Delta u_{droop} \quad (2)$$

$$u = \begin{cases} usp_{max} & \text{if } u' > usp_{max} \\ usp_{min} & \text{if } u' < usp_{min} \\ u' & \text{if } u' \geq usp_{min} \ \& \ u_s \leq usp_{max} \end{cases} \quad (3)$$

$$\Delta u_{droop} = \frac{Q - Q_{setpoint}}{Q_{droop}} \quad (4)$$

$$Q_{droop} = \frac{S_r \cdot 100}{ddroop} \quad (5)$$

where:

- $u$  is the actual voltage value at the terminal
- $u_{setpoint}$  is the specified voltage setpoint
- $usp_{max}, usp_{min}$  is the max. and min. voltage setpoint
- $\Delta u_{droop}$  is the voltage deviation
- $du_{setpoint}$  is the voltage signal coming from the station controller, when the station controller is set to *Voltage Setpoint Adaptation* method, otherwise is zero by default. Please consult the [Technical Reference of the Station Controller](#)
- $Q$  is the actual reactive power output
- $Q_{setpoint}$  is the specified dispatch reactive power
- $Q_{droop}$  is the additional reactive power for the specified voltage droop
- $S_r$  is the rated apparent power
- $ddroop$  is the voltage droop value specified in percentage




Figure 2.3: Voltage Q-Droop Control

### 2.1.3 Voltage Iq-Droop

The block diagram for this option is shown in Figure 2.4. When the load option *Consider reactive power limits* is enabled, the voltage limits  $usp_{max}$  and  $usp_{min}$  are considered.

The Voltage Iq-Droop control corresponds to a reactive current controller, in which the reactive current is calculated in proportion to the deviation from the voltage set point entered in the element.




Figure 2.4: Voltage Iq-Droop Control

The voltage reactive current droop in p.u. is based on the rated active current of the machine and calculated as follows:

$$u' = u_{setpoint} + du_{setpoint} - \Delta u_{droop} \quad (6)$$

$$u = \begin{cases} usp_{max} & \text{if } u' > usp_{max} \\ usp_{min} & \text{if } u' < usp_{min} \\ u' & \text{if } u' \geq usp_{min} \text{ \& } u_s \leq usp_{max} \end{cases} \quad (7)$$

$$\Delta u_{droop} = \frac{Iq - Iq_{setpoint}}{K_{droop} \cdot Ip_r} \quad (8)$$

$$K_{droop} = \frac{100}{ddroop} \quad (9)$$

with the reactive current setpoint:

$$Iq_{setpoint} = \frac{qgini \cdot ngnum}{\sqrt{3} \cdot U_{nom}} \quad (10)$$

and with the rated active current:

$$Ip_r = \frac{sgn \cdot ngnum \cdot cosn}{\sqrt{3} \cdot U_r} \quad (11)$$

Where:

- $u$  is the actual voltage value at the terminal
- $u_{setpoint}$  is the specified voltage setpoint
- $usp_{max}, usp_{min}$  is the max. and min. voltage setpoint
- $\Delta u_{droop}$  is the voltage deviation
- $du_{setpoint}$  is the voltage signal coming from the station controller, when the station controller is set to *Voltage Setpoint Adaptation* method, otherwise is zero by default. Please consult the [Technical Reference of the Station Controller](#)
- $Iq$  is the reactive current output of the machine in kA
- $Iq_{setpoint}$  is the reactive current setpoint of the machine in kA
- $K_{droop}$  is the gain
- $ddroop$  is the voltage droop value specified in percentage
- $qgini$  is the reactive power setpoint in MVA
- $ngnum$  is the number of parallel machines
- $U_{nom}$  is the nominal voltage of the corresponding connected busbar in kV
- $U_r$  is the rated voltage of the machine in kV
- $Ip_r$  is the rated active current in kA

- $sgn$  is the rated apparent power in MVA
- $cosn$  is the rated power factor




Figure 2.5: Voltage Iq-Droop Control

The dispatched reactive current is calculated by using the nominal voltage of the connected busbar instead of the rated voltage of the machine.

#### 2.1.4 Const. Q

The Local Controller defined as “Const. Q” is typically used for smaller synchronous generators, like the ones embedded in distribution grids, where the power factor is keep constant (“PQ” mode). With this type of control, the user can specify the active and reactive power dispatch of the generator. These parameters can be specificated in different ways, depending on the selected *Input Mode*.

The Voltage and Angle boxes are disabled for the “Const. Q” control option.  $P_{sum}$  and  $Q_{sum}$  will be controlled in unbalanced load flow.

#### 2.1.5 Q(P)-Characteristic

The Q(P) characteristic is a reactive power control and follows e.g. an user-specified characteristic as shown in Figure 2.6:




Figure 2.6: Q(P)-Characteristic

The local controller acts as a reactive power controller in which the reactive power setpoint is adapted according to the active power output of the machine.

Further details regarding using Q(P)-Curve object (*IntQpcurve*), see [Technical Reference of the Q\(P\)-Curve](#)

**Note:** the synchronous generator model is generator oriented, the synchronous motor is load oriented, so it is recommend to define the Q(P)-Curve correspondingly in generator or load orientation.

The Q(P)-Curve defines the reactive power for one machine, the reactive power is then multiplied accordingly by the number of parallel machines (*ngnum*) to obtain the total reactive power. In case if the curve is defined in p.u. the rated apparent power (*sgn*) of the synchronous machine type is used to convert the p.u. values into Mvar and MW values.

### 2.1.6 Const. cosphi

The local controller acts as a reactive power controller in which the reactive power setpoint is adapted according to the active power output of the machine, such that the specified power factor is kept constant.

For most cases, the active power setpoint does not vary during the solution, and therefore this mode acts as a constant reactive power control (see Section 2.1.4). However, for the cases where the generator is a slack, or a secondary controller is activated, or the load flow balancing is based on distributed slack by synchronous generators, then the active power output varies during the solution and this control mode is employed.

## 2.2 Reactive Power Limits

There are several ways for specifying reactive power limits:

- Fixed reactive power limits in the element

- Fixed reactive power limits in the type
- Capability Curve

Generally, reactive power limits are only considered, if the synchronous machine is set to voltage control (Const.V) and the load flow option *Consider reactive power limits* is enabled in the Load Flow Calculation command. If this option is disabled and the specified reactive power limits are exceeded, *PowerFactory* generates a warning message but doesn't apply any actual limit to the generator's reactive power output.

In the case that it is difficult to achieve a well balanced load flow state, an additional scaling factor can be applied to the reactive power limits. This scaling factor is more for "debugging reasons" and doesn't have any physical interpretation. The reactive scaling factor is only considered if the load flow option *Consider Reactive Power Limits Scaling Factor* is enabled.

### 2.2.1 Fixed reactive power limits

Fixed reactive power limits can either be specified at Element or Type level of the synchronous machine. Type limits are used when the option *Use Limits Specified in Type* is enabled, otherwise, the model takes the Element limits that can either be defined on a p.u.-basis or using actual units (Mvar).

### 2.2.2 Capability Curve

The capability curve allows specifying a complete, active power and voltage dependent capability diagram. User-defined capability diagrams are defined using the object *IntQlim*, which is stored in the Operational Library. Refer to the User Manual for more information.

For assigning a capability diagram to a Synchronous Machine Element, the corresponding reference (pQlim) must be set. If this pointer is assigned, all other attributes relating to reactive power limits are hidden and the local capability diagram of the Synchronous Machine Element displays the reactive power limits defined by the *Capability Curve* object (C) at nominal voltage.

#### 2.2.2.1 Base capability curve

The base capability curve is informational only (not used for limiting of active and reactive power) and is based on data of the synchronous machine type (*TypSym*). This P/Q capability curve is calculated for 1[p.u.] voltage (Figure 2.7) and shows the following limits:

- Stability limit defined for maximum angle of 70 degrees (a line with a slope of  $\tan(70)$  starting at the coordinate  $[-1/x_d, 0]$  where  $x_d$  is the synchronous reactance of the machine).
- Armature current limit shown (part of a unit circle with center at the coordinate  $[0, 0]$ ).
- Field current limit (part of a circle with center at the coordinate  $[-1/x_d, 0]$  and radius to coordinate  $[Q_n, \cos n]$ , where  $\cos n$  is the rated power factor and  $Q_n = \sqrt{1 - \cos n^2}$  is the rated reactive power of the synchronous machine).




Figure 2.7: Base capability curve of the synchronous machine

## 2.3 Active Power Control and Balancing

### 2.3.1 Fixed Active Power

Active power will be set to a fixed value if:

- Option *Reference Machine* is disabled
- No *External Secondary Controller* object is selected
- No *Primary Frequency Bias* is defined

Besides these local settings, the corresponding options on the *Active Power Control* page of the Load Flow Calculation command either activate or deactivate the influence of Secondary Controller or Primary Frequency Bias.

### 2.3.2 Reference Machine

The option *Reference Machine* has two consequences:

- Voltage angle at the machine's terminal is fixed
- Machine balances active power if the *Active Power Control* option as *Dispatched* is selected and the *Balancing* option by *Reference Machine* is enabled, or the *Active Power Control according to Secondary Control* is selected and no Secondary Controller is specified in the network.

When more than one machines is marked as reference machine and the machines are in the same synchronous (separated) area, a warning message will be issued in the output window. See further details in the user manual, chapter 'Reference Machine Selection'.



### 2.3.2.1 Force voltage angle control (const. phi)

the option can be found at *Load Flow* page, sub page *Advanced*, but only available when the machine is marked as reference machine.

The voltage angle control is normally only for the reference machine supported, but can be also forced by enabling this option. The behaviour of the machine is similar when two external grid models are configured as bus type *SL*, so both machine will control the voltage angle of the corresponding nodes.

The voltage angle can be entered at the *Load Flow* page, parameter *phiini* in deg. Via input signal *phiset* in rad the angle can be also changed via Quasi-Dynamic Model (*ElmQdsl*). The input signal is initialised to:

$$phiset = phiini \cdot \pi / 180$$

The voltage angle of the node is then controlled by the following equation:

$$\angle u = phiset + phirelref \quad (12)$$

where the attribute *phirelref* in rad is the relative angle difference between the reference node and the corresponding machine, including transformer vector group phase shift angles. In case of the machine is the reference machine, the angle is zero.

### 2.3.3 Primary Frequency Bias

The primary frequency bias is considered if:

- Parameter *Kpf* (in MW/Hz) is >0 and
- *Active Power Control* option *According to Primary Control* is selected

In this case, *PowerFactory* considers in all isolated grids a common frequency deviation  $\Delta F$  and establishes an active power balance through this variable and the primary frequency bias of the individual generators:

$$P = P_0 + K_{pf} \cdot \Delta F$$

where:

- *P*: Actual active power in MW
- *P0*: Active power setpoint in MW
- *Kpf*: Primary frequency bias in MW/Hz
- $\Delta F$ : Frequency deviation in Hz

The “Primary Controlled Load Flow” represents that state of a power system following an active power disturbance, in which the primary governors have settled and the system finds a “quasi steady-state” before the secondary controlled power plants take over the active power balancing task.

During the “primary frequency controlled” state, there is a deviation from nominal frequency. The corresponding calculation quantities (signal) for the frequency deviation can be found in the variable selection dialogue (*s : dFin* in Hz).

### 2.3.4 External Secondary Controller

For bringing frequency back to nominal frequency and/or for re-establishing area exchange flows of an interconnected power system, secondary controlled power plants take over the active power balancing task from the primary control after a few minutes (typically five minutes).

For simulating the “Secondary Controlled” state, which is an (artificial) steady state following the settling of the secondary control system:

- A Power Frequency Controlled has to be specified and assigned to the machine
- *Active Power Control* option *according to Secondary Control* has to be activated.

The actual active power of each generator is defined by:

$$P = P_0 + K \cdot \Delta P_{SCO} \quad (13)$$

where:

- P: Actual active power of the machine in MW
- P0: Active power setpoint in MW
- K: Participation factor (to be specified in the power-frequency control object)
- dPsc0: Total active power deviation of all units controlled by the respective power frequency controller.

For more information related to the *Power Frequency Controller* object, refer to the corresponding Technical Reference Manual.

### 2.3.5 Inertial Power Flow

During the first seconds following an active power disturbance such as a loss of generation or load, before the primary control takes over, the active power balance of the system is established by releasing energy from the rotating masses of all electrical machines.

This situation can be modelled by enabling the *Active Power Control* option *According to Inertias*. In this case, the variable dF represents an equivalent frequency rate of change and active power will be balanced according to the inertia of all generators (defined by the Acceleration Time Constant, to be found on the *RMS-* and *EMT-simulation* pages of the generator type *TypSym*).

### 2.3.6 Active Power: Operational Limits, Ratings

The active power rating can be entered as a rating factor on basis of the rated active power, which is calculated by the rated apparent power times the rated power factor (type-level). Derating of generators can be considered by entering a rating factor  $< 1$ .

When considering active power limits in a load flow calculation, *PowerFactory* makes reference to the Operational Limits (Min. and Max.).

These limits are considered when:

- Generator participates in the active power balancing
- Load Flow option *Consider Active Power Limits* is selected.

### 2.4 Wind Speed Input for Wind Generators

When the synchronous generator is a wind generator (Category = Wind) an additional option on the load flow page is available to either enter the active power directly (Active power input) or alternatively via wind speed (Wind speed input) and a corresponding wind power curve.

The active power in MW is then calculated as follow:

$$P = f(wind\ speed) \quad (14)$$

In case of the wind power curve is defined in p.u., the base value is the rated active power  $P_r = sgn \cdot cosn$  in MW.

where:

- *wind speed* is the wind speed in m/s
- $f(wind\ speed)$  is the corresponding calculated active power value from the wind power curve
- *sgn* is the rated apparent power
- *cosn* is the rated power factor

The max. active power ( $P_{max}$ ) is automatically limited by the max. possible active power for the entered wind speed:

$$P_{max} = Min( f(wind\ speed) \text{ or } P_{max_{uc}} ) \quad (15)$$

where  $P_{max_{uc}}$  is the max. active power operational limit.

### 2.5 Spinning if circuit breaker is open

This option decides whether a synchronous machine can be used for driving an island-network. Typical applications are:

- Load flow set-up for a dynamic simulation of a synchronisation event.
- Island around this generator shall form a supplied island-grid when disconnected from the main-grid (e.g. during Contingency Analysis).

In case of contingencies that split the system two of more isolated areas, *PowerFactory* requires at least one synchronous generator with this option being enabled for assuming that the corresponding island can continue operating after having been islanded. Otherwise, the load flow calculation will assume a complete black out in the corresponding island (all loads and generators unsupplied).

## 2.6 Permanent magnet synchronous machine Load Flow model

For the permanent magnet only the active power is an input parameter for the Load Flow model and the reactive power is a function of the defined active power.

For steady-state conditions with sinusoidal balanced voltages  $\underline{u}$  and speed value of 1 p.u., the current flowing in the machine  $\underline{i}$  is defined as [1] [2]:

$$\underline{i} = \frac{(1 - \underline{K}.r) \cdot \underline{i}_0.r - \underline{K}.i \cdot \underline{i}_0.i + j \cdot ((1 + \underline{K}.r) \cdot \underline{i}_0.i - \underline{K}.i \cdot \underline{i}_0.r)}{1 - (\underline{K}.r)^2 - (\underline{K}.i)^2} \quad (16)$$

where:

$$\begin{aligned} \underline{K} &= \frac{1}{2} \cdot \frac{(x_d - x_q) \cdot e^{(j \cdot \text{angleEq})}}{r_{str} + j \cdot x_q + (x_d - x_q)/2 \cdot e^{(j \cdot \text{angleEq})}} \\ \underline{i}_0 &= \frac{-\underline{u} + \psi_m \cdot e^{(j \cdot \text{angleEq})}}{r_{str} + j \cdot x_q + (x_d - x_q)/2 \cdot e^{(j \cdot \text{angleEq})}} \end{aligned} \quad (17)$$

and  $\text{angleEq}$  is a state variable representing the angle of the q-axis voltage.

As seen above, the input parameters  $r_{str}$ ,  $x_d$ ,  $x_q$  and  $\psi_m$  are used in the Load Flow equations. For round-rotor machines it is valid that  $x_d = x_q$  and the above current equation gets a simplified form:

$$\underline{i} = \frac{-\underline{u} + \psi_m \cdot e^{(j \cdot \text{angleEq})}}{r_{str} + j \cdot x_q} \quad (18)$$

### 3 Short-Circuit Analysis

For short-circuit analysis, depending on the considered time phase following a grid fault, synchronous machines are represented by their:

- Subtransient equivalent
- Transient equivalent
- Synchronous equivalent

The distinction of the time dependence is due to the effect of increased stator currents on the induced currents in the damper windings, rotor mass and field winding. In the case of a fault near to a generator the stator current can increase so that the resulting magnetic field weakens the rotor field considerably. In steady state short circuit analysis, this field-weakening effect is represented by the corresponding equivalent source voltage and reactance. The associated positive sequence model of a synchronous machine is shown in Figure 3.1. The delayed effect of the stator field on the excitation and damping field is modelled by using different reactances depending on the time frame of the calculation.




Figure 3.1: Single-phase equivalent circuit diagrams of a generator for short-circuit current calculations which include the modelling of the field attenuation

#### 3.1 Calculation of transient and subtransient reactances

If only equivalent circuit data (please refer to section 6.1.1 for more information on dynamic data for the synchronous machine) is provided the short circuit impedances are calculated as follows [3]:

$$x'_d = x_l + \frac{x_{ad} \cdot (x_{fd} + x_{rld})}{x_{ad} + x_{fd} + x_{rld}} \quad (19)$$

$$x''_d = x_l + \frac{x_{1d} \cdot x_{fd} \cdot x_{ad} + x_{1d} \cdot x_{rld} \cdot x_{ad} + x_{rld} \cdot x_{fd} \cdot x_{ad}}{x_{ad} \cdot x_{fd} + x_{ad} \cdot x_{1d} + x_{1d} \cdot x_{fd} + x_{1d} \cdot x_{rld} + x_{rld} \cdot x_{fd}}$$

If the parameter  $x_{rld}$  is not provided, the equation above becomes much simpler ( $x_{rld} = 0$ ). The q-axis subtransient impedance is calculated as above, with using the q-axis instead of the d-axis parameters.

#### 3.2 Short-Circuit According to IEC 60909 or VDE 102/103

The IEC 60909 (equivalent to VDE 102/103) series of standards only calculates the subtransient time phase. Short circuit currents of longer time phases are assessed based on empirical methods by multiplying the subtransient fault current with corresponding factors.

Figure 3.2 shows the basic IEC 60909 short circuit model of a synchronous machine.




Figure 3.2: Short-circuit model for a synchronous machine

When calculating initial symmetrical (sub-transient) short-circuit currents in systems fed directly from generators without unit transformers, for example in industrial networks or in low-voltage networks, the following sequence-impedances have to be used:

- Positive sequence system:

$$z_1'' = r_{str} + jx_d'' \quad (20)$$

- Negative sequence system:

$$z_2 = r_2 + jx_2 \quad (21)$$

where normally it is assumed that  $x_2 = x_d''$ . If  $x_d''$  and  $x_q''$  differ significantly the following can be used:

$$x_2 = \frac{x_d'' + x_q''}{2} \quad (22)$$

- Zero sequence system:

$$z_0 = r_0 + jx_0 \quad (23)$$

For the sub-transient reactance, the saturated value  $x_{dsat}''$  has to be used leading to highest possible fault currents.

IEC 60909 (VDE 102/103) makes no provision of the pre-fault state. It always considers a voltage factor  $c_{max}$  of 1.1 (or 1.05 in LV-networks). Because this approach would lead to overestimated fault currents, the impedance is corrected by a correction factor. For power station units, the correction factor calculation takes into account the *Range of generator voltage Regulation* parameter  $pG$  which is located on the *Short-Circuit VDE/IEC* tab of *ElmSym*.

All short circuit indices are calculated precisely according to the IEC 60909 (VDE 102/103) standard.

### 3.3 Complete Short Circuit Method

In the complete short circuit method, the internal voltage source can be initialised by a preceding load flow calculation.

The complete short circuit method calculates subtransient and transient fault currents using subtransient and transient voltage sources and impedances. The subtransient impedances are calculated as in section 3.2. The positive sequence transient impedance is calculated as:

$$\underline{z}'_1 = r_{str} + jx'_d \quad (24)$$

Based on the calculated subtransient and transient (AC-) currents, *PowerFactory* derives other relevant short-circuit indices, such as peak short circuit current, peak-break current, AC-break current, equivalent thermal short circuit current by applying the relevant methods according to IEC60909.

#### 3.3.1 Single phase machine model

The single phase machine is supported only by the complete short circuit method.

The transient and subtransient short circuit models for the single-phase machine are also modelled as a single impedance and a voltage source. The transient and sub-transient impedances used for the transient and sub-transient short circuit calculation are:

$$\begin{aligned} \underline{z}' &= r_{str} + j \cdot \frac{\left( x'_d + \frac{x''_d + x''_q}{2} \right)}{2} \\ \underline{z}'' &= r_{str} + j \cdot \frac{\left( x''_d + \frac{x''_d + x''_q}{2} \right)}{2} \end{aligned} \quad (25)$$

### 3.4 ANSI-C37 Short-Circuit

Besides IEC 60909, *PowerFactory* supports short circuit calculation according to ANSI C-37. Similar to short circuit calculations according to IEC 60909, only subtransient fault currents are actually calculated.

For further details related to ANSI C-37, refer to the original ANSI C-37 standard and corresponding literature.

### 3.5 IEC 61363 Short-Circuit

The IEC 61363 standard describes procedures for calculating short-circuits currents in three-phase ac radial electrical installations on ships and on mobile and fixed offshore units.

The calculation of the short-circuit current for a synchronous machine is based on evaluating the envelope of the maximum values of the machine's actual time-dependent short-circuit current. The resulting envelope is a function of the basic machine parameters (power, impedance, etc.) and the active voltages behind the machine's subtransient, transient and steady-state impedance. The impedance is dependent upon the machine operating conditions immediately prior to the occurrence of the short-circuit condition.

When calculating the short-circuit current, only the highest values of the current are considered. The highest values vary as a function of time along the top envelope of the complex time-dependent function. The current defined by this top envelope is calculated from the equation:

$$i_K(t) = \sqrt{2} \cdot I_{ac}(t) + i_{dc}(t) \quad (26)$$

The a.c. component  $I_{ac}(t)$  is calculated with:

$$I_{ac}(t) = (I''_{kd} - I'_{kd}) \cdot e^{-t/T''_d} + (I'_{kd} - I_{kd}) \cdot e^{-t/T'_d} + I_{kd} \quad (27)$$

The subtransient, transient and steady-state currents are evaluated using equations:

$$I''_{kd} = E''_{q0} / Z''_d \quad \text{with} \quad Z''_d = (R_{str} + jX''_d) \quad (28)$$

and:

$$I'_{kd} = E'_{q0} / Z'_d \quad \text{with} \quad Z'_d = (R_{str} + jX'_d) \quad (29)$$

Internal voltages considering terminal voltage and pre-load conditions are calculated using equations:

$$E''_{q0} = \underline{U}_0 / \sqrt{3} + \underline{I}_0 \cdot \underline{Z}''_d \quad (30)$$

$$E'_{q0} = \underline{U}_0 / \sqrt{3} + \underline{I}_0 \cdot \underline{Z}'_d \quad (31)$$

The d.c. component can be evaluated from equation:

$$I_{dc}(t) = \sqrt{2} \cdot (I''_{kd} - I_0 \cdot \sin \phi_0) \cdot e^{-t/T_{dc}} \quad (32)$$



## 4 Optimal Power Flow

The Optimal Power Flow (OPF) function in *PowerFactory* allows the user to calculate optimal operational conditions, e.g. the minimisation of losses or production costs by adjusting the active and reactive power dispatch of the generators.

To consider the synchronous machine in the OPF calculation the following options have to be assigned on the *Optimal Power Flow* page of the synchronous machine element.

### 4.1 OPF Controls

It is possible to enable and disable the active and reactive power optimisation of the machine. The active power flag allows the active power dispatch of the machine to be optimised in the *OPF* calculation. On the other hand, the reactive power flag allows the voltage reference of the machine to be adapted according to the *OPF* optimisation function.

When these options are disabled, the synchronous machine is treated as in a conventional load flow calculation during the execution of the *OPF*.

### 4.2 Constraints: Active / Reactive Power Limits

For every machine a minimum and maximum active and reactive power limit can be defined. For the reactive power limits there is also the possibility to use the limits which are specified in the synchronous machine type (enable the flag *Use limits specified in type*) or include a capability curve (see section 2.2).

The active and reactive power limits will be considered in the *OPF* if and only if the individual constraint flag is checked in the synchronous machine element and the corresponding global flag is enabled in the Optimal Power Flow command.

### 4.3 Operating Cost

The operating costs of the synchronous machine are defined on the *Operating Cost* The table Operating Costs specifies the costs (\$/h) for the produced active power (MW) of the units. The representation of the data is shown automatically on the diagram below the table for checking purposes. The cost curve of a synchronous machine is calculated as the interpolation of the predefined cost points.

## 5 Harmonic Analysis

For frequency sweep calculation the synchronous machine is represented by an *Impedance* model. For harmonic load flow calculation, two additional models are available: *Thevenin Equivalent* and *Ideal Voltage Source*. The harmonic voltages given in the harmonic voltage source object are referred to the rated voltage of the synchronous machine.

The equivalent circuits of *Impedance* and the *Thevenin Equivalent* model for harmonics are shown in Figures 5.1 and 5.2 (using absolute values).




Figure 5.1: Harmonic load flow impedance model




Figure 5.2: Harmonic load flow thevenin equivalent model

### 5.1 Frequency dependency

The input parameters for the reactances in the model are valid at the fundamental frequency. Therefore, the per-unit values of the inductances and reactances are equivalent for frequency  $f$  equal to the base frequency  $f_{base} = f_{nom}$ :

$$x = \frac{\omega}{\omega_{base}} \cdot \frac{L}{L_{base}} \cdot \frac{\Omega}{\Omega} = \frac{2 \cdot \pi \cdot f}{2 \cdot \pi \cdot f_{nom}} \cdot \frac{L}{L_{base}} \cdot \frac{\Omega}{\Omega} = \frac{f}{f_{nom}} \cdot l = l \text{ p.u.} \quad (33)$$

The impedances in the harmonic analysis functions have frequency-dependent reactances due to the change in frequency in the term  $\omega_{nom} \cdot L$ . In addition, it is possible to consider the frequency dependency of the inductances  $l(f)$  and resistances  $r(f)$ :

$$z(f) = r(f) + j \cdot x(f) = r(f) + j \cdot \frac{f}{f_{nom}} \cdot l(f) = r(f) + j \cdot h \cdot l(f) \quad (34)$$

where  $h = f/f_{nom}$  is the harmonic order.

This frequency dependency of the inductances  $l(f)$  and resistances  $r(f)$  can be modelled using characteristics.

Several types of characteristics can be applied to the resistances and reactances, as shown on the *Harmonics/Power Quality* page of the synchronous machine type (*TypSym*) dialog:

- Frequency Polynomial Characteristic (*ChaPol*)

- Vector Characteristic (*ChaVec*)
- Matrix Characteristic (*ChaMat*)

For example, when using the vector characteristic, values for the resistance can be entered for predefined frequencies (defined through a frequency scale). When using the frequency polynomial characteristic, the stator resistance can be made frequency dependent using the parameters  $a$  and  $b$  according to the functions:

$$\begin{aligned} r_{str}(f) &= r_{str} \cdot k(f) = r_{str} \cdot \left( (1 - a) + a \cdot (f/f_{nom})^b \right) \\ r_{str}(f) &= r_{str} \cdot k(f) = r_{str} \cdot \left( 1 + a \cdot ((f/f_{nom}) - 1)^b \right) \end{aligned} \quad (35)$$

## 5.2 Impedance calculation

There are two methods available to calculate the impedance:

- Using standard parameters
- Using frequency transfer functions

### 5.2.1 Calculation using standard parameters

In the presence of harmonic currents, the average inductance is approximated by:

$$l'' = \frac{l_d'' + l_q''}{2} \quad (36)$$

If a characteristic is applied to  $l''$ , then the resulting value is  $l''(f)$ . The sequence and grounding impedance are then calculated as:

$$\begin{aligned} z_1(f) &= r_{str}(f) + j \cdot h \cdot l''(f) \\ z_2(f) &= r_2(f) + j \cdot h \cdot l_2(f) \\ z_0(f) &= r_0(f) + j \cdot h \cdot l_0(f) \\ z_e(f) &= r_e + j \cdot h \cdot l_e \end{aligned} \quad (37)$$

where the internal grounding impedance per-unit values are calculated as  $(r_{esy} + j \cdot x_{esy})/z_b = r_e + j \cdot x_e$  using the base impedance  $z_b = u_{gn}^2/sgn$  ( $u_{gn}$  is the rated voltage of the machine and  $sgn$  is the rated apparent power).

### 5.2.2 Calculation using frequency transfer functions (operational inductances)

If the option *Use frequency transfer functions* is enabled, the harmonic inductance is calculated using the input parameters provided on the RMS/EMT tabs of the *TypSym* dialog. Because of the accurate representation around nominal frequency, this model can increase the accuracy of sub-synchronous resonance studies based on frequency domain analysis. The effect of the transient and synchronous reactance is visible only in a very narrow band around nominal frequency (Figure 5.3).




Figure 5.3: Frequency domain representation of synchronous machine using the option *Use frequency transfer functions*

The positive and negative sequence impedances are calculated using the operational inductances for the d and q axes as shown in Equation 38 (where  $s$  is the Laplace operator).

$$\begin{aligned} l_d(s) &= l_d \cdot \frac{(1 + s \cdot t'_d) \cdot (1 + s \cdot t''_d)}{(1 + s \cdot t'_{d0}) \cdot (1 + s \cdot t''_{d0})} \\ l_q(s) &= l_q \cdot \frac{(1 + s \cdot t'_q) \cdot (1 + s \cdot t''_q)}{(1 + s \cdot t'_{q0}) \cdot (1 + s \cdot t''_{q0})} \end{aligned} \quad (38)$$

Equation 38 is valid for the standard round rotor synchronous machine model in *PowerFactory*. For the standard salient pole machine model, the parameters  $t'_q$  and  $t'_{q0}$  are zero and the terms  $(1 + s \cdot t'_q)$  and  $(1 + s \cdot t'_{q0})$  are neglected (this is valid for all following equations based on operational inductances).

Similarly, the operational inductances of the 3.3 model have an additional term in the numerator and denominator, utilising the sub-subtransient short-circuit and open-loop time constants  $t'''_d$ ,  $t'''_{d0}$ ,  $t'''_q$  and  $t'''_{q0}$ .

This option is not supported for the classical model and the model for asynchronous starting.

The frequency dependent inductances have the form:

$$\begin{aligned} l_d(f) &= l_d \cdot \frac{(1 + j \cdot \omega \cdot t'_d) \cdot (1 + j \cdot \omega \cdot t''_d)}{(1 + j \cdot \omega \cdot t'_{d0}) \cdot (1 + j \cdot \omega \cdot t''_{d0})} \\ l_q(f) &= l_q \cdot \frac{(1 + j \cdot \omega \cdot t'_q) \cdot (1 + j \cdot \omega \cdot t''_q)}{(1 + j \cdot \omega \cdot t'_{q0}) \cdot (1 + j \cdot \omega \cdot t''_{q0})} \end{aligned} \quad (39)$$

where  $\omega = \omega_{nom} \cdot (h - 1)$  for the positive sequence and  $\omega = \omega_{nom} \cdot (-h - 1)$  for the negative sequence inductances.

The positive and negative sequence impedances are then calculated as:

$$\begin{aligned} z_1(f) &= r_{str}(f) + j \cdot h \cdot \frac{l_{d1}(f) + l_{q1}(f)}{2} \\ z_2(f) &= r_{str}(f) + j \cdot h \cdot \frac{l_{d2}(f) + l_{q2}(f)}{2} \end{aligned} \quad (40)$$

The zero sequence and grounding impedances are calculated as in Equation 37.

Depending on the input data available for the model, the time constants for the operational inductances are taken directly or calculated from the input parameters:

- Short-circuit input data - standard model

The short-circuit time constants are taken directly from the input data and the open-loop time constants for the standard model are calculated as (using standard assumptions):

$$\begin{aligned} t'_{d0} &= t'_d \cdot \frac{l_d}{l'_d} \\ t''_{d0} &= t''_d \cdot \frac{l'_d}{l''_d} \\ t'_{q0} &= t'_q \cdot \frac{l_q}{l'_q} \\ t''_{q0} &= t''_q \cdot \frac{l'_q}{l''_q} \end{aligned} \quad (41)$$

For the salient pole machine, the q-axis time constants are calculated as:

$$\begin{aligned} t'_{q0} &= 0 \\ t''_{q0} &= t''_q \cdot \frac{l_q}{l''_q} \end{aligned} \quad (42)$$

- Equivalent circuit parameters input data - standard and 3.3 models

From the equivalent circuit parameters, the open-loop time constants and dynamic inductances are calculated according to [4] and [5]. The short-circuit time constants are then calculated according to Equation 41 and:

$$\begin{aligned} t'''_d &= t'''_{d0} \cdot \frac{l'''_d}{l'''_d} \\ t'''_q &= t'''_{q0} \cdot \frac{l'''_q}{l'''_q} \end{aligned} \quad (43)$$

- Operational inductances as input data - 3.3 model

In this case no calculation is possible since the data used in the operational reactances is available. The time constants  $t_{1d}, t_{2d}, t_{3d}, t_{1q}, t_{2q}, t_{3q}$  are the short-circuit time constants and  $t_{4d}, t_{5d}, t_{6d}, t_{4q}, t_{5q}, t_{6q}$  are the open-loop time constants.

### 5.2.3 Impedance calculation for the single-phase model

The impedance for the single-phase machine is calculated similar as for the three phase machine model (equations 37 or equations 40). Depending on the calculation method we have the following:

- Using standard parameters

$$z(f) = r_{str}(f) + j \cdot h \cdot l''(f) \quad (44)$$

- Using frequency transfer functions

$$z(f) = r_{str}(f) + j \cdot h \cdot \frac{\frac{l_{d1}(f) + l_{q1}(f)}{2} + \frac{l_{d2}(f) + l_{q2}(f)}{2}}{2} \quad (45)$$

#### 5.2.4 Flicker

Independent of the selected *Harmonic Model* (*Thevenin Equivalent*, *Ideal Voltage Source* or *Impedance*), the model is considered to be a constant current source in the positive sequence system.

*Note:* The different representations of the synchronous machine (as a current source in the flicker calculation and as a voltage source in harmonics) mean that some calculation results, such as *Pst20.cont*, will not be able to be back-calculated from values displayed in the single-line diagram.

## 6 RMS/EMT Simulation

In the following subsections the available synchronous machine models together with the input and output signals and state variables used for the RMS and EMT simulation are presented. In the appendix B, the calculation of some additional parameters is presented.

### 6.1 *PowerFactory* Standard Model

The standard model in *PowerFactory* is a synchronous machine model implemented according to [6], [7]. It is essentially using the complete second-order model equivalent circuit diagrams for the d- and q-axis same as in [8] and [3].

The rotor d-axis is always modelled by two rotor loops representing the excitation (field) winding and the 1d-damper winding. For the q-axis, *PowerFactory* supports two models, a salient-pole rotor machine model having only the 1q-damper winding and a round-rotor machine model with the 1q- and 2q-damper windings. According to the designation in the IEEE guide [8], these two models can also be referred to as Model 2.1 and Model 2.2, respectively.

Figures 6.1 to 6.3 show the equivalent circuit diagrams of the standard *PowerFactory* synchronous machine model, which are represented in a rotor reference system (Park coordinates, dq-reference frame).




Figure 6.1: d-axis equivalent circuit




Figure 6.2: q-axis equivalent circuit - salient rotor




Figure 6.3: q-axis equivalent circuit - round rotor

The equations presented in this section are valid for the round-rotor machine. The equations for the salient-rotor machine can be obtained by ignoring the 2q-damper winding variables and equations.

The standard *PowerFactory* model is written using subtransient variables. An overview of the basic equations of the synchronous machine together with how the subtransient model is obtained is given in Section 6.1.2.

### 6.1.1 Input Parameters

The typical parameters available for a synchronous machine are the short-circuit parameters. They can be entered directly into the standard *PowerFactory* synchronous machine model (*TypSym*) and are listed in Table 6.1.

Table 6.1: Standard input parameters of the synchronous machine

| Name in PF | Symbol    | Unit | Description                                         |
|------------|-----------|------|-----------------------------------------------------|
| $r_{str}$  | $r_{str}$ | p.u. | Stator resistance                                   |
| $x_l$      | $x_l$     | p.u. | Stator leakage reactance                            |
| $x_{rl}$   | $x_{rld}$ | p.u. | Coupling reactance between field and damper winding |
| $x_{rlq}$  | $x_{rlq}$ | p.u. | Coupling reactance between q-axis damper windings   |
| $x_d$      | $x_d$     | p.u. | Synchronous reactance d-axis                        |
| $x_q$      | $x_q$     | p.u. | Synchronous reactance q-axis                        |
| $x_{ds}$   | $x'_d$    | p.u. | Transient reactance d-axis                          |
| $x_{qs}$   | $x'_q$    | p.u. | Transient reactance q-axis                          |
| $x_{dss}$  | $x''_d$   | p.u. | Subtransient reactance d-axis                       |
| $x_{qss}$  | $x''_q$   | p.u. | Subtransient reactance q-axis                       |
| $t_{ds}$   | $t'_d$    | s    | Short-circuit transient time constant d-axis        |
| $t_{qs}$   | $t'_q$    | s    | Short-circuit transient time constant q-axis        |
| $t_{dss}$  | $t''_d$   | s    | Short-circuit subtransient time constant d-axis     |
| $t_{qss}$  | $t''_q$   | s    | Short-circuit subtransient time constant q-axis     |

As shown in Table 6.1, the short-circuit and not the open-loop time constants are used by the model. If open-loop time constants are selected as input ( $t_{dss0}$  ( $t'_{do}$ ),  $t_{qss0}$  ( $t'_{qo}$ ),  $t_{ds0}$  ( $t'_{do}$ ) and  $t_{qs0}$  ( $t'_{qo}$ )), the short circuit time constants are automatically calculated during the entering of the open-loop constants in the synchronous machine type. The calculated values (values used by the model) can be seen if the input mode is switched to short-circuit time constants. There are two ways to calculate the short-circuit from the open-loop time constants:

- Standard procedure (using simplifications)



The conversion in this case is carried out as follows:

$$\begin{aligned}
 t''_d &= t''_{do} \cdot \frac{x''_d}{x'_d} \\
 t''_q &= t''_{qo} \cdot \frac{x''_q}{x'_q} \\
 t'_d &= t'_{do} \cdot \frac{x'_d}{x_d} \\
 t'_q &= t'_{qo} \cdot \frac{x'_q}{x_q}
 \end{aligned} \tag{46}$$

In the case of a salient pole machine (the transient reactance  $x'_q$  and the transient time constant  $t'_q$  in the q-axis are not needed) the subtransient time constant  $t''_q$  is calculated using  $x_q$  instead of  $x'_q$ .

- Exact procedure

The exact procedure is based on [9] and requires solution of a quadratic equation which is obtained from the following equations:

$$\begin{aligned}
 t'_{do} + t''_{do} &= \frac{x_d}{x'_d} \cdot t'_d + \left(1 - \frac{x_d}{x'_d} + \frac{x_d}{x''_d}\right) \cdot t''_d \\
 t'_{do} \cdot t''_{do} &= \frac{x_d}{x''_d} \cdot t'_d \cdot t''_d
 \end{aligned} \tag{47}$$

The option *Exact conversion of time constants* is available in the *Advanced* tab of the synchronous machine type.

Table 6.2: Model parameters of the synchronous machine

| Name in PF | Symbol    | Unit | Description                                         |
|------------|-----------|------|-----------------------------------------------------|
| $r_{str}$  | $r_{str}$ | p.u. | Stator resistance                                   |
| $x_l$      | $x_l$     | p.u. | Stator leakage reactance                            |
| $x_{rl}$   | $x_{rld}$ | p.u. | Coupling reactance between field and damper winding |
| $x_{rlq}$  | $x_{rlq}$ | p.u. | Coupling reactance between q-axis damper windings   |
| $x_{ad}$   | $x_{ad}$  | p.u. | Mutual (magnetising) reactance, d-axis              |
| $x_{aq}$   | $x_{aq}$  | p.u. | Mutual (magnetising) reactance, q-axis              |
| $x_{fd}$   | $x_{fd}$  | p.u. | Reactance of excitation (field) winding (d-axis)    |
| $x_{1d}$   | $x_{1d}$  | p.u. | Reactance of 1d-damper winding (d-axis)             |
| $x_{1q}$   | $x_{1q}$  | p.u. | Reactance of 1q-damper winding (q-axis)             |
| $x_{2q}$   | $x_{2q}$  | p.u. | Reactance of 2q-damper winding (q-axis)             |
| $r_{fd}$   | $r_{fd}$  | p.u. | Resistance of excitation winding (d-axis)           |
| $r_{1d}$   | $r_{1d}$  | p.u. | Resistance of 1d-damper winding (d-axis)            |
| $r_{1q}$   | $r_{1q}$  | p.u. | Resistance of 1q-damper winding (q-axis)            |
| $r_{2q}$   | $r_{2q}$  | p.u. | Resistance of 2q-damper winding (q-axis)            |

The parameters used by the model internally are the parameters shown in the equivalent circuits (Figure 6.1 to Figure 6.3) and are listed in Table 6.2. If available, the equivalent circuit parameters can be directly entered in the standard *PowerFactory* model.

The impedance base is calculated using the rated voltage and rated apparent power as  $\frac{u_{gn}^2}{sgn}$ . The rotor variables are referred to the stator windings.

### 6.1.1.1 Conversion of Short-Circuit to Equivalent Circuit Parameters

From the short-circuit input parameters, the equivalent damper winding resistances and reactances can be calculated. *PowerFactory* applies an exact parameter conversion method as described in [10] and presented in [6] and [7]. Please note that the conversion is done when the RMS/EMT simulation is being initialised and the equivalent circuit type parameters are not being updated. The result parameters of the conversion process are available as calculation parameters.

The mutual reactances can be obtained from the synchronous and leakage reactances as follows:

$$\begin{aligned} x_{ad} &= x_d - x_l \\ x_{aq} &= x_q - x_l \end{aligned} \quad (48)$$

Using the help variables  $x_1$ ,  $x_2$ ,  $x_3$ ,  $T_1$ ,  $T_2$ ,  $a$  and  $b$ , the equivalent model parameters for the d-axis are calculated as follows:

$$\begin{aligned} x_1 &= x_d - x_l + x_{rld} \\ x_2 &= x_1 - \frac{(x_d - x_l)^2}{x_d} \\ x_3 &= \frac{x_2 - x_1 \cdot \frac{x_d''}{x_d}}{1 - \frac{x_d''}{x_d}} \end{aligned} \quad (49)$$

$$\begin{aligned} T_1 &= \frac{x_d}{x_d'} \cdot t_d' + \left(1 - \frac{x_d}{x_d'} + \frac{x_d}{x_d''}\right) \cdot t_d'' \\ T_2 &= t_d' + t_d'' \end{aligned} \quad (50)$$

$$\begin{aligned} a &= \frac{x_2 \cdot T_1 - x_1 \cdot T_2}{x_1 - x_2} \\ b &= \frac{x_3}{x_3 - x_2} \cdot t_d' \cdot t_d'' \end{aligned} \quad (51)$$

$$\begin{aligned} T_{\sigma fd} &= \frac{-a}{2} + \sqrt{\frac{a^2}{4} - b} \\ T_{\sigma 1d} &= \frac{-a}{2} - \sqrt{\frac{a^2}{4} - b} \end{aligned} \quad (52)$$

$$\begin{aligned} x_{fd} &= \frac{\frac{T_{\sigma fd} - T_{\sigma 1d}}{x_1 - x_2} + \frac{T_{\sigma 1d}}{x_3}}{\frac{T_{\sigma 1d} - T_{\sigma fd}}{x_1 - x_2} + \frac{T_{\sigma fd}}{x_3}} \\ x_{1d} &= \frac{\frac{T_{\sigma 1d} - T_{\sigma fd}}{x_1 - x_2} + \frac{T_{\sigma fd}}{x_3}}{\frac{T_{\sigma fd} - T_{\sigma 1d}}{x_1 - x_2} + \frac{T_{\sigma 1d}}{x_3}} \\ r_{fd} &= \frac{x_{fd}}{\omega_n \cdot T_{\sigma fd}} \\ r_{1d} &= \frac{x_{1d}}{\omega_n \cdot T_{\sigma 1d}} \end{aligned} \quad (53)$$

where  $\omega_n = 2 \cdot \pi \cdot F_{nom}$  is the nominal angular frequency.

The q-axis model parameters can be calculated analogously to the d-axis parameters in case of a round-rotor machine (two rotor-loops). For a salient pole machine (one rotor loop), the model parameters can be calculated as follows:

$$\begin{aligned} x_{1q} &= \frac{(x_q - x_l) \cdot (x_q'' - x_l)}{x_q - x_q''} \\ r_{1q} &= \frac{x_q''}{x_q} \cdot \frac{x_q - x_l + x_{1q}}{\omega_n \cdot t_q''} \end{aligned} \quad (54)$$

### 6.1.2 Equations for the standard model in *PowerFactory*

The equations are written using the dq rotor reference frame in generator orientation.

The standard *PowerFactory* synchronous machine model for time domain simulations uses the rotor fluxes, the speed  $n$  and the angle  $\varphi$  as state variables. The equations for both the RMS and EMT model are written using subtransient variables.

In the case of balanced RMS simulation, the available simulated values are positive sequence complex values. In the case of unbalanced RMS simulation, the available complex phase values for currents and voltages are first transformed into symmetrical components. For transforming to the dq-reference frame, the variables are shifted by multiplying with the transformation  $\cos \varphi - j \cdot \sin \varphi$ . The voltages and currents available from the EMT simulation are first transformed from instantaneous values in the  $\alpha\beta\gamma$  system using the Clarke transformation. The same transformation as above is used for transforming to the dq rotating reference frame.

Based on the equivalent circuit diagrams according to Figure 6.1 to Figure 6.3, the differential equations for the model can be derived.

The stator voltage equations can be described as follows:

$$\begin{aligned} u_d &= -r_{str} \cdot i_d - n \cdot \psi_q + \frac{1}{\omega_n} \cdot \frac{d\psi_d}{dt} \\ u_q &= -r_{str} \cdot i_q + n \cdot \psi_d + \frac{1}{\omega_n} \cdot \frac{d\psi_q}{dt} \\ u_0 &= -r_{str} \cdot i_0 + \frac{1}{\omega_n} \cdot \frac{d\psi_0}{dt} \end{aligned} \quad (55)$$

where  $n$  is the speed of the rotor and  $\omega_n = 2 \cdot \pi \cdot f_{nom}$  is the nominal angular frequency.

The stator flux linkage equations in the d- and q-axis have the following form:

$$\begin{aligned} \psi_d &= -(x_l + x_{ad}) \cdot i_d + x_{ad} \cdot i_{fd} + x_{ad} \cdot i_{1d} \\ \psi_q &= -(x_l + x_{aq}) \cdot i_q + x_{aq} \cdot i_{2q} + x_{aq} \cdot i_{1q} \end{aligned} \quad (56)$$

The stator flux equations can be also written in the following form:

$$\begin{aligned} \psi_d &= \psi_{ad} - x_l \cdot i_d \\ \psi_q &= \psi_{aq} - x_l \cdot i_q \end{aligned} \quad (57)$$

where  $\psi_{ad}$  and  $\psi_{aq}$  are the d- and q-axis components of the magnetising flux:

$$\begin{aligned} \psi_{ad} &= x_{ad} \cdot (-i_d + i_{1d} + i_{fd}) \\ \psi_{aq} &= x_{aq} \cdot (-i_q + i_{1q} + i_{2q}) \end{aligned} \quad (58)$$

The rotor flux linkage equations in the d- and q-axis have the following form:

$$\begin{aligned}
 \psi_{fd} &= -x_{ad} \cdot i_d + (x_{ad} + x_{rld} + x_{fd}) \cdot i_{fd} + (x_{ad} + x_{rld}) \cdot i_{1d} \\
 \psi_{1d} &= -x_{ad} \cdot i_d + (x_{ad} + x_{rld}) \cdot i_{fd} + (x_{ad} + x_{rld} + x_{1d}) \cdot i_{1d} \\
 \psi_{1q} &= -x_{aq} \cdot i_q + (x_{aq} + x_{rlq}) \cdot i_{2q} + (x_{aq} + x_{rlq} + x_{1q}) \cdot i_{1q} \\
 \psi_{2q} &= -x_{aq} \cdot i_q + (x_{aq} + x_{rlq} + x_{2q}) \cdot i_{2q} + (x_{aq} + x_{rlq}) \cdot i_{1q}
 \end{aligned} \tag{59}$$

Introducing the subtransient fluxes:

$$\begin{aligned}
 \psi_d'' &= k_{fd} \cdot \psi_{fd} + k_{1d} \cdot \psi_{1d} \\
 \psi_q'' &= k_{1q} \cdot \psi_{1q} + k_{2q} \cdot \psi_{2q}
 \end{aligned} \tag{60}$$

the stator fluxes can be expressed using subtransient values as:

$$\begin{aligned}
 \psi_d &= -x_d'' \cdot i_d + \psi_d'' \\
 \psi_q &= -x_q'' \cdot i_q + \psi_q''
 \end{aligned} \tag{61}$$

Using these definitions for the flux, the stator voltage equations can be rewritten as ([6], [7]):

$$\begin{aligned}
 u_d &= u_d'' - r_{str} \cdot i_d + n \cdot x_q'' \cdot i_q - \frac{x_d''}{\omega_n} \cdot \frac{di_d}{dt} \\
 u_q &= u_q'' - r_{str} \cdot i_q - n \cdot x_d'' \cdot i_d - \frac{x_q''}{\omega_n} \cdot \frac{di_q}{dt} \\
 u_0 &= -r_0 \cdot i_0 - \frac{x_0}{\omega_n} \cdot \frac{di_0}{dt}
 \end{aligned} \tag{62}$$

where the subtransient voltages are calculated using coupling factors:

$$\begin{aligned}
 u_d'' &= -n \cdot (k_{1q} \cdot \psi_{1q} + k_{2q} \cdot \psi_{2q}) + \left( \frac{k_{fd}}{\omega_n} \cdot \frac{d\psi_{fd}}{dt} + \frac{k_{1d}}{\omega_n} \cdot \frac{d\psi_{1d}}{dt} \right) \\
 u_q'' &= n \cdot (k_{fd} \cdot \psi_{fd} + k_{1d} \cdot \psi_{1d}) + \left( \frac{k_{1q}}{\omega_n} \cdot \frac{d\psi_{1q}}{dt} + \frac{k_{2q}}{\omega_n} \cdot \frac{d\psi_{2q}}{dt} \right)
 \end{aligned} \tag{63}$$

The coupling factors  $k_{fd}$  and  $k_{1d}$  and the subtransient reactance in the d-axis  $x_d''$  are defined as:

$$\begin{aligned}
 k_{fd} &= \frac{x_{ad} \cdot x_{1d}}{(x_{ad} + x_{rld}) \cdot (x_{1d} + x_{fd}) + x_{fd} \cdot x_{1d}} \\
 k_{1d} &= \frac{x_{ad} \cdot x_{fd}}{(x_{ad} + x_{rld}) \cdot (x_{1d} + x_{fd}) + x_{fd} \cdot x_{1d}} \\
 x_d'' &= x_{ad} + x_l - (k_{1d} + k_{fd}) \cdot x_{ad}
 \end{aligned} \tag{64}$$

The coupling factors  $k_{1q}$  and  $k_{2q}$  and the subtransient reactance in the q-axis  $x_q''$  are defined depending on whether the machine has a round-rotor or salient-pole rotor. For the salient-pole rotor machine:

$$\begin{aligned}
 k_{1q} &= \frac{x_{aq}}{x_{aq} + x_{rlq} + x_{1q}} \\
 k_{2q} &= 0 \\
 x_q'' &= x_{aq} + x_l - k_{1q} \cdot x_{aq}
 \end{aligned} \tag{65}$$

and for the round-rotor machine (similar as for the d-axis) we have the following:

$$\begin{aligned}
 k_{1q} &= \frac{x_{aq} \cdot x_{2q}}{(x_{aq} + x_{rlq}) \cdot (x_{2q} + x_{1q}) + x_{2q} \cdot x_{1q}} \\
 k_{2q} &= \frac{x_{aq} \cdot x_{1q}}{(x_{aq} + x_{rlq}) \cdot (x_{2q} + x_{1q}) + x_{2q} \cdot x_{1q}} \\
 x_q'' &= x_{aq} + x_l - (k_{2q} + k_{1q}) \cdot x_{aq}
 \end{aligned} \tag{66}$$

The electrical torque is calculated using the stator currents and stator fluxes and the rated power factor  $\cos n$ :

$$t_e = \frac{i_q \cdot \psi_d - i_d \cdot \psi_q}{\cos n} \quad \text{p.u.} \quad (67)$$

The rotor voltage equations for the d-axis and q-axis have the following form:

$$\begin{aligned} v_{fd} &= r_{fd} \cdot i_{fd} + \frac{1}{\omega_n} \cdot \frac{d\psi_{fd}}{dt} \\ 0 &= r_{1d} \cdot i_{1d} + \frac{1}{\omega_n} \cdot \frac{d\psi_{1d}}{dt} \\ 0 &= r_{1q} \cdot i_{1q} + \frac{1}{\omega_n} \cdot \frac{d\psi_{1q}}{dt} \\ 0 &= r_{2q} \cdot i_{2q} + \frac{1}{\omega_n} \cdot \frac{d\psi_{2q}}{dt} \end{aligned} \quad (68)$$

The following expressions are valid for the rotor currents:

$$\begin{aligned} i_{fd} &= k_{fd} \cdot i_d + \frac{x_{1d\text{loop}} \cdot \psi_{fd} - (x_{ad} + x_{rl}) \cdot \psi_{1d}}{x_{det.d}} \\ i_{1d} &= k_{1d} \cdot i_d + \frac{x_{fd\text{loop}} \cdot \psi_{1d} - (x_{ad} + x_{rl}) \cdot \psi_{fd}}{x_{det.d}} \\ i_{1q} &= k_{1q} \cdot i_q + \frac{x_{2q\text{loop}} \cdot \psi_{1q} - (x_{aq} + x_{rlq}) \cdot \psi_{2q}}{x_{det.q}} \\ i_{2q} &= k_{2q} \cdot i_q + \frac{x_{1q\text{loop}} \cdot \psi_{2q} - (x_{aq} + x_{rlq}) \cdot \psi_{1q}}{x_{det.q}} \end{aligned} \quad (69)$$

where:

$$\begin{aligned} x_{det.d} &= (x_{ad} + x_{rld}) \cdot (x_{1d} + x_{fd}) + x_{fd} \cdot x_{1d} \\ x_{det.q} &= (x_{aq} + x_{rlq}) \cdot (x_{2q} + x_{1q}) + x_{2q} \cdot x_{1q} \end{aligned} \quad (70)$$

For a salient pole machine the current in the 2q-damper winding  $i_{2q}$  is zero and the current in the Q-damper winding has the following form:

$$i_{1q} = k_{1q} \cdot i_q + \frac{\psi_{1q}}{x_{1q}} \quad (71)$$

In the above equations the following reactances have been used (reactance sum per a winding loop):

$$\begin{aligned} x_{fd\text{loop}} &= x_{ad} + x_{rld} + x_{fd} \\ x_{1d\text{loop}} &= x_{ad} + x_{rld} + x_{1d} \\ x_{1q\text{loop}} &= x_{aq} + x_{rlq} + x_{1q} \\ x_{2q\text{loop}} &= x_{aq} + x_{rlq} + x_{2q} \end{aligned} \quad (72)$$

### 6.1.2.1 Equations for the RMS model

The RMS model uses the equations presented in Section 6.1.2 where some simplifications are being done. Normally, for large-scale stability studies the transformer voltage terms and

the effect of speed variations are neglected in the stator voltage equations as discussed in [3]. These simplifications are also discussed in [8] where it is noted that the speed variation effect should not be neglected for frequency stability studies especially when studying islanding conditions.

The stator dynamics are relatively fast for stability studies. Therefore, for RMS-simulations, the derivatives of the stator quantities (transformer voltage terms) are not considered in the equations. This allows also using bigger time steps compared to the EMT model. Taking into account this simplification, the stator voltage Equations 62 and 63 can be written as:

$$\begin{aligned} u_d &= u_d'' - r_{str} \cdot i_d + n \cdot x_q'' \cdot i_q \\ u_q &= u_q'' - r_{str} \cdot i_q - n \cdot x_d'' \cdot i_d \end{aligned} \quad (73)$$

where the subtransient voltages are calculated as:

$$\begin{aligned} u_d'' &= -n \cdot \psi_q'' \\ u_q'' &= n \cdot \psi_d'' \end{aligned} \quad (74)$$

Additional simplification can be made to the model by modifying the effect of the speed variation on the stator voltages (option available on the *Advanced* tab of the *RMS-Simulation* page of the *TypSym* edit dialog). Depending on the option selected, Equation 73 and Equation 74 are modified as follows:

- Effect of speed variation considered  
The equations have the form as already presented and the speed is considered in the equations.
- Effect of speed variation neglected  
The speed is set equal to the initial speed in both equations. It is assumed that the speed changes are small and they don't have a big effect on the stator voltage [3]. The model is valid for speed deviations around initial speed.
- Effect of speed variation partially neglected  
The speed  $n$  is set to initial speed when multiplying with the sub-transient reactances and stator currents (only in Equation 73). The speed variation is considered when multiplying the sub-transient fluxes.

The option *Considered* should not be used for direct motor starting applications since during starting there is a big difference between the speed of the machine and the network frequency. The simulated results without this option are similar to the results of the EMT model. For motor starting applications including variable speed drives the speed effect variation option should be considered.

For studies where the torque is of true interest, the EMT model is more appropriate.

Another available option is to select an extended model [11] (*Advanced* tab of the *RMS-Simulation* page). This model provides an approximation of the rotor back-swing effect. It is using an iterative time scale separation and is based on the singular perturbation theory. The difference to the standard model is that in the extended model the electrical and mechanical state variables need to be corrected for every time step of the RMS simulation. The following corrections are

applied to the rotor fluxes and rotor speed:

$$\begin{aligned}
\Delta\psi_{fd}^k &= -r_{fd}/x_d'' \cdot \Delta\psi_q^k \\
\Delta\psi_{1d}^k &= -r_{1d}/x_d'' \cdot \Delta\psi_q^k \\
\Delta\psi_{1q}^k &= r_{1q}/x_q'' \cdot \Delta\psi_d^k \\
\Delta\psi_{2q}^k &= r_{2q}/x_q'' \cdot \Delta\psi_d^k \\
\Delta n^k &= \frac{\Delta\psi_d^k/x_d'' \cdot (k_{fd} \cdot \psi_{fd} + k_{1d} \cdot \psi_{1d}) + \Delta\psi_q^k/x_q'' \cdot (\psi_{1q} \cdot k_{1q} + \psi_{2q} \cdot k_{2q})}{2 \cdot \pi \cdot f_{nom} \cdot t_{ag} \cdot \cos n}
\end{aligned} \tag{75}$$

where the variation of the stator fluxes  $\psi_d$  and  $\psi_q$  over a time step is:

$$\begin{aligned}
\Delta\psi_d^k &= \psi_d^k - \psi_d^{k-1} \\
\Delta\psi_q^k &= \psi_q^k - \psi_q^{k-1}
\end{aligned} \tag{76}$$

The level of saturation depends on the magnetising fluxes  $\psi_{ad}$  and  $\psi_{aq}$ :

$$\psi_{ad} = (u_q + r_{str} \cdot i_q)/n + x_l \cdot i_d \tag{77}$$

$$\psi_{aq} = -(u_d + r_{str} \cdot i_d)/n + x_l \cdot i_q \tag{78}$$

$$\psi_m = \sqrt{\psi_{ad}^2 + \psi_{aq}^2} \tag{79}$$

where the nominal value of the speed is being used if the speed variation is not considered (with  $n = 1$  it is assumed that the magnetising flux is equal to the magnetising voltage).

In the case of unbalanced RMS simulation, additionally the negative sequence, the zero sequence and neutral equations (if neutral is connected) have to be satisfied.

The negative sequence equations take into account the negative sequence impedance of the model as shown in Equation 80. Depending on the type of study, the studied phenomena of interest can be strongly influenced by the value of the negative sequence impedance. Therefore, it is worth noting that this value is not constant [3].

$$\underline{u}_2 = -(r_{2sy} + j \cdot x_{2sy}) \cdot \underline{i}_2 \tag{80}$$

If the machine has 'YN' connection (type parameter *nsly*), the zero sequence impedance  $r_{0sy} + j \cdot x_{0sy}$  can be entered in the model. The internal grounding impedance and neutral connection information can be also defined (*Grounding/Neutral Conductor* tab of the *Basic Data* page of *ElmSym*). The internal grounding impedance per unit values are calculated as  $(r_{esy} + j \cdot x_{esy})/z_b = r_e + j \cdot x_e$  using the base impedance  $z_b = u_{gn}^2/sgn$  ( $u_{gn}$  is the rated voltage of the machine and  $sgn$  is the rated apparent power).

Three different cases can be distinguished depending on the neutral conductor and internal grounding impedance connection modes:

- No neutral connection and internal grounding impedance connected

In this case there is need only for zero sequence equations:

$$\underline{u}_0 = -(r_{0sy} + j \cdot x_{0sy}) \cdot \underline{i}_0 - 3 \cdot (r_e + j \cdot x_e) \cdot \underline{i}_0 \tag{81}$$

- N-connection at terminal (ABC-N)

When a neutral conductor is connected, zero sequence and equations for the neutral are required. Here two sub-cases are possible:

- Internal grounding impedance not connected

$$\underline{u}_0 = -(r_{0sy} + j \cdot x_{0sy}) \cdot \underline{i}_0 + \underline{u}_n \tag{82}$$

$$0 = 3 \cdot \underline{i}_0 + \underline{i}_n \tag{83}$$

– Internal grounding impedance connected

$$\underline{u}_0 = -(r_{0sy} + j \cdot x_{0sy}) \cdot \underline{i}_0 + \underline{u}_n \quad (84)$$

$$\underline{u}_n = -(r_e + j \cdot x_e) \cdot (3 \cdot \underline{i}_0 + \underline{i}_n) \quad (85)$$

• N-connection at separate terminal (internal grounding impedance is never connected)

$$\underline{u}_0 = -(r_{0sy} + j \cdot x_{0sy}) \cdot \underline{i}_0 + \underline{u}_n \quad (86)$$

$$0 = 3 \cdot \underline{i}_0 + \underline{i}_n \quad (87)$$

For the unbalanced RMS simulation, a negative sequence torque is taken into the equation of motion (Equation 100) if the option *Consider negative sequence torque* is selected. The negative sequence torque is calculated as:

$$t_{e2} = \frac{(r_{2sy} - r_{str}) \cdot \underline{i}_2^2}{\cos n} \quad (88)$$

The positive sequence torque  $t_{e1}$  is calculated according to Equation 67. The total electrical torque  $t_e$  is the sum of the positive and negative sequence torques

$$t_e = t_{e1} + t_{e2} \quad (89)$$

### 6.1.2.2 Equations for the EMT model

For the EMT model, the stator voltage equations are rewritten ([6], [7]) to be based on the stator  $\alpha\beta 0$  stationary reference frame.

The following equations are obtained for the stator voltage  $\underline{u}_{\alpha\beta} = u_\alpha + j \cdot u_\beta$ :

$$\begin{aligned} \underline{u}_{\alpha\beta} &= \underline{u}_{\alpha\beta}'' - r_{str} \cdot \underline{i}_{\alpha\beta} - j \cdot 2 \cdot n \cdot x_{\Delta}'' \cdot e^{j \cdot 2 \cdot \varphi} \cdot \underline{i}_{\alpha\beta}^* - \frac{x''}{\omega_n} \cdot \frac{d\underline{i}_{\alpha\beta}}{dt} - \frac{x_{\Delta}''}{\omega_n} \cdot e^{j \cdot 2 \cdot \varphi} \cdot \frac{d\underline{i}_{\alpha\beta}^*}{dt} \\ u_0 &= -r_0 \cdot i_0 - \frac{x_0}{\omega_n} \cdot \frac{di_0}{dt} \end{aligned} \quad (90)$$

where the subtransient voltage is calculated by transforming the subtransient voltages in the dq axis (from Equation 63) to the  $\alpha\beta 0$  stationary reference frame using the rotor position angle  $\varphi$ :

$$\underline{u}_{\alpha\beta}'' = (u_d'' + j \cdot u_q'') \cdot e^{j \cdot \varphi} \quad (91)$$

In the above equations,  $x_{\Delta}''$  and  $x''$  are calculated as:  $x_{\Delta}'' = \frac{x_d'' - x_q''}{2}$  and  $x'' = \frac{x_d'' + x_q''}{2}$ .

The level of saturation depends on the magnetising fluxes  $\psi_{ad}$  and  $\psi_{aq}$  which are calculated from Equation 57. The magnitude of the magnetisation flux is calculated as:

$$\psi_m = \sqrt{(\psi_d + x_l \cdot i_d)^2 + (\psi_q + x_l \cdot i_q)^2} \quad (92)$$

Same as for the RMS simulation, if the *Connection* is set to 'YN' (type parameter *nslty*), the zero sequence parameters can be entered and the internal grounding impedance and neutral connection information can be defined.

Three different cases can be distinguished depending on the neutral conductor and internal grounding impedance connection modes:



- No neutral connection and internal grounding impedance connected

In this case there is need only for a zero sequence equation:

$$u_0 = -(r_0 + 3 \cdot r_e) \cdot i_0 - (x_0 + 3 \cdot x_e) \cdot \frac{1}{h\pi i} \cdot \frac{di_0}{dt} \quad (93)$$

- N-connection at terminal (ABC-N)

When a neutral conductor is connected, a zero sequence and an equation for the neutral are required. Here two sub-cases are possible:

- Internal grounding impedance not connected

$$u_0 = -r_0 \cdot i_0 - x_0 \cdot \frac{1}{h\pi i} \cdot \frac{di_0}{dt} + u_n \quad (94)$$

$$0 = 3 \cdot i_0 + i_n \quad (95)$$

- Internal grounding impedance connected

$$u_0 = -r_0 \cdot i_0 - x_0 \cdot \frac{1}{h\pi i} \cdot \frac{di_0}{dt} + u_n \quad (96)$$

$$u_n = -r_e \cdot (3 \cdot i_0 + i_n) - \frac{x_e}{h\pi i} \cdot \left( 3 \cdot \frac{di_0}{dt} + \frac{di_n}{dt} \right) \quad (97)$$

- N-connection at separate terminal (internal grounding impedance is never connected)

$$u_0 = -r_0 \cdot i_0 - x_0 \cdot \frac{1}{h\pi i} \cdot \frac{di_0}{dt} + u_n \quad (98)$$

$$0 = 3 \cdot i_0 + i_n \quad (99)$$

### 6.1.2.3 Mechanical Equations

The speed derivative  $dn/dt$  of the machine is calculated using the following equation:

$$\frac{dn}{dt} = \begin{cases} \frac{t_m - t_e - t_{dkd} - t_{dpe}}{t_{ag}} & \text{p.u./s for generators} \\ \frac{-t_m - t_e - t_{dkd} - t_{dpe}}{t_{ag}} & \text{p.u./s for motors} \end{cases} \quad (100)$$

where:

- $t_m$  is the mechanical torque in p.u.;
- $t_e$  is the electrical torque in p.u. calculated according to Equation 67;
- $t_{dkd}$  is damping torque in p.u.
- $t_{dpe}$  is damping torque based on power in p.u.
- $t_{ag}$  is the acceleration time constant in s

From Equation 100 can be seen that, if there is a difference between the torques, the rotor will be accelerated or decelerated. This equation represents the equation of motion.

In the case of a synchronous motor, if the speed falls under zero, the speed derivative  $\frac{dn}{dt}$  is set to zero so that the motor can not get a negative speed.

The base torque is the ratio between the electrical active power and the nominal mechanical angular frequency in mech. rad/s:

$$t_{base} = \frac{sgn \cdot \cos n \cdot 1e^6}{\omega_{mech,n}} \quad \text{Nm} \quad (101)$$

#### 6.1.2.4 Mechanical Torque

The calculation of the mechanical torque  $t_m$  (parameter  $xmt$ ) depends on if the machine is defined as a motor or as a generator:

$$t_m = \begin{cases} \frac{pt}{n} - xmdm - dpu \cdot n + addmt & \text{p.u. for generators} \\ xmdm + dpu \cdot n + addmt & \text{p.u. for motors} \end{cases} \quad (102)$$

where:

- $xmdm$  is the *Torque Input* input signal in p.u.;
- $addmt$  is the *Additional Torque* parameter in p.u.. It can be used as an additional MDM torque for the motor or as an additional  $pt$  torque for the generator;
- $dpu \cdot n$  is turbine shaft friction torque in p.u.;
- $pt$  is the *Turbine Power* input signal in p.u.;
- $n$  is the *speed* in p.u..

#### 6.1.2.5 Damping Torque

In *PowerFactory*, the damping torque can be considered in the swing equation by using one (or more) of the three coefficients available in the synchronous machine type:

- *Turbine shaft friction torque coefficient* ( $dpu$ );
- *Damping torque coefficient* ( $dkd$ );
- *Damping torque coefficient based on power* ( $dpe$ ).

The coefficients are used to calculate the damping torques as follows:

- $dpu$  (in p.u. torque/p.u. speed) is multiplied by the speed to get the turbine shaft friction torque ( $dpu \cdot n$ ) in p.u.. It is being considered in Equation 102;
- $dkd$  (in p.u. torque/p.u. speed deviation) is used for calculating the *Damping torque* (parameter  $c$  :  $xmdkd$ ) as follows:

$$t_{dkd} = dkd \cdot (n - n_{ref}) \quad (103)$$

where  $n_{ref}$  can be selected to be the nominal speed (1 p.u.) of the machine or the speed of the local reference machine. The damping torque is being considered in Equation 100;

- $dpe$  (in p.u. power/p.u. speed deviation) is used for calculating the *Damping torque based on power* (parameter  $c$  :  $xmdpe$ ) as follows:

$$t_{dpe} = \frac{dpe}{n} \cdot (n - n_{ref}) \quad (104)$$

where  $n_{ref}$  can be selected to be the nominal speed (1 p.u.) of the machine or the speed of the local reference machine. The damping torque based on power is being considered in Equation 100;

If the speed deviation for the damping torque  $t_{dkd}$  and  $t_{dpe}$  is calculated based on the nominal speed of the machine, it follows that:

- If the machine operates at nominal speed, the damping torque will be zero.
- If the speed of the machine deviates from the nominal speed, the damping torque will tend to return the machines speed towards nominal speed.

If the calculated speed deviation is based on the local reference machine speed, it follows that:

- If the machine is the reference machine, the damping torque will be zero.
- If the speed of the machine deviates from the speed of the reference machine, the damping torque will tend to return the machines speed towards the speed of the reference machine.

The damping torque based on power can be used to represents the change of electrical load dependent on frequency, as seen from the machine. This effect is usually included in the load model.

### 6.1.2.6 Acceleration Time Constant

The acceleration time constant  $t_{ag}$ , which is also referred as the mechanical starting time ([3]) is equal to  $t_{ag} = 2 \cdot H$  in s where  $H$  is the inertia constant. In *PowerFactory*, the inertia of the machine can be entered using one of the following options:

- Acceleration time constant  $T_{ag}$  rated to  $Pgn$ ,
- Acceleration time constant  $T_{ag}$  rated to  $Sgn$ ,
- Inertia constant  $H$  rated to  $Pgn$ ,
- Inertia constant  $H$  rated to  $Sgn$ ,
- Moment of inertia  $J$ .

The following equation is used for calculating  $t_{ag}$  from the moment of inertia  $J$ :

$$t_{ag} = 2 \cdot H = \frac{J \cdot \omega_{mech.n}^2}{sgn \cdot cosn \cdot 1e6} \quad \text{s} \quad (105)$$

$$\omega_{mech.n} = \frac{\omega_n}{\text{polepairs}} = \frac{2 \cdot \pi \cdot Fnom}{\text{polepairs}} \quad \text{mech.rad/s} \quad (106)$$

where:

- $J$  is the moment of inertia in  $\text{kgm}^2$ ;
- $sgn$  is the *Rated Apparent Power* type parameter;
- $cosn$  is the *Rated Power Factor* type parameter;
- $\omega_{mech.n}$  is the rated mechanical angular frequency;
- $\omega_n$  is the rated electrical angular frequency;
- $Fnom$  is the nominal frequency Hz;
- $\text{polepairs}$  is the number of pole-pairs.

The synchronous speed can be calculated as:

$$Ns = \frac{60 \cdot Fnom}{\text{polepairs}} \quad \text{rev/min} \quad (107)$$

**Mechanical load definition for synchronous motors** In the case of a synchronous motor, also a moment of inertia for a mechanical load can be entered (RMS- and EMT-Simulation pages of *ElmSym*). The calculation of  $t_{me}$  considers also the gear ratio (speed ratio) of a gear train. The total acceleration time  $t_{tot}$  for the motor is then:

$$\begin{aligned} t_{tot} &= t_{ag} + t_{me} \cdot \text{gear ratio}^2 \\ &= t_{ag} + \frac{J}{sgn \cdot \cos n \cdot 1e6} \cdot \left( \frac{\omega_n}{\text{polepairs}} \cdot \text{gear ratio} \right)^2 \\ &= t_{ag} + \frac{J}{sgn \cdot \cos n \cdot 1e6} \cdot (\omega_n \cdot \text{gratio})^2 \quad \text{s} \end{aligned} \quad (108)$$

where  $\text{gratio} = \text{gear ratio} / \text{polepairs}$  is a parameter which can be entered for the mechanical load (the number of pole-pairs has been introduced within  $\text{gratio}$  in order that the acceleration time constants  $t_{ag}$  and  $t_{me}$  have the same base).

### 6.1.2.7 Initialisation of the mechanical parameters

The initialisation of the mechanical parameters depends on which input signals are connected to the model:

- Input signal  $pt$  is connected (if  $xmdm$  is not connected, then  $xmdm = 0$ ):

$$pt = (t_e + dpu \cdot n + xmdm) \cdot n \quad \text{p.u.} \quad (109)$$

- Input signal  $xmdm$  is connected:

$$xmdm = -t_e - dpu \cdot n \quad \text{p.u.} \quad (110)$$

If both input signals  $pt$  and  $xmdm$  are not connected, then for a generator case  $xmdm = 0$  and  $pt$  is calculated according to Equation 109. For a motor case  $pt = 0$  and  $xmdm$  is calculated according to Equation 110.

The initialisation of the mechanical torque  $t_m$  ( $xmt$ ) depends on whether if the machine is defined as a motor or as a generator:

$$t_m = \begin{cases} \frac{pt}{n} - (xmdm + dpu \cdot n) & \text{p.u. for generators} \\ xmdm + dpu \cdot n & \text{p.u. for motors} \end{cases} \quad (111)$$

Per default, the speed  $n$  of the machine is initialised to  $n = 1$  p.u.. When the circuit-breaker of a synchronous motor is open and the motor is not spinning, the speed is initialised to zero. This is useful for motor starting applications in both RMS- and EMT-simulation.

### 6.1.3 Rotor angle definitions

*PowerFactory* defines several rotor angles based on different references. The values of the rotor angles are wrapped in the range between  $-\pi$  and  $\pi$  degrees. An example of a graphical representation of the rotor angles is given in Figure 6.4.




Figure 6.4: Rotor angle definitions example

The following variables are available:

- *fipol* (in deg): Internal rotor angle of the machine (also called load angle). It is referred to the terminal voltage (local bus voltage) of the generator and is calculated as:

$$fipol = fi + 90^\circ - \phi_{iu} \quad \text{deg} \quad (112)$$

where  $\phi_{iu}$  is the voltage angle of the machine terminal *m:phiu* (for unbalanced calculation *m:phiu1*).

An info message is displayed in the output window of *PowerFactory* if  $fipol \geq 85^\circ$  and a warning message is printed if  $fipol \geq 90^\circ$ ;

- *firot* (in deg): External rotor angle of the machine. It is referred to the reference voltage of the network (slack bus voltage) and is calculated as:

$$firot = fi + 90^\circ - \phi_{iu_{ref}} - (\phi_{iini} - \phi_{iini_{ref}}) \cdot 180^\circ / \pi \quad \text{deg} \quad (113)$$

where  $\phi_{iu_{ref}}$  is the voltage angle of the reference machine terminal *m:phiu* (or for unbalanced calculation *m:phiu1*),  $\phi_{iini}$  and  $\phi_{iini_{ref}}$  represent the initial voltage angle of the generator and of the reference machine terminals.

The basic data parameter *b:phiini* is available for terminals. It takes into account the initial dispatch angle of the reference machine and the vector group phase shift displacements of the transformers (e.g. if the initial dispatch angle of the reference machine is  $0^\circ$  and there is a Dyn5 transformer connected between the reference machine and the generator, the initial angle of the generator terminal will be  $\phi_{iini} = -210^\circ \cdot \pi / 180 = 150^\circ \cdot \pi / 180 \text{ rad}$ );

- *firel* (in deg): Rotor angle referred to that of the reference machine (slack machine). It is the angle between the q-axes (d-axes) of the reference machine and the generator. The angle *firel* is being calculated according to the following equation:

$$firel = fi - fi_{ref} - (\phi_{iini} - \phi_{iini_{ref}}) \cdot 180^\circ / \pi \quad \text{deg} \quad (114)$$

where  $fi_{ref}$  is the *fi* angle of the reference machine;

- *phi* (in rad): The angle *phi*, also referenced to as  $\varphi$ , is the position of the rotor (d-axis) referred to the reference voltage of the network. The angle  $\varphi$  is a state variable in the model and its time derivative  $d\varphi/dt$  is calculated as follows:

$$\frac{d\varphi}{dt} = \begin{cases} \omega_n \cdot (n - f_{ref}) & \text{rad in the RMS simulation} \\ \omega_n \cdot n & \text{rad in the EMT simulation} \end{cases} \quad (115)$$

where  $f_{ref}$  is an input signal connected to the reference machine frequency automatically by *PowerFactory*.

The state variable  $\varphi$  is initialised by the q-axis angle, and then it is shifted to the d-axis ( $-90^\circ$ ):

$$\varphi = \arctan(\underline{u}_t + (r_{str} + j \cdot x_q) \cdot \underline{i}_t) - \frac{\pi}{2} \quad \text{rad} \quad (116)$$

where  $\underline{u}_t$  is the terminal voltage of the machine,  $r_{str}$  is the stator resistance,  $x_q$  is the q-axis synchronous reactance of the machine and  $\underline{i}_t$  is the current flowing through the machine.

For the reference machine (slack), the reference frequency is equal to the speed ( $f_{ref} = n$ ) and the derivative of the angle is zero ( $\frac{d\varphi}{dt} = 0$ ). When the reference systems of two separated areas are merged using the pre-synchronising event (*EvtPresync*), the input signal  $f_{ref}$  of one reference machine is connected to the main reference machine automatically.

- *fi* (in deg): The angle *fi* is equal to *phi* expressed in degrees.

#### 6.1.3.1 Out of step detection

The out of step detection (pole slip) is based on the angle *firel* (rotor angle of the synchronous machine in respect to the rotor angle of the local reference).

The parameter *outofstepdet* in deg is used for the out of step detection. This parameter can be changed by the user (located in the calculation of the initial conditions 'Basic Options' page) and its default value is 360 degrees. There are two different options available depending on the *iopt\_outofstep* parameter:

- Out of step is detected when the rotor angle *firel* reaches the angle *outofstepdet* defined by the user.
- Out of step is detected when the rotor angle *firel* changes by *outofstepdet* degrees from its initial operating point.

When this happens, an out of step message is printed in the output window and the output signal *outofstep* is set to one. To reset the out of step signal, the value of the parameter *slipreset* needs to be changed using a parameter event to *slipreset* = 1. Please note that the loss of synchronism tool uses the *outofstep* output signal.

If the machine is the local reference machine, then *firel* remains zero and no out of step can be detected.

The out of step detection is carried out only for RMS simulation.

#### 6.1.4 Saturation

The model described so far is a purely linear model not considering any saturation effects. Generally, there exists saturation for all reactances of the synchronous machine model. For the

purpose of system analysis, main flux saturation can be considered in the model by considering saturation of the mutual (magnetising) reactances  $x_{ad}$  and  $x_{aq}$ . Saturation in subtransient reactances is not considered since they are less susceptible to saturation effects. The saturation of stator leakage reactance is a current-dependent saturation, i.e. high currents after short-circuits will lead to a saturation effect of the leakage reactance. The saturation of the leakage reactance is supported only in Model 3.3.

Figure 6.5 shows a main-flux saturation curve (full line). The linear line represents the air-gap line indicating the excitation current required to overcome the reluctance of the air-gap. The degree of saturation is the deviation of the open-circuit characteristic from the air-gap line. The y-axis is the terminal voltage in p.u. and the x-axis is the excitation current in p.u..




Figure 6.5: Open-circuit saturation characteristic

The extent of main flux saturation is different in the d- and q-axis. The saturation data usually provided is the open circuit saturation characteristic (Figure 6.5) which represents the saturation in the d-axis. In power system studies this data is being used to calculate the main flux saturation in the d-axis for salient-pole machines and the main flux saturation in the d- and q-axis in the case of round-rotor machines [3].

Measurements of the saturation in the q-axis of a round-rotor machines [4], have shown that the q-axis saturates in a greater extent compared to the d-axis (Figure 6.6). The model in *PowerFactory* supports data for separate saturation in the d- and q-axis.

The saturation curve of the main-flux can be defined in *PowerFactory* by a:

- *Quadratic* function using parameters  $SG_{10}$  and  $SG_{12}$ ;
- *Exponential* function using parameters  $SG_{10}$  and  $SG_{12}$ ;
- Smoothed curve with point-pairs of terminal voltage and the corresponding field current or  $SG(u)$  entered in a table (*Tabular Input*).

In all cases, a saturation coefficient  $c_{sat}$  is calculated which is used for the calculation of the saturation factors in the d- and q-axis  $sat_d$  and  $sat_q$ . The saturated values of the mutual reactances are then calculated as:

$$\begin{aligned} x_{ad} &= sat_d \cdot x_{adu} \\ x_{aq} &= sat_q \cdot x_{aqu} \end{aligned} \tag{117}$$




Figure 6.6: d- and q-axis saturation characteristics

When entering the saturation data in the table, the data has to be based on the non-reciprocal system of the appropriate axis which yields a slope of the air-gap line equal to one. For example, when entering d-axis saturation data a non-reciprocal system based on the unsaturated value of the d-axis mutual reactance needs to be used. For the q-axis, a non-reciprocal system based on the unsaturated value of the q-axis mutual reactance needs to be used. When using the quadratic or the exponential function, the curve is automatically based on the corresponding non-reciprocal p.u. system.

#### 6.1.4.1 Saturation coefficient calculation

- Saturation curve defined using a quadratic or exponential function  
The function can be defined specifying the excitation current  $i_{1.0p.u.}$  and  $i_{1.2p.u.}$  needed to obtain 1.0 p.u. and 1.2 p.u. of the rated generator voltage under no-load conditions (Figure 6.5). With these values the parameters  $SG_{10}$  and  $SG_{12}$  can be calculated as:

$$SG_{10} = \frac{i_{1.0}}{i_0} - 1 \quad (118)$$

$$SG_{12} = \frac{i_{1.2}}{1.2 \cdot i_0} - 1 \quad (119)$$

– Quadratic:

Based on the two parameters  $SG_{10}$  and  $SG_{12}$ , a quadratic approximation is applied and the  $c_{sat}$  coefficient is calculated as:

$$c_{sat} = \begin{cases} \frac{B_g \cdot (\psi_m - A_g)^2}{\psi_m} & \text{if } \psi_m > A_g \\ 0 & \text{if } \psi_m \leq A_g \end{cases} \quad (120)$$

where:

$$A_g = \frac{1.2 - \sqrt{1.2 \cdot \frac{SG_{12}}{SG_{10}}}}{1 - \sqrt{1.2 \cdot \frac{SG_{12}}{SG_{10}}}} \quad (121)$$

$$B_g = \frac{SG_{10}}{(1 - A_g)^2} \quad (122)$$



– Exponential:

Based on the same parameters  $SG_{10}$  and  $SG_{12}$ , an exponential approximation is applied and the  $c_{sat}$  coefficient is calculated as:

$$c_{sat} = \frac{SG_{10} \cdot \psi_m^{exp}}{\psi_m} \quad (123)$$

where the exponent is defined as:

$$exp = \frac{\ln \left( 1.2 \cdot \frac{SG_{12}}{SG_{10}} \right)}{\ln(1.2)} \quad (124)$$

• Saturation curve defined using tabular input

A smoothed curve is being created from the entered point-pairs and the *Smoothing Factor* (parameter *smoothfac* in %)  $c_{sat}$  is calculated as:

$$c_{sat} = \frac{f(x, y, \psi_m)}{\psi_m} \quad (125)$$

with  $x(i) = satv(i)$  and  $y(i) = satse(i) \cdot satv(i)$ .

The calculation of the excitation current  $i_{fd}$  % from  $satse$  p.u. ( $SG(u)$ ) and vice-versa is done according to:

$$\begin{aligned} i_{fd} &= (satse + 1) \cdot \psi_m \cdot 100 \\ satse &= \frac{i_{fd}/100}{\psi_m} - 1 \end{aligned} \quad (126)$$

#### 6.1.4.2 Options for calculating the saturation factors

One of the following saturation options can be selected for the synchronous machine type in *PowerFactory*:

• *d- and q-axis (flux magnitude) saturation*

This common saturation option is normally used for the round-rotor machine when only the open-circuit characteristic is available, which is normally the case (d-axis).

Using the magnitude of the magnetisation flux (calculated according to Equation 79 or 92), the saturation coefficient  $c_{sat}$  is being determined. Then, the saturation factors are calculated as follows:

$$\begin{aligned} sat_d &= \frac{1}{1 + c_{sat}} \\ sat_q &= \frac{1}{1 + \frac{x_{aqu}}{x_{adu}} \cdot c_{sat}} \end{aligned} \quad (127)$$

where the  $x_{adu}$  and  $x_{aqu}$  are the unsaturated values of the mutual reactances.

• *d- and q-axis equal (flux magnitude) saturation*

This saturation option is similar to the previous option. The difference is that the  $sat_q$  in this case is equal to  $sat_d$  (a multiplication factor is not being used):

$$\begin{aligned} sat_d &= \frac{1}{1 + c_{sat}} \\ sat_q &= \frac{1}{1 + c_{sat}} \end{aligned} \quad (128)$$

- *d-axis only (flux magnitude) saturation*

This option is normally used for the salient-rotor machine when only the open-circuit characteristic is available. The saturation coefficient is calculated same as in the previous options and the saturation factors have the following form:

$$\begin{aligned} sat_d &= \frac{1}{1 + c_{sat}} \\ sat_q &= 1 \end{aligned} \quad (129)$$

- *d- and q-axis (flux components) separate saturation*

When the characteristics for the d- and q-axis are available, a saturation coefficient is calculated from each characteristic. For this option, the magnitude of the magnetisation flux is not used, but its d- and q-axis components appropriately.

The saturation factors are calculated as:

$$\begin{aligned} sat_d &= \frac{1}{1 + c_{sat_d}} \\ sat_q &= \frac{1}{1 + c_{sat_q}} \end{aligned} \quad (130)$$

- *d-axis only (flux component, d-axis) separate saturation*

This case is analogue to the *d-axis (flux magnitude)* case, with the difference that here, instead of the flux magnitude, the d-axis component of the magnetising flux is being used. Since the d-axis component has a different form compared to the magnitude of the magnetising flux, the saturation will be somewhat different.

The saturation factors are calculated as in Equation 129.

### 6.1.5 Excitation system interfacing

All the quantities until now have been based on the standard “xadu” reciprocal p.u. system. The excitation current in the reciprocal system is being initialised as  $i_{fd} = ((x_{ad} + x_l) \cdot i_d + \psi_d) / x_{ad}$ .

For practicality reasons, another p.u. system is used for interfacing to the excitation system models. These p.u. system is usually referred to a non-reciprocal p.u. system (for more information refer to Chapter 8.6 in [3]).

The excitation current output signal  $i_e$  and the excitation voltage input signal  $v_e$  (both in the non-reciprocal system) are used for interfacing with the excitation system.

One of the non-reciprocal p.u. systems widely used is the no load, no saturation p.u.-system. In this system, excitation current of  $i_e = 1$  p.u. is required to produce 1 p.u. stator voltage on the air-gap line under no-load, steady-state and rated speed conditions. Excitation voltage of  $v_e = 1$  p.u. is the corresponding excitation voltage. The values are higher with saturation.

The excitation current  $i_e$  (in the non-reciprocal p.u. system) is calculated from the excitation current  $i_{fd}$  (in the reciprocal p.u. system) as:

$$i_e = x_{adu} \cdot i_{fd} \quad (131)$$

From the excitation voltage  $v_e$  (in the non-reciprocal p.u. system),  $u_{fd}$  (in the reciprocal p.u. system) is calculated as:

$$v_{fd} = \frac{r_{fd}}{x_{adu}} \cdot v_e \quad (132)$$

The excitation voltage input signal is being initialised as:

$$v_e = i_e \quad (133)$$

#### 6.1.5.1 Excitation system base modes in *PowerFactory*

By modifying the base equations with the parameter  $i_{fdBase}$  and  $e_{fdBaseRatio}$  (ratio between the exciter rated voltage and the machine excitation rated voltage), additional non-reciprocal p.u. systems can be defined. With these two parameters, the equations for the excitation current and voltage (Equations 131 and 132) obtain a new form:

$$i_e = x_{adu} \cdot i_{fd} \cdot (1/i_{fdBase}) \quad (134)$$

$$v_{fd} = \frac{r_{fd}}{x_{adu}} \cdot v_e \cdot (i_{fdBase} \cdot e_{fdBaseRatio}) \quad (135)$$

and similarly, for the initialisation of excitation voltage input signal the following is obtained:

$$v_e = i_e \cdot (1/e_{fdBaseRatio}) \quad (136)$$

The user can select between three different excitation system base modes in the *RMS-Simulation* and *EMT-Simulation* pages of the *ElmSym*:

- Air gap line mode (no load system without saturation)

This mode is the default in *PowerFactory* and it has been described above. In this mode  $i_{fdBase} = 1$ . This is the standard excitation base used by the IEEE.

- No load system with saturation mode

Under no-load, steady-state and rated speed conditions, excitation current of  $i_e = 1$  p.u. is required to produce 1 p.u. stator voltage for the machine with saturation. Excitation voltage of  $v_e = 1$  p.u. is the corresponding excitation voltage.

In this mode  $i_{fdBase} = 1/sat_d$  where  $sat_d$  is being calculated for 1 p.u. magnetisation voltage.

- Full load system with saturation mode

Under full load, steady-state and rated speed conditions, excitation current of  $i_e = 1$  p.u. is required to produce 1 p.u. stator voltage for the machine with saturation. Excitation voltage of  $v_e = 1$  p.u. is the corresponding excitation voltage.

In this mode  $i_{fdBase}$  corresponds to the excitation current calculated for full load conditions (equal to  $v_{e,rated}$ ).

The choice of the base system to be used should match with the system used by the excitation system.

In older versions of *PowerFactory* the rotor currents and fluxes of the standard model were based on the non-reciprocal p.u. system. For compatibility reasons, these quantities are still available only for the standard model:

$$\begin{aligned} i_D &= x_{adu} \cdot i_{1d} \\ i_Q &= x_{aqu} \cdot i_{1q} \\ i_x &= x_{aqu} \cdot i_{2q} \end{aligned} \quad (137)$$

$$\begin{aligned}
\psi_e &= \frac{x_{adu}}{x_{fd\_loop\_u}} \cdot \psi_{fd} \\
\psi_D &= \frac{x_{adu}}{x_{1d\_loop\_u}} \cdot \psi_{1d} \\
\psi_Q &= \frac{x_{aqu}}{x_{1q\_loop\_u}} \cdot \psi_{1q} \\
\psi_x &= \frac{x_{aqu}}{x_{2q\_loop\_u}} \cdot \psi_{2q}
\end{aligned} \tag{138}$$

where the reactance sums  $x_{fd\_loop\_u}$ ,  $x_{1d\_loop\_u}$ ,  $x_{1q\_loop\_u}$  and  $x_{2q\_loop\_u}$  are calculated as in Equation 72 where  $x_{ad}$  is being replaced with its unsaturated value  $x_{adu}$  and  $x_{aq}$  with  $x_{aqu}$ .

### 6.1.6 Delta Speed Input Signal

The input signal  $dw$  (delta speed) can be used to calculate sub-synchronous oscillations between DC links and synchronous generators. See also IEEE 1204 (Guide for planning DC links).

The speed can be modified with the additional input signal  $dw$ , e.g. connect to Fourier source. With the new signal it is possible to calculate the damping of a generator connected on a DC links over a frequency range.




Figure 6.7: Application for Delta Speed input signal

If the  $dw$  input signal is connected, the parameter  $t_{ag}$  (Acceleration Time Constant) is internally set to  $\infty$ .

The input signal  $dw$  is per default initialised to zero and modifies the speed as  $n' = n + dw$ .

The  $dw$  input signal is available for the RMS- and the EMT-Simulation for all generator models

except the classical model.

### 6.1.7 Integrated AVR for Motor Starting

When the synchronous machine is operating as a motor, the motor is starting, and the option *Use integrated AVR for motor starting* is activated, then the simplified AVR model shown in Figure 6.8 is used where:

- $rf_{st}$  is the starting field resistance
- $ie$  is the excitation current
- $speed_{th}$  is the speed threshold, at which the excitation will be triggered
- $ve_{const}$  is the constant value of excitation voltage
- $ve$  is the excitation voltage




Figure 6.8: Integrated AVR for motor starting

The motor is considered to be starting when the simulation is performed and the motor speed is 0, or a motor starting command is performed using the dynamic simulation type. If the simulation is not considered a motor starting, then the corresponding input signal  $ve$  is used.

### 6.1.8 Inputs/Outputs/State Variables of the Dynamic Model

#### 6.1.8.1 Stability Model (RMS)

Table 6.3: Input Definition of the RMS-Model

| Input Signal | Symbol    | Description                                    | Unit |
|--------------|-----------|------------------------------------------------|------|
| ve           | $v_e$     | Excitation voltage                             | p.u. |
| pt           |           | Turbine power                                  | p.u. |
| xmdm         |           | Torque input                                   | p.u. |
| fref         | $f_{ref}$ | Reference frequency                            | p.u. |
| freflocal    |           | Reference frequency of local reference machine | p.u. |
| dw           |           | Delta speed                                    | p.u. |

Table 6.4: State Variables Definition of the RMS-Model

| Parameter | Symbol      | Description                       | Unit |
|-----------|-------------|-----------------------------------|------|
| psifd     | $\psi_{fd}$ | Excitation flux                   | p.u. |
| psi1d     | $\psi_{1d}$ | Flux in 1d-damper winding, d-axis | p.u. |
| psi1q     | $\psi_{1q}$ | Flux in 1q-damper winding, q-axis | p.u. |
| psi2q     | $\psi_{2q}$ | Flux in 2q-damper winding, q-axis | p.u. |
| speed     | $n$         | Speed                             | p.u. |
| phi       | $\varphi$   | Rotor position angle              | rad  |

Table 6.5: Output Definition of the RMS-Model

| Parameter | Symbol  | Description                                                                  | Unit |
|-----------|---------|------------------------------------------------------------------------------|------|
| ut        | $ u_t $ | Terminal Voltage, Magnitude                                                  | p.u. |
| utr       |         | Terminal Voltage, Real Part                                                  | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                                             | p.u. |
| pgt       |         | Electrical Power (based on rated active power)                               | p.u. |
| ie        | $i_e$   | Excitation Current (in non-reciprocal p.u. system)                           | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                                                 | rad  |
| xspeed    |         | Speed ( $xspeed = speed$ )                                                   | p.u. |
| xme       | $t_e$   | Electrical Torque                                                            | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                                            | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude                                         | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part                                         | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part                                    | p.u. |
| P1        |         | Positive-Sequence, Active Power                                              | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                                            | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                                           | p.u. |
| outofstep |         | Out of step (pole slip) is "1" if generator is out of step and "0" otherwise |      |

### 6.1.8.2 EMT-Model

Table 6.6: Input Definition of the EMT-Model

| Input Signal | Symbol | Description        | Unit |
|--------------|--------|--------------------|------|
| ve           | $v_e$  | Excitation Voltage | p.u. |
| pt           |        | Turbine Power      | p.u. |
| xmdm         |        | Torque Input       | p.u. |
| dw           |        | Delta speed        | p.u. |

Table 6.7: State Variables Definition of the EMT-Model

| Parameter | Symbol      | Description                                      | Unit |
|-----------|-------------|--------------------------------------------------|------|
| psifd     | $\psi_{fd}$ | Excitation flux                                  | p.u. |
| psi1d     | $\psi_{1d}$ | Flux in 1d-damper winding, d-axis                | p.u. |
| psi1q     | $\psi_{1q}$ | Flux in 1q-damper winding, q-axis                | p.u. |
| psi2q     | $\psi_{2q}$ | Flux in 2q-damper winding, q-axis                | p.u. |
| psid      | $\psi_d$    | Stator flux, d-axis - only if saturation is used | p.u. |
| psiq      | $\psi_q$    | Stator flux, q-axis - only if saturation is used | p.u. |
| speed     | $n$         | Speed                                            | p.u. |
| phi       | $\varphi$   | Rotor position angle                             | rad  |

Table 6.8: Output Definition of the EMT-Model

| Parameter | Symbol  | Description                                        | Unit |
|-----------|---------|----------------------------------------------------|------|
| ussd      | $u_d''$ | Subtransient Voltage, d-axis                       | p.u. |
| ussq      | $u_q''$ | Subtransient Voltage, q-axis                       | p.u. |
| ut        | $ u_t $ | Terminal Voltage, Magnitude                        | p.u. |
| utr       |         | Terminal Voltage, Real Part                        | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                   | p.u. |
| pgt       |         | Electrical Power (based on rated active power)     | p.u. |
| ie        | $i_e$   | Excitation Current (in non-reciprocal p.u. system) | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                       | rad  |
| xspeed    | n       | Speed ( $xspeed = speed$ )                         | p.u. |
| xme       | $t_e$   | Electrical Torque                                  | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                  | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude               | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part               | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part          | p.u. |
| P1        |         | Positive-Sequence, Active Power                    | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                  | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                 | p.u. |

## 6.2 GENQEC model

The GENQEC model in *PowerFactory* is a synchronous machine model implemented according to the model description in [12]. This model is similar to the standard *PowerFactory* model and the main differences between the two models are due to the difference in the:

- Complete or "standard" second-order representation
  - The *PowerFactory* standard model (same as in [8], [4] and [3]) is based on the complete second-order IEEE representation where a coupling reactance between the field and the d-axis damper winding is being used.
  - The GENQEC model is based on the classical "standard" second-order IEEE representation (coupling reactance is not considered) where in addition a rotor current compensation factor  $kw$  has been added to the model. The classical "standard" equations are used to calculate the model parameters.
- Consideration of saturation
  - The saturation in the *PowerFactory* standard model is applied on the magnetizing reactance.
  - In the GENQEC model, the saturation is applied to the magnetizing reactance and to the rotor reactances.

The GENQEC model block diagrams and how they are derived is given in [12].

### 6.2.1 Input parameters and conversion

The GENQEC model uses as inputs the parameters given in Table 6.9.

Table 6.9: Standard input parameters of the synchronous machine GENQEC model

| Name in PF | Symbol     | Unit | Description                                 |
|------------|------------|------|---------------------------------------------|
| $r_{str}$  | $r_{str}$  | p.u. | Stator resistance                           |
| $x_l$      | $x_l$      | p.u. | Stator leakage reactance                    |
| $kw$       | $kw$       | p.u. | rotor current compensation factor           |
| $x_d$      | $x_d$      | p.u. | Synchronous reactance d-axis                |
| $x_q$      | $x_q$      | p.u. | Synchronous reactance q-axis                |
| $x_{ds}$   | $x'_d$     | p.u. | Transient reactance d-axis                  |
| $x_{qs}$   | $x'_q$     | p.u. | Transient reactance q-axis                  |
| $x_{dss}$  | $x''_d$    | p.u. | Subtransient reactance d-axis               |
| $x_{qss}$  | $x''_q$    | p.u. | Subtransient reactance q-axis               |
| $t_{ds0}$  | $t'_{d0}$  | s    | Open-loop transient time constant d-axis    |
| $t_{qs0}$  | $t'_{q0}$  | s    | Open-loop transient time constant q-axis    |
| $t_{dss0}$ | $t''_{d0}$ | s    | Open-loop subtransient time constant d-axis |
| $t_{qss0}$ | $t''_{q0}$ | s    | Open-loop subtransient time constant q-axis |

The impedance base is calculated using the rated voltage and rated apparent power as  $\frac{u_{gn}^2}{sgn}$ . The rotor variables are referred to the stator windings.



### 6.2.1.1 Conversion of Parameters

If instead of the open-loop time constants, the short circuit time constants are given, then they can be also directly used in *PowerFactory*. The conversion can be executed according to the "standard" or according to the exact procedure as described in Section 6.1.1.

Also equivalent circuit-data can be entered for the model (Table 6.10) from which the standard input parameters can be calculated (Table 6.9).

Table 6.10: Alternative input parameters of the synchronous machine GENQEC model

| Name in PF | Symbol    | Unit | Description                              |
|------------|-----------|------|------------------------------------------|
| $r_{str}$  | $r_{str}$ | p.u. | Stator resistance                        |
| $x_l$      | $x_l$     | p.u. | Stator leakage reactance                 |
| $x_{ad}$   | $x_{ad}$  | p.u. | Mutual (magnetising) reactance, d-axis   |
| $x_{aq}$   | $x_{aq}$  | p.u. | Mutual (magnetising) reactance, q-axis   |
| $kw$       | $kw$      | p.u. | rotor current compensation factor        |
| $x_{1d}$   | $x_{1d}$  | p.u. | Reactance of 1d-damper winding (d-axis)  |
| $r_{1d}$   | $r_{1d}$  | p.u. | Resistance of 1d-damper winding (d-axis) |
| $x_{fd}$   | $x_{fd}$  | p.u. | Reactance of field winding (d-axis)      |
| $r_{fd}$   | $r_{fd}$  | p.u. | Resistance of field winding (d-axis)     |
| $x_{1q}$   | $x_{1q}$  | p.u. | Reactance of 1q-damper winding (q-axis)  |
| $r_{1q}$   | $r_{1q}$  | p.u. | Resistance of 1q-damper winding (q-axis) |
| $x_{2q}$   | $x_{2q}$  | p.u. | Reactance of 2q-damper winding (q-axis)  |
| $r_{2q}$   | $r_{2q}$  | p.u. | Resistance of 2q-damper winding (q-axis) |

The calculation is done according to the "standard" classical conversion where the coupling reactance between field and damper winding is not taken into account.

For the d-axis parameters the following is valid:

$$\begin{aligned}
 x_d &= x_{ad} + x_l \\
 x'_d &= x_l + \frac{x_{ad} \cdot x_{fd}}{x_{ad} + x_{fd}} \\
 x''_d &= x_l + \frac{x_{ad} \cdot x_{fd} \cdot x_{1d}}{x_{ad} \cdot x_{fd} + x_{ad} \cdot x_{1d} + x_{fd} \cdot x_{1d}} \\
 t'_{d0} &= \frac{x_{ad} + x_{fd}}{r_{fd} \cdot 2 \cdot \pi \cdot Fnom} \\
 t''_{d0} &= \left( x_{1d} + \frac{x_{ad} \cdot x_{fd}}{x_{ad} + x_{fd}} \right) \cdot \frac{1}{r_{1d} \cdot 2 \cdot \pi \cdot Fnom}
 \end{aligned} \tag{139}$$

The q-axis model parameters can be calculated analogously to the d-axis parameters in case of a round-rotor machine (two rotor-loops) as:

$$\begin{aligned}
 x_q &= x_{aq} + x_l \\
 x'_q &= x_l + \frac{x_{aq} \cdot x_{1q}}{x_{aq} + x_{1q}} \\
 x''_q &= x_l + \frac{x_{aq} \cdot x_{1q} \cdot x_{2q}}{x_{aq} \cdot x_{1q} + x_{aq} \cdot x_{2q} + x_{1q} \cdot x_{2q}} \\
 t'_{q0} &= \frac{x_{aq} + x_{1q}}{r_{1q} \cdot 2 \cdot \pi \cdot Fnom} \\
 t''_{q0} &= \left( x_{2q} + \frac{x_{aq} \cdot x_{1q}}{x_{aq} + x_{1q}} \right) \cdot \frac{1}{r_{2q} \cdot 2 \cdot \pi \cdot Fnom}
 \end{aligned} \tag{140}$$

The q-axis parameters for salient machines are calculated as follows:

$$\begin{aligned}
 x_q &= x_{aq} + x_l \\
 x'_q &= x_q \\
 x'_q &= x_l + \frac{x_{aq} \cdot x_{1q}}{x_{aq} + x_{1q}} \\
 t'_{q0} &= 0 \\
 t''_{q0} &= \frac{x_{aq} + x_{1q}}{r_{1q} \cdot 2 \cdot \pi \cdot F_{nom}}
 \end{aligned} \tag{141}$$

### 6.2.2 Model equations

The rotor variables are referred to the stator windings and the equations are written using the rotor reference frame in generator orientation.

In the case of balanced RMS simulation, the available simulated values are positive sequence complex values. In the case of unbalanced RMS simulation, the available complex phase values for currents and voltages are first transformed into symmetrical components. For transforming to the dq-reference frame, the variables are shifted by multiplying with the transformation  $\cos \varphi - j \cdot \sin \varphi$ . The voltages and currents available from the EMT simulation are first transformed from instantaneous values in the  $\alpha\beta\gamma$  system using the Clarke transformation. The same transformation as above is used for transforming to the dq rotating reference frame.

The GENQEC synchronous machine model for RMS simulations uses the rotor fluxes, the speed  $n$  and the angle  $\varphi$  as state variables. The EMT model uses two more state variables (stator fluxes  $\psi_d$  and  $\psi_q$ ).

#### 6.2.2.1 Equations for the RMS model

As previously mentioned, the GENQEC model in *PowerFactory* is implemented according to the model description in [12] valid for RMS simulation.

The rotor voltage equations for the d-axis and q-axis have the following form:

$$\begin{aligned}
 \frac{d\psi_{fd}}{dt} &= \frac{v_e - i_e}{t'_{d0}} \\
 \frac{d\psi_{1d}}{dt} &= \frac{-\psi_{1d} - (x'_d - x_l) \cdot i_d \cdot \text{sat}_d + \psi_{fd}}{\text{sat}_d \cdot t'_{d0}} \\
 \frac{d\psi_{1q}}{dt} &= \frac{-\psi_{1q} - (x'_q - x_l) \cdot i_q \cdot \text{sat}_q + \psi_{2q}}{\text{sat}_q \cdot t'_{q0}} \\
 \frac{d\psi_{2q}}{dt} &= - \frac{\psi_{2q} + (x_q - x'_q) \cdot (i_q \cdot \text{sat}_q + \frac{x'_q - x''_q}{(x'_q - x_l)^2} \cdot (\psi_{2q} - \psi_{1q} - (x'_q - x_l) \cdot i_q \cdot \text{sat}_q))}{\text{sat}_q \cdot t'_{q0}}
 \end{aligned} \tag{142}$$

For salient machines  $\frac{d\psi_{2q}}{dt}$  is set to zero.

The subtransient fluxes are calculated as follows:

$$\begin{aligned}
 \psi''_d &= \frac{x''_d - x_l}{x'_d - x_l} \cdot \psi_{fd} + \frac{x'_d - x''_d}{x'_d - x_l} \cdot \psi_{1d} \\
 \psi''_q &= \frac{x''_q - x_l}{x'_q - x_l} \cdot \psi_{2q} + \frac{x'_q - x''_q}{x'_q - x_l} \cdot \psi_{1q}
 \end{aligned} \tag{143}$$

The stator fluxes can be expressed using the subtransient values as:

$$\begin{aligned}\psi_d &= -((x_d'' - x_l) \cdot sat_d + x_l) \cdot i_d + \psi_d'' \\ \psi_q &= -((x_q'' - x_l) \cdot sat_q + x_l) \cdot i_q + \psi_q''\end{aligned}\quad (144)$$

The excitation current is calculated as:

$$i_e = \frac{\psi_{fd} + (x_d - x_d') \cdot (i_d \cdot sat_d + \frac{x_d' - x_d''}{(x_d' - x_l)^2} \cdot (\psi_{fd} - \psi_{1d} - (x_d' - x_l) \cdot i_d \cdot sat_d))}{sat_d \cdot (1 - kw \cdot i_d)} \quad (145)$$

where the  $kw \cdot i_d$  term is limited between:  $-0.4 < kw \cdot i_d < 0.4$ .

The stator voltage equation is:

$$\begin{aligned}u_d &= -r_{str} \cdot i_d - n \cdot \psi_q \\ u_q &= -r_{str} \cdot i_q + n \cdot \psi_d\end{aligned}\quad (146)$$

Similar as in the standard *PowerFactory* RMS model, additional change can be made to the model by modifying the effect of the speed variation on the stator voltages (option located on the *Advanced* tab of the *RMS-Simulation* page of the *TypSym* edit dialog). Depending on the option selected, Equation 146 is modified as follows:

- Effect of speed variation considered

The equations have the form as already presented and the speed is considered in the equations.

- Effect of speed variation neglected

The speed is set equal to the initial speed in both equations. It is assumed that the speed changes are small and they don't have a big effect on the stator voltage [3]. The model is then valid for speed deviations around initial speed.

The option *Considered* should not be used for direct motor starting applications since during starting there is a big difference between the speed of the machine and the network frequency. The simulated results without this option are similar to the results of the EMT model. For motor starting applications including variable speed drives the speed effect variation option should be considered. For studies where the torque is of true interest, the EMT model is more appropriate.

The electrical torque is calculated using the stator currents and stator fluxes and the rated power factor  $\cos n$ :

$$t_e = \frac{i_q \cdot \psi_d - i_d \cdot \psi_q}{\cos n} \quad \text{p.u.} \quad (147)$$

In the case of unbalanced RMS simulation the same neutral, zero and negative sequence equations have to be satisfied as in Section 6.1.2.1.

For the unbalanced RMS simulation, the model takes into account also a negative sequence torque into the equation of motion (Equation 100). The negative sequence torque is calculated as:

$$t_{e2} = \frac{(r_{2sy} - r_{str}) \cdot i_2^2}{\cos n} \quad \text{p.u.} \quad (148)$$

The positive sequence torque  $t_{e1}$  is calculated according to Equation 147. The total electrical torque  $t_e$  is the sum of the positive and negative sequence torques:

$$t_e = t_{e1} + t_{e2} \quad \text{p.u.} \quad (149)$$

### 6.2.2.2 Equations for the EMT model

The GENQEC model described in [12] is an RMS model where the transformer voltage terms in the stator voltage are neglected ([3], [8]). In order to obtain an EMT model, the transformer voltage terms need to be added to the stator voltage equations.

The stator voltage equations for the GENQEC EMT model have the following form:

$$\begin{aligned}u_d &= -r_{str} \cdot i_d - n \cdot \psi_q + \frac{1}{\omega_n} \cdot \frac{d\psi_d}{dt} \\u_q &= -r_{str} \cdot i_q + n \cdot \psi_d + \frac{1}{\omega_n} \cdot \frac{d\psi_q}{dt} \\u_0 &= -r_{str} \cdot i_0 + \frac{1}{\omega_n} \cdot \frac{d\psi_0}{dt}\end{aligned}\tag{150}$$

where  $n$  is the speed of the rotor and  $\omega_n = 2 \cdot \pi \cdot f_{nom}$  is the nominal angular frequency.

The rest of the GENQEC model equations are equal as for the EMT model

For the EMT simulation, the neutral and zero sequence equations that have to be satisfied are the same as in Section 6.1.2.2.

### 6.2.2.3 Mechanical Equations, Rotor Angles and Delta Speed Input Signal

The mechanical equations, together with the definitions for mechanical torque, damping torque and acceleration time constant is described in Section 6.1.2.3.

The rotor angle definitions are identical to the definitions presented in Section 6.1.3.

The functionality of the delta speed input signal  $dw$  is given in Section 6.1.6.

### 6.2.3 Saturation

In the GENQEC model, the saturation is applied to the magnetizing reactance and to the rotor reactances.

Internally a saturation factor  $c_{sat}$  is calculated (which corresponds to  $S_a$  in [12]) and from there the saturation factors  $sat_d$  and  $sat_q$  are calculated. In [12], the same factor is used for the saturation in the d- and q-axis. In *PowerFactory* this option is available, but also other options can be used to apply the saturation.

The available options are described in Section 6.1.4. Please note that the saturation is not applied through  $x_{ad}$  and  $x_{aq}$ , but the saturation is applied directly in the equations of the GENQEC model. In the GENQEC model  $x_{ad}$  and  $x_{aq}$  are the unsaturated values.

### 6.2.4 Excitation system interfacing

The GENQEC excitation current output signal  $i_e$  and the excitation voltage input signal  $v_e$  are already in the non-reciprocal system and therefore can be used directly for interfacing with the excitation system.

Refer to Section 6.1.5 for more information. Please note that for the GENQEC model, the current  $i_e$  is calculated according to equation 145.

### 6.2.5 Integrated AVR for Motor Starting

Refer to Section 6.1.7.

### 6.2.6 Inputs/Outputs/State Variables of the Dynamic Model

#### 6.2.6.1 Stability Model (RMS)

Table 6.11: Input Definition of the RMS-Model

| Input Signal | Symbol    | Description                                    | Unit |
|--------------|-----------|------------------------------------------------|------|
| ve           | $v_e$     | Excitation voltage                             | p.u. |
| pt           |           | Turbine power                                  | p.u. |
| xmdm         |           | Torque input                                   | p.u. |
| fref         | $f_{ref}$ | Reference frequency                            | p.u. |
| freflocal    |           | Reference frequency of local reference machine | p.u. |
| dw           |           | Delta speed                                    | p.u. |

Table 6.12: State Variables Definition of the RMS-Model

| Parameter | Symbol      | Description                       | Unit |
|-----------|-------------|-----------------------------------|------|
| psifd     | $\psi_{fd}$ | Excitation flux                   | p.u. |
| psi1d     | $\psi_{1d}$ | Flux in 1d-damper winding, d-axis | p.u. |
| psi1q     | $\psi_{1q}$ | Flux in 1q-damper winding, q-axis | p.u. |
| psi2q     | $\psi_{2q}$ | Flux in 2q-damper winding, q-axis | p.u. |
| speed     | $n$         | Speed                             | p.u. |
| phi       | $\varphi$   | Rotor position angle              | rad  |

Table 6.13: Output Definition of the RMS-Model

| Parameter | Symbol  | Description                                                                  | Unit |
|-----------|---------|------------------------------------------------------------------------------|------|
| ut        | $u_t$   | Terminal Voltage                                                             | p.u. |
| utr       |         | Terminal Voltage, Real Part                                                  | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                                             | p.u. |
| pgt       |         | Electrical Power (based on rated active power)                               | p.u. |
| ie        | $i_e$   | Excitation Current (in non-reciprocal p.u. system)                           | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                                                 | rad  |
| xspeed    |         | Speed ( $xspeed = speed$ )                                                   | p.u. |
| xme       | $t_e$   | Electrical Torque                                                            | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                                            | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude                                         | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part                                         | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part                                    | p.u. |
| P1        |         | Positive-Sequence, Active Power                                              | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                                            | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                                           | p.u. |
| outofstep |         | Out of step (pole slip) is "1" if generator is out of step and "0" otherwise |      |

## 6.2.6.2 EMT-Model

Table 6.14: Input Definition of the EMT-Model

| Input Signal | Symbol | Description        | Unit |
|--------------|--------|--------------------|------|
| ve           | $v_e$  | Excitation Voltage | p.u. |
| pt           |        | Turbine Power      | p.u. |
| xmdm         |        | Torque Input       | p.u. |
| dw           |        | Delta speed        | p.u. |

Table 6.15: State Variables Definition of the EMT-Model

| Parameter | Symbol      | Description                                      | Unit |
|-----------|-------------|--------------------------------------------------|------|
| psifd     | $\psi_{fd}$ | Excitation flux                                  | p.u. |
| psi1d     | $\psi_{1d}$ | Flux in 1d-damper winding, d-axis                | p.u. |
| psi1q     | $\psi_{1q}$ | Flux in 1q-damper winding, q-axis                | p.u. |
| psi2q     | $\psi_{2q}$ | Flux in 2q-damper winding, q-axis                | p.u. |
| psid      | $\psi_d$    | Stator flux, d-axis - only if saturation is used | p.u. |
| psiq      | $\psi_q$    | Stator flux, q-axis - only if saturation is used | p.u. |
| speed     | $n$         | Speed                                            | p.u. |
| phi       | $\varphi$   | Rotor position angle                             | rad  |

Table 6.16: Output Definition of the EMT-Model

| Parameter | Symbol  | Description                                        | Unit |
|-----------|---------|----------------------------------------------------|------|
| ut        | $u_t$   | Terminal Voltage                                   | p.u. |
| utr       |         | Terminal Voltage, Real Part                        | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                   | p.u. |
| pgt       |         | Electrical Power (based on rated active power)     | p.u. |
| ie        | $i_e$   | Excitation Current (in non-reciprocal p.u. system) | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                       | rad  |
| xspeed    | $n$     | Speed ( $xspeed = speed$ )                         | p.u. |
| xme       | $t_e$   | Electrical Torque                                  | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                  | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude               | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part               | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part          | p.u. |
| P1        |         | Positive-Sequence, Active Power                    | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                  | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                 | p.u. |

### 6.3 Model 3.3

The 3.3 model is a more detailed model compared to the *PowerFactory* standard model. It requires more input data and can be used for more detailed studies. In this case, the EMT model is to be preferred since there are no simplifications done as in the RMS model.

The rotor d-axis is modelled by three rotor loops representing the excitation and two damper windings. The rotor q-axis is also modelled with three rotor loops. According to the designation in [8], this model is referred to as 3.3 model. The model is based on [8] and [4]. Using high values for the impedance of certain branches, models with varying degrees of complexity can be simulated.

Figure 6.9 and Figure 6.10 show the equivalent circuit diagrams of the *PowerFactory* synchronous machine model 3.3, which is represented in a rotor reference system (Park coordinates, dq-reference frame).




Figure 6.9: d-axis equivalent circuit




Figure 6.10: q-axis equivalent circuit

#### 6.3.1 Input parameters and conversion

The 3.3 model can be used with operational reactances data as given in Table 6.17 or with equivalent circuit data (model parameters) as given in Table 6.18. Internally the model works with the equivalent circuit data. If operational reactances data is used, the data is converted to equivalent circuit data according to the conversion presented in [8].

Table 6.17: Input data from operational reactances

| Name in PF               | Symbol    | Unit | Description                            |
|--------------------------|-----------|------|----------------------------------------|
| $r_{str}$                | $r_{str}$ | p.u. | Stator resistance                      |
| $x_l$                    | $x_l$     | p.u. | Stator leakage reactance               |
| $x_{ad}$                 | $x_{ad}$  | p.u. | Mutual (magnetising) reactance, d-axis |
| $x_{aq}$                 | $x_{aq}$  | p.u. | Mutual (magnetising) reactance, q-axis |
| $t_{1d}, t_{2d}, t_{3d}$ |           | s    | Time constants d-axis                  |
| $t_{4d}, t_{5d}, t_{6d}$ |           | s    | Time constants d-axis                  |
| $t_{7d}, t_{8d}$         |           | s    | Time constants d-axis                  |
| $t_{1q}, t_{2q}, t_{3q}$ |           | s    | Time constants q-axis                  |
| $t_{4q}, t_{5q}, t_{6q}$ |           | s    | Time constants q-axis                  |

Table 6.18: Model parameters of the model 3.3 synchronous machine

| Name in PF | Symbol     | Unit | Description                                            |
|------------|------------|------|--------------------------------------------------------|
| $r_{str}$  | $r_{str}$  | p.u. | Stator resistance                                      |
| $x_l$      | $x_l$      | p.u. | Stator leakage reactance                               |
| $x_{ad}$   | $x_{ad}$   | p.u. | Mutual (magnetising) reactance, d-axis                 |
| $x_{aq}$   | $x_{aq}$   | p.u. | Mutual (magnetising) reactance, q-axis                 |
| $x_{rl}$   | $x_{rld}$  | p.u. | Coupling reactance of all d-axis rotor circuits        |
| $x_{rl2d}$ | $x_{rl2d}$ | p.u. | Coupling reactance between field and 2d damper winding |
| $x_{1d}$   | $x_{1d}$   | p.u. | Reactance of 1d-damper winding (d-axis)                |
| $r_{1d}$   | $r_{1d}$   | p.u. | Resistance of 1d-damper winding (d-axis)               |
| $x_{2d}$   | $x_{2d}$   | p.u. | Reactance of 2d-damper winding (d-axis)                |
| $r_{2d}$   | $r_{2d}$   | p.u. | Resistance of 2d-damper winding (d-axis)               |
| $x_{fd}$   | $x_{fd}$   | p.u. | Reactance of field winding (d-axis)                    |
| $r_{fd}$   | $r_{fd}$   | p.u. | Resistance of field winding (d-axis)                   |
| $x_{1q}$   | $x_{1q}$   | p.u. | Reactance of 1q-damper winding (q-axis)                |
| $r_{1q}$   | $r_{1q}$   | p.u. | Resistance of 1q-damper winding (q-axis)               |
| $x_{2q}$   | $x_{2q}$   | p.u. | Reactance of 2q-damper winding (q-axis)                |
| $r_{2q}$   | $r_{2q}$   | p.u. | Resistance of 2q-damper winding (q-axis)               |
| $x_{3q}$   | $x_{3q}$   | p.u. | Reactance of 3q-damper winding (q-axis)                |
| $r_{3q}$   | $r_{3q}$   | p.u. | Resistance of 3q-damper winding (q-axis)               |

The synchronous reactances can be obtained as follows:

$$\begin{aligned} x_d &= x_l + x_{ad} \\ x_q &= x_l + x_{aq} \end{aligned} \quad (151)$$

### 6.3.2 Model equations

The rotor variables are referred to the stator windings and the equations are written using the rotor reference frame in generator orientation.

In the case of balanced RMS simulation, the available simulated values are positive sequence complex values. In the case of unbalanced RMS simulation, the available complex phase values for currents and voltages are first transformed into symmetrical components. For transforming to the dq-reference frame, the variables are shifted by multiplying with the transformation  $\cos \varphi - j \cdot \sin \varphi$ . The voltages and currents available from the EMT simulation are first transformed from instantaneous values in the  $\alpha\beta\gamma$  system using the Clarke transformation. The same transformation as above is used for transforming to the dq rotating reference frame.



The differential equations can be derived based on the equivalent circuit diagrams according to Figure 6.9 to Figure 6.10.

The *PowerFactory* synchronous machine model for RMS simulations uses the rotor currents, magnetisation fluxes, the speed  $n$  and the angle  $\varphi$  as state variables. The EMT model uses two more state variables (stator fluxes  $\psi_d$  and  $\psi_q$ ).

The stator voltage equations can be described as follows:

$$\begin{aligned} u_d &= -r_{str} \cdot i_d - n \cdot \psi_q + \frac{1}{\omega_n} \cdot \frac{d\psi_d}{dt} \\ u_q &= -r_{str} \cdot i_q + n \cdot \psi_d + \frac{1}{\omega_n} \cdot \frac{d\psi_q}{dt} \\ u_0 &= -r_{str} \cdot i_0 + \frac{1}{\omega_n} \cdot \frac{d\psi_0}{dt} \end{aligned} \quad (152)$$

where  $n$  is the speed of the rotor and  $\omega_n = 2 \cdot \pi \cdot f_{nom}$  is the nominal angular frequency.

The rotor voltage equations for the d-axis and q-axis have the following form:

$$\begin{aligned} 0 &= r_{1d} \cdot i_{1d} + \frac{1}{\omega_n} \cdot \frac{d\psi_{1d}}{dt} \\ 0 &= r_{2d} \cdot i_{2d} + \frac{1}{\omega_n} \cdot \frac{d\psi_{2d}}{dt} \\ v_{fd} &= i_{fd} \cdot r_{fd} + \frac{1}{\omega_n} \cdot \frac{d\psi_{fd}}{dt} \end{aligned} \quad (153)$$

$$\begin{aligned} 0 &= r_{1q} \cdot i_{1q} + \frac{1}{\omega_n} \cdot \frac{d\psi_{1q}}{dt} \\ 0 &= r_{2q} \cdot i_{2q} + \frac{1}{\omega_n} \cdot \frac{d\psi_{2q}}{dt} \\ 0 &= r_{3q} \cdot i_{3q} + \frac{1}{\omega_n} \cdot \frac{d\psi_{3q}}{dt} \end{aligned} \quad (154)$$

For completing the model, the stator and rotor flux linkage equations in the d- and q-axis are required:

$$\begin{aligned} \psi_d &= -(x_l + x_{ad}) \cdot i_d + x_{ad} \cdot i_{1d} + x_{ad} \cdot i_{2d} + x_{ad} \cdot i_{fd} = \psi_{ad} - x_l \cdot i_d \\ \psi_q &= -(x_l + x_{aq}) \cdot i_q + x_{aq} \cdot i_{1q} + x_{aq} \cdot i_{2q} + x_{aq} \cdot i_{3q} = \psi_{aq} - x_l \cdot i_q \end{aligned} \quad (155)$$

$$\begin{aligned} \psi_{1d} &= \psi_{ad} + (x_{rl1d} + x_{1d}) \cdot i_{1d} + x_{rl1d} \cdot i_{2d} + x_{rl1d} \cdot i_{fd} \\ \psi_{2d} &= \psi_{ad} + x_{rl1d} \cdot i_{1d} + (x_{rl1d} + x_{rl2d} + x_{2d}) \cdot i_{2d} + (x_{rl1d} + x_{rl2d}) \cdot i_{fd} \\ \psi_{fd} &= \psi_{ad} + x_{rl1d} \cdot i_{1d} + (x_{rl1d} + x_{rl2d}) \cdot i_{2d} + (x_{rl1d} + x_{rl2d} + x_{fd}) \cdot i_{fd} \end{aligned} \quad (156)$$

$$\begin{aligned} \psi_{1q} &= \psi_{aq} + x_{1q} \cdot i_{1q} \\ \psi_{2q} &= \psi_{aq} + x_{2q} \cdot i_{2q} \\ \psi_{3q} &= \psi_{aq} + x_{3q} \cdot i_{3q} \end{aligned} \quad (157)$$

where  $\psi_{ad}$  and  $\psi_{aq}$  are the d- and q-axis components of the magnetising flux:

$$\begin{aligned} \psi_{ad} &= x_{ad} \cdot (-i_d + i_{1d} + i_{2d} + i_{fd}) \\ \psi_{aq} &= x_{aq} \cdot (-i_q + i_{1q} + i_{2q} + i_{3q}) \end{aligned} \quad (158)$$

The electrical torque is calculated using the stator currents and stator fluxes and the rated power factor  $\cos n$ :

$$t_e = \frac{i_q \cdot \psi_d - i_d \cdot \psi_q}{\cos n} \quad \text{p.u.} \quad (159)$$

### 6.3.2.1 Equations for the RMS model

The equations from Section 6.3.2 are used for the RMS model where several simplifications have been made for the stator voltage equations.

The stator dynamics are relatively fast for stability studies. Therefore, for RMS-simulations, the derivatives of the stator quantities are not considered in the equations. Taking into account this simplification, the stator voltage Equations 152 can be written as:

$$\begin{aligned} u_d &= -r_{str} \cdot i_d - n \cdot \psi_q \\ u_q &= -r_{str} \cdot i_q + n \cdot \psi_d \end{aligned} \quad (160)$$

Similar as in the standard *PowerFactory* RMS model, additional simplification can be made to the model by modifying the effect of the speed variation on the stator voltages (option located on the *Advanced* tab of the *RMS-Simulation* page of the *TypSym* edit dialog). Depending on the option selected, Equation 160 is modified as follows:

- Effect of speed variation considered

The equations have the form as already presented and the speed is considered in the equations.

- Effect of speed variation neglected

The speed is set equal to the initial speed in both equations. It is assumed that the speed changes are small and they don't have a big effect on the stator voltage [3]. The model is then valid for speed deviations around initial speed.

The option *Considered* should not be used for direct motor starting applications since during starting there is a big difference between the speed of the machine and the network frequency. The simulated results without this option are similar to the results of the EMT model. For motor starting applications including variable speed drives the speed effect variation option should be considered.

For studies where the torque is of true interest, the EMT model is more appropriate.

In the case of unbalanced RMS simulation the same neutral, zero and negative sequence equations have to be satisfied as in Section 6.1.2.1.

For the unbalanced RMS simulation, the model 3.3 takes into account also a negative sequence torque into the equation of motion (Equation 100). The negative sequence torque is calculated as:

$$t_{e2} = \frac{(r_{2sy} - r_{str}) \cdot i_2^2}{\cos n} \quad \text{p.u.} \quad (161)$$

The positive sequence torque  $t_{e1}$  is calculated according to Equation 159. The total electrical torque  $t_e$  is the sum of the positive and negative sequence torques:

$$t_e = t_{e1} + t_{e2} \quad \text{p.u.} \quad (162)$$

### 6.3.2.2 Equations for the EMT model

For the EMT model, there are no changes made to the equations presented in Section 6.3.2.

For the EMT simulation, the neutral and zero sequence equations that have to be satisfied are the same as in Section 6.1.2.2.

### 6.3.2.3 Mechanical Equations, Rotor Angles and Delta Speed Input Signal

The mechanical equations, together with the definitions for mechanical torque, damping torque and acceleration time constant is described in Section 6.1.2.3.

The rotor angle definitions are identical to the definitions presented in Section 6.1.3.

The functionality of the delta speed input signal  $dw$  is given in Section 6.1.6.

### 6.3.3 Saturation

The model described so far is a purely linear model not considering any saturation effects. Generally, there exists saturation for all reactances of the synchronous machine model. However, for the purpose of system analysis, main flux saturation can be considered in the model by considering saturation of the mutual (magnetising) reactances  $x_{ad}$  and  $x_{aq}$ .

The main-flux saturation and the available options are identical to what is described in Section 6.1.4.

The saturation of stator leakage reactance is a current-dependent saturation, i.e. high currents after short-circuits will lead to a saturation effect of the leakage reactance. The modelling of the current dependency of the stator leakage reactance is supported by the Model 3.3 synchronous machine in *PowerFactory*. The data can be entered using tabular input of point-pairs of current and reactance. The data is then transformed to a smoothed curve with a piece-wise linear function using the dependency curve smoothing factor.

On every simulation step the stator reactance is determined from the curve for a specific value of the magnitude of the dq-stator current (zero sequence current is neglected):

$$x_l = x_{l\_curve} \left( \sqrt{i_d^2 + i_q^2} \right) \quad (163)$$

### 6.3.4 Excitation system interfacing

Refer to Section 6.1.5.

### 6.3.5 Integrated AVR for Motor Starting

Refer to Section 6.1.7.

### 6.3.6 Inputs/Outputs/State Variables of the Dynamic Model

#### 6.3.6.1 Stability Model (RMS)

Table 6.19: Input Definition of the RMS-Model

| Input Signal | Symbol    | Description                                    | Unit |
|--------------|-----------|------------------------------------------------|------|
| ve           | $v_e$     | Excitation voltage                             | p.u. |
| pt           |           | Turbine power                                  | p.u. |
| xmdm         |           | Torque input                                   | p.u. |
| fref         | $f_{ref}$ | Reference frequency                            | p.u. |
| freflocal    |           | Reference frequency of local reference machine | p.u. |
| dw           |           | Delta speed                                    | p.u. |

Table 6.20: State Variables Definition of the RMS-Model

| Parameter | Symbol      | Description                                        | Unit |
|-----------|-------------|----------------------------------------------------|------|
| i1d       | $i_{1d}$    | Current in 1d-damper winding, d-axis               | p.u. |
| i2d       | $i_{2d}$    | Current in 2d-damper winding, d-axis               | p.u. |
| ifd       | $i_{fd}$    | Current in field winding (excitation flux), d-axis | p.u. |
| i1q       | $i_{1q}$    | Current in 1q-damper winding, q-axis               | p.u. |
| i2q       | $i_{2q}$    | Current in 2q-damper winding, q-axis               | p.u. |
| i3q       | $i_{3q}$    | Current in 3q-damper winding, q-axis               | p.u. |
| psiad     | $\psi_{ad}$ | Magnetisation flux, d-axis                         | p.u. |
| psiaq     | $\psi_{aq}$ | Magnetisation flux, q-axis                         | p.u. |
| speed     | $n$         | Speed                                              | p.u. |
| phi       | $\varphi$   | Rotor position angle                               | rad  |

Table 6.21: Output Definition of the RMS-Model

| Parameter | Symbol  | Description                                                                  | Unit |
|-----------|---------|------------------------------------------------------------------------------|------|
| ut        | $u_t$   | Terminal Voltage                                                             | p.u. |
| utr       |         | Terminal Voltage, Real Part                                                  | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                                             | p.u. |
| pgt       |         | Electrical Power (based on rated active power)                               | p.u. |
| ie        | $i_e$   | Excitation Current (in non-reciprocal p.u. system)                           | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                                                 | rad  |
| xspeed    |         | Speed ( $xspeed = speed$ )                                                   | p.u. |
| xme       | $t_e$   | Electrical Torque                                                            | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                                            | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude                                         | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part                                         | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part                                    | p.u. |
| P1        |         | Positive-Sequence, Active Power                                              | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                                            | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                                           | p.u. |
| outofstep |         | Out of step (pole slip) is "1" if generator is out of step and "0" otherwise |      |

## 6.3.6.2 EMT-Model

Table 6.22: Input Definition of the EMT-Model

| Input Signal | Symbol | Description        | Unit |
|--------------|--------|--------------------|------|
| ve           | $v_e$  | Excitation Voltage | p.u. |
| pt           |        | Turbine Power      | p.u. |
| xmdm         |        | Torque Input       | p.u. |
| dw           |        | Delta speed        | p.u. |

Table 6.23: State Variables Definition of the EMT-Model

| Parameter | Symbol      | Description                                        | Unit |
|-----------|-------------|----------------------------------------------------|------|
| i1d       | $i_{1d}$    | Current in 1d-damper winding, d-axis               | p.u. |
| i2d       | $i_{2d}$    | Current in 2d-damper winding, d-axis               | p.u. |
| ifd       | $i_{fd}$    | Current in field winding (excitation flux), d-axis | p.u. |
| i1q       | $i_{1q}$    | Current in 1q-damper winding, q-axis               | p.u. |
| i2q       | $i_{2q}$    | Current in 2q-damper winding, q-axis               | p.u. |
| i3q       | $i_{3q}$    | Current in 3q-damper winding, q-axis               | p.u. |
| psiad     | $\psi_{ad}$ | Magnetisation flux, d-axis                         | p.u. |
| psiaq     | $\psi_{aq}$ | Magnetisation flux, q-axis                         | p.u. |
| psid      | $\psi_d$    | Stator flux, d-axis                                | p.u. |
| psiq      | $\psi_q$    | Stator flux, q-axis                                | p.u. |
| speed     | $n$         | Speed                                              | p.u. |
| phi       | $\varphi$   | Rotor position angle                               | rad  |

Table 6.24: Output Definition of the EMT-Model

| Parameter | Symbol  | Description                                        | Unit |
|-----------|---------|----------------------------------------------------|------|
| ut        | $u_t$   | Terminal Voltage                                   | p.u. |
| utr       |         | Terminal Voltage, Real Part                        | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                   | p.u. |
| pgt       |         | Electrical Power (based on rated active power)     | p.u. |
| ie        | $i_e$   | Excitation Current (in non-reciprocal p.u. system) | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                       | rad  |
| xspeed    | $n$     | Speed ( $xspeed = speed$ )                         | p.u. |
| xme       | $t_e$   | Electrical Torque                                  | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                  | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude               | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part               | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part          | p.u. |
| P1        |         | Positive-Sequence, Active Power                    | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                  | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                 | p.u. |

## 6.4 Permanent magnet model

The permanent magnet synchronous machine model in *PowerFactory* has been implemented according to [1].

The model represents a three-phase permanent magnet machine having a sinusoidal flux distribution.

When modelling a machine with a round or with a salient rotor, both reactances  $L_d$  and  $L_q$  need to be entered. In the case of the round rotor they are equal ( $L_d = L_q$ ). In addition to these parameters also the amplitude of the magnetic flux linkage  $\psi_m$  of the permanent magnet needs to be specified.

Please refer to appendix A for base values calculations. No other electrical parameters are needed since the model does not require damper windings.

### 6.4.1 Equations for the RMS model

The stator dynamics are relatively fast for stability studies. Therefore, for RMS-simulations, the derivatives of the stator quantities are not considered in the equations:

$$u_d = -r_{str} \cdot i_d + n \cdot x_q \cdot i_q \quad (164)$$

$$u_q = -r_{str} \cdot i_q - n \cdot x_d \cdot i_d + n \cdot \psi_m \quad (165)$$

In the case of unbalanced RMS simulation the same neutral, zero and negative sequence equations have to be satisfied as in Section 6.1.2.1.

The electrical torque is calculated using the rated power factor  $\cos n$  as:

$$t_e = -(-\psi_m \cdot i_q + (x_d - x_q) \cdot i_d \cdot i_q) / \cos n \quad (166)$$

The other mechanical equations are identical to the equations of the detailed synchronous machine presented in Section 6.1.2.3. The model uses only two state variables:

- the speed of the machine  $n$  in p.u.;
- the angle  $\varphi$  in rad which is initialised as in Equation 116.

### 6.4.2 Equations for the EMT model

In addition to the two state variables used in the RMS model, the EMT model uses two more state variables for the currents. The following equations need to be satisfied:

$$u_d = -r_{str} \cdot i_d + n \cdot x_q \cdot i_q - x_d \cdot \frac{1}{\omega_n} \cdot \frac{di_d}{dt} \quad (167)$$

$$u_q = -r_{str} \cdot i_q - n \cdot x_d \cdot i_d + n \cdot \psi_m - x_q \cdot \frac{1}{\omega_n} \cdot \frac{di_q}{dt} \quad (168)$$

The electrical torque is calculated exactly same as for the RMS model.

The neutral and zero sequence equations that need to be satisfied are the same as in Section 6.1.2.2.

The mechanical equations are identical to the equations of the detailed synchronous machine presented in Section 6.1.2.3.

### 6.4.3 Inputs/Outputs/State Variables of the Dynamic Model

#### 6.4.3.1 Stability Model (RMS)

Table 6.25: Input Definition of the RMS-Model

| Input Signal | Symbol    | Description                                    | Unit |
|--------------|-----------|------------------------------------------------|------|
| pt           |           | Turbine power                                  | p.u. |
| xmdm         |           | Torque input                                   | p.u. |
| fref         | $f_{ref}$ | Reference frequency                            | p.u. |
| freflocal    |           | Reference frequency of local reference machine | p.u. |

Table 6.26: State Variables Definition of the RMS-Model

| Parameter | Symbol    | Description          | Unit |
|-----------|-----------|----------------------|------|
| speed     | $n$       | Speed                | p.u. |
| phi       | $\varphi$ | Rotor position angle | rad  |

Table 6.27: Output Definition of the RMS-Model

| Parameter | Symbol  | Description                                                                  | Unit |
|-----------|---------|------------------------------------------------------------------------------|------|
| ut        | $ u_t $ | Terminal Voltage, Magnitude                                                  | p.u. |
| utr       |         | Terminal Voltage, Real Part                                                  | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                                             | p.u. |
| pgt       |         | Electrical Power (based on rated active power)                               | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                                                 | rad  |
| xspeed    |         | Speed ( $xspeed = speed$ )                                                   | p.u. |
| xme       | $t_e$   | Electrical Torque                                                            | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                                            | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude                                         | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part                                         | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part                                    | p.u. |
| P1        |         | Positive-Sequence, Active Power                                              | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                                            | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                                           | p.u. |
| outofstep |         | Out of step (pole slip) is "1" if generator is out of step and "0" otherwise |      |

#### 6.4.3.2 EMT-Model

Table 6.28: Input Definition of the EMT-Model

| Input Signal | Symbol | Description   | Unit |
|--------------|--------|---------------|------|
| pt           |        | Turbine power | p.u. |
| xmdm         |        | Torque input  | p.u. |

Table 6.29: State Variables Definition of the EMT-Model

| Parameter | Symbol    | Description           | Unit |
|-----------|-----------|-----------------------|------|
| id        | $i_d$     | Stator current d-axis | p.u. |
| iq        | $i_q$     | Stator current q-axis | p.u. |
| speed     | $n$       | Speed                 | p.u. |
| phi       | $\varphi$ | Rotor position angle  | rad  |

Table 6.30: Output Definition of the EMT-Model

| Parameter | Symbol  | Description                                    | Unit |
|-----------|---------|------------------------------------------------|------|
| ut        | $ u_t $ | Terminal Voltage, Magnitude                    | p.u. |
| utr       |         | Terminal Voltage, Real Part                    | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part               | p.u. |
| pgt       |         | Electrical Power (based on rated active power) | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                   | rad  |
| xspeed    | $n$     | Speed ( $xspeed = speed$ )                     | p.u. |
| xme       | $t_e$   | Electrical Torque                              | p.u. |
| xmt       | $t_m$   | Mechanical Torque                              | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude           | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part           | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part      | p.u. |
| P1        |         | Positive-Sequence, Active Power                | MW   |
| Q1        |         | Positive-Sequence, Reactive Power              | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )             | p.u. |



## 6.5 Classical Model

In comparison with the detailed model explained in Section 6.1, the classical model is a simplified model represented by a voltage behind an impedance. The equivalent circuit diagram is shown in Figure 6.11.




Figure 6.11: Classical model equivalent circuit

The classical synchronous machine model can be used for representing equivalents of parts of a system that are not represented in detail or for not so important machines.

The classical model normally refers to a model with a constant voltage (constant emf) behind a transient impedance. In the case of *PowerFactory*, the constant voltage is  $v_e$  which is automatically initialised and the transient impedance is  $z' = r_{str} + j x_{str}$ . If  $r_{str} = 0$ , the model becomes a lossless model.

If required, it is possible to vary the voltage  $v_e$  by a DSL model.

The definitions of the rotor angles is the same as presented in Section 6.1.3.

Since it is a simplified model saturation is not taken into account.

### 6.5.1 Equations for the RMS model

The voltage equation that needs to be satisfied for the RMS simulation is:

$$\underline{u}_t = -(r_{str} + j x_{str}) \cdot \underline{i}_t + (v_e \cdot n) \angle \varphi \quad (169)$$

where the amplitude of  $v_e$  is initialised as:

$$v_e = \sqrt{(\underline{u}_t + (r_{str} + j x_{str}) \cdot \underline{i}_t)^2} \quad (170)$$

The stator flux is calculated as:

$$\underline{\psi}_{str} = (\underline{u}_t + r_{str} \cdot \underline{i}_t) / j n \quad (171)$$

Similar as in the standard *PowerFactory* RMS model, there is an option to neglect the rotor speed variation ( $n = 1 p.u.$ ) in the voltage equation and when calculating the stator flux (the option is located on the *Advanced* tab of the *RMS-Simulation* page of the *TypSym* edit dialogue).

In the case of unbalanced RMS simulation the same neutral, zero and negative sequence equations have to be satisfied as in Section 6.1.2.1.

The electrical torque is calculated using the stator current and stator flux and the rated power factor  $\cos n$ :

$$t_e = \frac{\Im(\underline{i}_t) \cdot \Re(\underline{\psi}_{str}) - \Re(\underline{i}_t) \cdot \Im(\underline{\psi}_{str})}{\cos n} \quad \text{p.u.} \quad (172)$$

The other mechanical equations are identical to the equations of the detailed synchronous machine presented in Section 6.1.2.3. The model uses only two state variables:

- the speed of the machine  $n$  in p.u.;
- the angle  $\varphi$  in rad which is initialised as in Equation 116 where  $x_q$  is replaced by  $x_{str}$ .

### 6.5.2 Equations for the EMT model

In addition to the two state variables used in the RMS model, the EMT model uses two more state variables for the stator flux. The following equations need to be satisfied:

$$\begin{aligned}\psi_d &= v_e \angle \varphi_q - x_{str} \cdot i_d \\ \psi_q &= -v_e \angle \varphi_d - x_{str} \cdot i_q\end{aligned}\tag{173}$$

$$\begin{aligned}u_d &= -r_{str} \cdot i_d - \psi_q + \frac{1}{\omega_n} \cdot \frac{d\psi_d}{dt} \\ u_q &= -r_{str} \cdot i_q + \psi_d + \frac{1}{\omega_n} \cdot \frac{d\psi_q}{dt}\end{aligned}\tag{174}$$

where the amplitude of  $v_e \angle \varphi_d$  and  $v_e \angle \varphi_q$  are the d and q component of  $v_e$  (calculated as in 170).

For the EMT model it is considered that the rotor speed variation is small and therefore it is neglected ( $n = 1$  p.u. in equation 174).

In addition to the above, the neutral and zero sequence equations that need to be satisfied are the same as in Section 6.1.2.2.

The mechanical equations are identical to the equations of the detailed synchronous machine presented in Section 6.1.2.3.

### 6.5.3 Integrated AVR for Motor Starting

The classical model does not support the integrated AVR for motor starting.

### 6.5.4 Inputs/Outputs/State Variables of the Dynamic Model

#### 6.5.4.1 Stability Model (RMS)

Table 6.31: Input Definition of the RMS-Model

| Input Signal | Symbol    | Description                                                 | Unit |
|--------------|-----------|-------------------------------------------------------------|------|
| ve           | $v_e$     | Excitation voltage (const. voltage for the classical model) | p.u. |
| pt           |           | Turbine power                                               | p.u. |
| xmdm         |           | Torque input                                                | p.u. |
| fref         | $f_{ref}$ | Reference frequency                                         | p.u. |
| freflocal    |           | Reference frequency of local reference machine              | p.u. |

Table 6.32: State Variables Definition of the RMS-Model

| Parameter | Symbol    | Description          | Unit |
|-----------|-----------|----------------------|------|
| speed     | $n$       | Speed                | p.u. |
| phi       | $\varphi$ | Rotor position angle | rad  |

Table 6.33: Output Definition of the RMS-Model

| Parameter | Symbol  | Description                                                                  | Unit |
|-----------|---------|------------------------------------------------------------------------------|------|
| ut        | $ u_t $ | Terminal Voltage, Magnitude                                                  | p.u. |
| utr       |         | Terminal Voltage, Real Part                                                  | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                                             | p.u. |
| pgt       |         | Electrical Power (based on rated active power)                               | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                                                 | rad  |
| xspeed    |         | Speed ( $xspeed = speed$ )                                                   | p.u. |
| xme       | $t_e$   | Electrical Torque                                                            | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                                            | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude                                         | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part                                         | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part                                    | p.u. |
| P1        |         | Positive-Sequence, Active Power                                              | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                                            | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                                           | p.u. |
| outofstep |         | Out of step (pole slip) is "1" if generator is out of step and "0" otherwise |      |

#### 6.5.4.2 EMT-Model

Table 6.34: Input Definition of the EMT-Model

| Input Signal | Symbol | Description                                                 | Unit |
|--------------|--------|-------------------------------------------------------------|------|
| ve           | $v_e$  | Excitation voltage (const. voltage for the classical model) | p.u. |
| pt           |        | Turbine power                                               | p.u. |
| xmdm         |        | Torque input                                                | p.u. |

Table 6.35: State Variables Definition of the EMT-Model

| Parameter | Symbol    | Description          | Unit |
|-----------|-----------|----------------------|------|
| psid      | $\psi_d$  | Stator flux d-axis   | p.u. |
| psiq      | $\psi_q$  | Stator flux q-axis   | p.u. |
| speed     | $n$       | Speed                | p.u. |
| phi       | $\varphi$ | Rotor position angle | rad  |

Table 6.36: Output Definition of the EMT-Model

| Parameter | Symbol  | Description                                    | Unit |
|-----------|---------|------------------------------------------------|------|
| ut        | $ u_t $ | Terminal Voltage, Magnitude                    | p.u. |
| utr       |         | Terminal Voltage, Real Part                    | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part               | p.u. |
| pgt       |         | Electrical Power (based on rated active power) | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                   | rad  |
| xspeed    | n       | Speed ( $xspeed = speed$ )                     | p.u. |
| xme       | $t_e$   | Electrical Torque                              | p.u. |
| xmt       | $t_m$   | Mechanical Torque                              | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude           | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part           | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part      | p.u. |
| P1        |         | Positive-Sequence, Active Power                | MW   |
| Q1        |         | Positive-Sequence, Reactive Power              | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )             | p.u. |

## 6.6 Asynchronous starting model

Compared to the 2.1 model (standard salient machine model), this model requires more input data because it contains additional impedance branches. The parameters of these branches are dependent of the square root of the slip and represent eddy-current effects of solid rotor. This model is suitable for motor starting simulations. For detailed analysis the EMT model is to be preferred since there are no simplification done as in the RMS model. For example, in studies where the torque is of true interest, the EMT model is more appropriate.

This model is based on [13]. More information can be found in [14], [15], [16]. In opposite to [13], where  $\alpha$  dictates the imaginary part components of the eddy-current resistances, in *PowerFactory* the real and imaginary parts are to be entered directly. The parameters  $x_{1de}$ ,  $r_{1de}$ ,  $x_{fde}$ ,  $r_{fde}$ ,  $x_{1qe}$  and  $r_{1qe}$  are all dependent of  $\sqrt{\text{slip}}$ .

Figure 6.12 and Figure 6.13 show the equivalent circuit diagrams of the *PowerFactory* synchronous machine model representing eddy-current effects of solid rotor, written in a rotor reference system (Park coordinates, dq-reference frame).




Figure 6.12: d-axis equivalent circuit




Figure 6.13: q-axis equivalent circuit

### 6.6.1 Input parameters

The model representing eddy-current effects can be used only with with equivalent circuit data (model parameters) as given in Table 6.37.

Table 6.37: Model parameters of the model 3.3 synchronous machine

| Name in PF | Symbol    | Unit | Description                                                                       |
|------------|-----------|------|-----------------------------------------------------------------------------------|
| $r_{str}$  | $r_{str}$ | p.u. | Stator resistance                                                                 |
| $x_l$      | $x_l$     | p.u. | Stator leakage reactance                                                          |
| $x_{ad}$   | $x_{ad}$  | p.u. | Mutual (magnetising) reactance, d-axis                                            |
| $x_{aq}$   | $x_{aq}$  | p.u. | Mutual (magnetising) reactance, q-axis                                            |
| $x_{rl}$   | $x_{rld}$ | p.u. | Coupling reactance of all d-axis rotor circuits                                   |
| $x_{1dc}$  | $x_{1dc}$ | p.u. | Coupling reactance between 1d-axis damper windings                                |
| $x_{1d}$   | $x_{1d}$  | p.u. | Reactance of 1d-damper winding (d-axis)                                           |
| $r_{1d}$   | $r_{1d}$  | p.u. | Resistance of 1d-damper winding (d-axis)                                          |
| $x_{1de}$  | $x_{1de}$ | p.u. | Eddy-current reactance of 1d-damper winding for $slip = 1p.u.$ (d-axis)           |
| $r_{1de}$  | $r_{1de}$ | p.u. | Eddy-current resistance of 1d-damper winding for $slip = 1p.u.$ (d-axis)          |
| $x_{fd}$   | $x_{fd}$  | p.u. | Reactance of excitation (field) winding (d-axis)                                  |
| $r_{fd}$   | $r_{fd}$  | p.u. | Resistance of excitation (field) winding (d-axis)                                 |
| $x_{fde}$  | $x_{fde}$ | p.u. | Eddy-current reactance of excitation (field) winding for $slip = 1p.u.$ (d-axis)  |
| $r_{fde}$  | $r_{fde}$ | p.u. | Eddy-current resistance of excitation (field) winding for $slip = 1p.u.$ (d-axis) |
| $x_{1qc}$  | $x_{1qc}$ | p.u. | Coupling reactance between 1q-axis damper windings                                |
| $x_{1q}$   | $x_{1q}$  | p.u. | Reactance of 1q-damper winding (q-axis)                                           |
| $r_{1q}$   | $r_{1q}$  | p.u. | Resistance of 1q-damper winding (q-axis)                                          |
| $x_{1qe}$  | $x_{1qe}$ | p.u. | Eddy-current reactance of 1q-damper winding for $slip = 1p.u.$ (q-axis)           |
| $r_{1qe}$  | $r_{1qe}$ | p.u. | Eddy-current resistance of 1q-damper winding for $slip = 1p.u.$ (q-axis)          |

The synchronous reactances can be obtained as follows:

$$\begin{aligned} x_d &= x_l + x_{ad} \\ x_q &= x_l + x_{aq} \end{aligned} \tag{175}$$

### 6.6.2 Model equations

The rotor variables are referred to the stator windings and the equations are written using the rotor reference frame in generator orientation.

In the case of balanced RMS simulation, the available simulated values are positive sequence complex values. In the case of unbalanced RMS simulation, the available complex phase values for currents and voltages are first transformed into symmetrical components. For transforming to the dq-reference frame, the variables are shifted by multiplying with the transformation  $\cos \varphi - j \cdot \sin \varphi$ . The voltages and currents available from the EMT simulation are first transformed from instantaneous values in the  $\alpha\beta\gamma$  system using the Clarke transformation. The same transformation as above is used for transforming to the dq rotating reference frame.

Based on the equivalent circuit diagrams according to Figure 6.12 to Figure 6.13, the following differential equations can be derived.

The *PowerFactory* synchronous machine model for RMS simulations uses the rotor currents, magnetisation fluxes, the speed  $n$  and the angle  $\varphi$  as state variables. The EMT model uses two more state variables (stator fluxes  $\psi_d$  and  $\psi_q$ ).

The stator voltage equations can be described as follows:

$$\begin{aligned} u_d &= -r_{str} \cdot i_d - n \cdot \psi_q + \frac{1}{\omega_n} \cdot \frac{d\psi_d}{dt} \\ u_q &= -r_{str} \cdot i_q + n \cdot \psi_d + \frac{1}{\omega_n} \cdot \frac{d\psi_q}{dt} \\ u_0 &= -r_{str} \cdot i_0 + \frac{1}{\omega_n} \cdot \frac{d\psi_0}{dt} \end{aligned} \quad (176)$$

where  $n$  is the speed of the rotor and  $\omega_n = 2 \cdot \pi \cdot f_{nom}$  is the nominal angular frequency.

The rotor voltage equations for the d-axis and q-axis have the following form:

$$\begin{aligned} 0 &= r_{1d} \cdot i_{1d} + \frac{1}{\omega_n} \cdot \frac{d\psi_{1d}}{dt} \\ 0 &= r_{1de} \cdot i_{1de} + \frac{1}{\omega_n} \cdot \frac{d\psi_{1de}}{dt} \\ v_{fd} &= i_{fd} \cdot r_{fd} + \frac{1}{\omega_n} \cdot \frac{d\psi_{fd}}{dt} \\ 0 &= i_{fde} \cdot r_{fde} + \frac{1}{\omega_n} \cdot \frac{d\psi_{fde}}{dt} \end{aligned} \quad (177)$$

$$\begin{aligned} 0 &= r_{1q} \cdot i_{1q} + \frac{1}{\omega_n} \cdot \frac{d\psi_{1q}}{dt} \\ 0 &= r_{1qe} \cdot i_{1qe} + \frac{1}{\omega_n} \cdot \frac{d\psi_{1qe}}{dt} \end{aligned} \quad (178)$$

For completing the model, the stator and rotor flux linkage equations in the d- and q-axis are required:

$$\begin{aligned} \psi_d &= \psi_{ad} - x_l \cdot i_d \\ \psi_q &= \psi_{aq} - x_l \cdot i_q \end{aligned} \quad (179)$$

$$\begin{aligned} \psi_{1d} &= \psi_{ad} + x_{rld} \cdot (i_{fd} + i_{fde}) + (x_{rld} + x_{1dc}) \cdot i_{1de} + (x_{rld} + x_{1dc} + x_{1d}) \cdot i_{1d} \\ \psi_{1de} &= \psi_{ad} + x_{rld} \cdot (i_{fd} + i_{fde}) + (x_{rld} + x_{1dc}) \cdot i_{1d} + (x_{rld} + x_{1dc} + x_{1de}) \cdot i_{1de} \\ \psi_{fd} &= \psi_{ad} + x_{rld} \cdot (i_{1d} + i_{1de}) + (x_{rld} + x_{fd}) \cdot (i_{fd} + i_{fde}) \\ \psi_{fde} &= \psi_{ad} + (x_{rld} + x_{fd}) \cdot i_{fd} + (x_{rld} + x_{fd} + x_{fde}) \cdot i_{fde} + x_{rld} \cdot (i_{1d} + i_{1de}) \end{aligned} \quad (180)$$

$$\begin{aligned} \psi_{1q} &= \psi_{aq} + x_{1qc} \cdot i_{1qe} + (x_{1qc} + x_{1q}) \cdot i_{1q} \\ \psi_{1qe} &= \psi_{aq} + x_{1qc} \cdot i_{1q} + (x_{1qc} + x_{1qe}) \cdot i_{1qe} \end{aligned} \quad (181)$$

where  $\psi_{ad}$  and  $\psi_{aq}$  are the d- and q-axis components of the magnetising flux:

$$\begin{aligned} \psi_{ad} &= x_{ad} \cdot (-i_d + i_{1d} + i_{1de} + i_{fd} + i_{fde}) \\ \psi_{aq} &= x_{aq} \cdot (-i_q + i_{1q} + i_{1qe}) \end{aligned} \quad (182)$$

The electrical torque is calculated using the stator currents and stator fluxes and the rated power factor  $\cos n$ :

$$t_e = \frac{i_q \cdot \psi_d - i_d \cdot \psi_q}{\cos n} \quad \text{p.u.} \quad (183)$$

### 6.6.2.1 Equations for the RMS model

The equations from Section 6.6.2 are used for the RMS model where several simplifications have been made for the stator voltage equations.

The stator dynamics are relatively fast for stability studies. Therefore, for RMS-simulations, the derivatives of the stator quantities are not considered in the equations. Taking into account this simplification, the stator voltage Equations 176 can be written as:

$$\begin{aligned} u_d &= -r_{str} \cdot i_d - n \cdot \psi_q \\ u_q &= -r_{str} \cdot i_q + n \cdot \psi_d \end{aligned} \quad (184)$$

Similar as in the standard *PowerFactory* RMS model, additional modification can be made to the model by enabling/disabling the effect of the speed variation on the stator voltages (option *i\_speedVar* on the *Advanced* tab of the *RMS-Simulation* page of *TypSym*). Depending on the option selected, Equation 184 is modified as follows:

- Effect of speed variation considered

The equations have the form as already presented and the speed is considered in the equations.

- Effect of speed variation neglected

The speed is set equal to the initial speed in both equations.

The option *Considered* should not be used for direct motor starting applications since during starting there is a big difference between the speed of the machine and the network frequency. The simulated results without this option are similar to the results of the EMT model. For motor starting applications including variable speed drives the speed effect variation option should be considered.

For studies where the torque is of true interest, the EMT model is more appropriate.

In the case of unbalanced RMS simulation the same neutral, zero and negative sequence equations have to be satisfied as in Section 6.1.2.1.

For the unbalanced RMS simulation, the model for asynchronous starting takes into account also a negative sequence torque into the equation of motion (Equation 100). The electrical torque  $t_e$  is the sum of the positive and negative sequence torques. The positive sequence torque  $t_{e1}$  is calculated according to 183. The negative sequence torque is calculated as:

$$t_{e2} = \frac{(r_{2sy} - r_{str}) \cdot i_2^2}{\cos n} \quad \text{p.u.} \quad (185)$$

### 6.6.2.2 Equations for the EMT model

For the EMT model, there are no changes made to the equations presented in Section 6.6.2.

For the EMT simulation, the neutral and zero sequence equations that have to be satisfied are the same as in Section 6.1.2.2.

When simulating asynchronous starting of a synchronous motor, the rotor angle (see 6.6.2.3) of the machine is initialised always with the same value when the circuit-breaker of the machine is open. This yields one of many possible solutions. The DC components of the simulated variables depend on the rotor position with respect to the terminal voltage where the machine



will be connected. The DC components can be varied by changing the initial angle of the reference (for example: synchronous machine, voltage source, external grid) or by modifying the execution time of the circuit-breaker closing event.

### 6.6.2.3 Mechanical Equations, Rotor Angles and Delta Speed Input Signal

The mechanical equations, together with the definitions for mechanical torque, damping torque and acceleration time constant, are described in Section 6.1.2.3.

The rotor angle definitions are identical to the definitions presented in Section 6.1.3.

The functionality of the delta speed input signal  $dw$  is given in Section 6.1.6.

### 6.6.2.4 Saturation and parameter dependency

The model described so far is a purely linear model not considering any saturation effects. Generally, there exists saturation for all reactances of the synchronous machine model. However, for the purpose of system analysis, main flux saturation can be considered in the model by considering saturation of the mutual (magnetising) reactances  $x_{ad}$  and  $x_{aq}$ .

The main-flux saturation and the available options are as described in Section 6.1.4.

The saturation of stator leakage reactance is a current-dependent saturation, i.e. high currents after short-circuits will lead to a saturation effect of the leakage reactance. The modelling of the current dependency of the stator leakage reactance is supported by this model of the synchronous machine in *PowerFactory*. The data can be entered using tabular input of point-pairs of current and reactance. The data is then transformed to a smoothed curve with a piece-wise linear function using the dependency curve smoothing factor.

On every simulation step the stator reactance is determined from the curve for a specific value of the magnitude of the dq-stator current (zero sequence current is neglected):

$$xl = xl\_curve \left( \sqrt{i_d^2 + i_q^2} \right) \quad (186)$$

The additional impedance branches that are introduced to represent eddy-current effects, have parameters ( $x_{1de}$ ,  $r_{1de}$ ,  $x_{fde}$ ,  $r_{fde}$ ,  $x_{1qe}$  and  $r_{1qe}$ ) that are multiplied with the square root of the slip  $\sqrt{slip}$ . The values entered for this parameters in *TypSym* need to be for  $slip = 100\%$ . Internally the values are being kept and the dependent parameters are always updated according to:

$$\begin{aligned} x_{1de} &= x_{1de\_slip100\%} \cdot \sqrt{slip} \\ r_{1de} &= r_{1de\_slip100\%} \cdot \sqrt{slip} \\ x_{fde} &= x_{fde\_slip100\%} \cdot \sqrt{slip} \\ r_{fde} &= r_{fde\_slip100\%} \cdot \sqrt{slip} \\ x_{1qe} &= x_{1qe\_slip100\%} \cdot \sqrt{slip} \\ r_{1qe} &= r_{1qe\_slip100\%} \cdot \sqrt{slip} \end{aligned} \quad (187)$$

A threshold for the minimum slip is defined by using the parameter  $slip_{min}$ . By setting this parameter to 100%, the parameter dependency can be neglected.

### 6.6.2.5 Excitation system interfacing

Please refer to Section 6.1.5.

### 6.6.3 Integrated AVR for Motor Starting

Refer to Section 6.1.7.

### 6.6.4 Inputs/Outputs/State Variables of the Dynamic Model

#### 6.6.4.1 Stability Model (RMS)

Table 6.38: Input Definition of the RMS-Model

| Input Signal | Symbol    | Description                                    | Unit |
|--------------|-----------|------------------------------------------------|------|
| ve           | $v_e$     | Excitation voltage                             | p.u. |
| pt           |           | Turbine power                                  | p.u. |
| xmdm         |           | Torque input                                   | p.u. |
| fref         | $f_{ref}$ | Reference frequency                            | p.u. |
| freflocal    |           | Reference frequency of local reference machine | p.u. |
| dw           |           | Delta speed                                    | p.u. |

Table 6.39: State Variables Definition of the RMS-Model

| Parameter | Symbol      | Description                                             | Unit |
|-----------|-------------|---------------------------------------------------------|------|
| i1d       | $i_{1d}$    | Current in 1d-damper winding, d-axis                    | p.u. |
| i1de      | $i_{1de}$   | Eddy-current in 1d-damper winding, d-axis               | p.u. |
| ifd       | $i_{fd}$    | Current in field winding (excitation flux), d-axis      | p.u. |
| ifde      | $i_{fde}$   | Eddy-current in field winding (excitation flux), d-axis | p.u. |
| i1q       | $i_{1q}$    | Current in 1q-damper winding, q-axis                    | p.u. |
| i1qe      | $i_{1qe}$   | Eddy-current in 1q-damper winding, q-axis               | p.u. |
| psiad     | $\psi_{ad}$ | Magnetisation flux, d-axis                              | p.u. |
| psiaq     | $\psi_{aq}$ | Magnetisation flux, q-axis                              | p.u. |
| speed     | $n$         | Speed                                                   | p.u. |
| phi       | $\varphi$   | Rotor position angle                                    | rad  |

Table 6.40: Output Definition of the RMS-Model

| Parameter | Symbol  | Description                                                                  | Unit |
|-----------|---------|------------------------------------------------------------------------------|------|
| ut        | $u_t$   | Terminal Voltage                                                             | p.u. |
| utr       |         | Terminal Voltage, Real Part                                                  | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                                             | p.u. |
| pgt       |         | Electrical Power (based on rated active power)                               | p.u. |
| ie        | $i_e$   | Excitation Current (in non-reciprocal p.u. system)                           | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                                                 | rad  |
| xspeed    |         | Speed ( $xspeed = speed$ )                                                   | p.u. |
| xme       | $t_e$   | Electrical Torque                                                            | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                                            | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude                                         | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part                                         | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part                                    | p.u. |
| P1        |         | Positive-Sequence, Active Power                                              | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                                            | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                                           | p.u. |
| outofstep |         | Out of step (pole slip) is "1" if generator is out of step and "0" otherwise |      |

#### 6.6.4.2 EMT-Model

Table 6.41: Input Definition of the EMT-Model

| Input Signal | Symbol | Description        | Unit |
|--------------|--------|--------------------|------|
| ve           | $v_e$  | Excitation Voltage | p.u. |
| pt           |        | Turbine Power      | p.u. |
| xmdm         |        | Torque Input       | p.u. |
| dw           |        | Delta speed        | p.u. |

Table 6.42: State Variables Definition of the EMT-Model

| Parameter | Symbol      | Description                                             | Unit |
|-----------|-------------|---------------------------------------------------------|------|
| i1d       | $i_{1d}$    | Current in 1d-damper winding, d-axis                    | p.u. |
| i1de      | $i_{1de}$   | Eddy-current in 1d-damper winding, d-axis               | p.u. |
| ifd       | $i_{fd}$    | Current in field winding (excitation flux), d-axis      | p.u. |
| ifde      | $i_{fde}$   | Eddy-current in field winding (excitation flux), d-axis | p.u. |
| i1q       | $i_{1q}$    | Current in 1q-damper winding, q-axis                    | p.u. |
| i1qe      | $i_{1qe}$   | Eddy-current in 1q-damper winding, q-axis               | p.u. |
| psiad     | $\psi_{ad}$ | Magnetisation flux, d-axis                              | p.u. |
| psiaq     | $\psi_{aq}$ | Magnetisation flux, q-axis                              | p.u. |
| psid      | $\psi_d$    | Stator flux, d-axis                                     | p.u. |
| psiq      | $\psi_q$    | Stator flux, q-axis                                     | p.u. |
| speed     | $n$         | Speed                                                   | p.u. |
| phi       | $\varphi$   | Rotor position angle                                    | rad  |

Table 6.43: Output Definition of the EMT-Model

| Parameter | Symbol  | Description                                        | Unit |
|-----------|---------|----------------------------------------------------|------|
| ut        | $u_t$   | Terminal Voltage                                   | p.u. |
| utr       |         | Terminal Voltage, Real Part                        | p.u. |
| uti       |         | Terminal Voltage, Imaginary Part                   | p.u. |
| pgt       |         | Electrical Power (based on rated active power)     | p.u. |
| ie        | $i_e$   | Excitation Current (in non-reciprocal p.u. system) | p.u. |
| xphi      |         | Rotor Angle ( $xphi = phi$ )                       | rad  |
| xspeed    | n       | Speed ( $xspeed = speed$ )                         | p.u. |
| xme       | $t_e$   | Electrical Torque                                  | p.u. |
| xmt       | $t_m$   | Mechanical Torque                                  | p.u. |
| cur1      | $ i_t $ | Positive-Sequence Current, Magnitude               | p.u. |
| cur1r     |         | Positive-Sequence Current, Real Part               | p.u. |
| cur1i     |         | Positive-Sequence Current, Imaginary Part          | p.u. |
| P1        |         | Positive-Sequence, Active Power                    | MW   |
| Q1        |         | Positive-Sequence, Reactive Power                  | Mvar |
| fe        |         | Frequency Output ( $fe = xspeed$ )                 | p.u. |

## 6.7 Single-phase model

Single-phase synchronous machines in the high-power range are mainly used as generators for the railway power supply in some countries [17]. The development of the single-phase dynamic models was supported by [18].

The rotor d-axis is modelled by two rotor loops representing the excitation (field) winding and the 1d-damper winding. The q-axis is modelled using one 1q-damper winding.

### 6.7.1 Input Parameters

The input parameters for the single-phase machine are the same as for the standard salient machine model without the  $x_{rlq}$  parameter. Please refer to subsection 6.1.1 of Section *PowerFactory Standard Model*.

The input resistances and reactances of a single-phase machine have double the values of a three-phase machines, whereas the time constants have the same values (please see Section A).

*Note on the determination of the mutual magnetizing reactances:* While the definition for the mutual magnetizing reactances for three-phase machines is  $x_{ad} = 3/2 \cdot (lh + lh2)$  and  $x_{aq} = 3/2 \cdot (lh - lh2)$ , for the single-phase machine is  $x_{ad} = 1/2 \cdot (lh + lh2)$  and  $x_{aq} = 1/2 \cdot (lh - lh2)$ . For both machines  $lh$  is the mean value of the magnetizing inductance and  $lh2$  is the amplitude of the second harmonic of the magnetizing inductance for one stator phase. If measured the inductance of a stator phase is in front of a rotor pole  $lh + lh2 + xl$  and in between rotor poles  $lh - lh2 + xl$ .

### 6.7.2 Model equations

The rotor variables are referred to the stator windings and the equations are written using the rotor reference frame in generator orientation.

In the case of unbalanced RMS simulation, the available complex phase values for currents and voltages are first transformed into symmetrical components. For transforming to the dq-reference frame, the variables are shifted by multiplying with the transformation  $\cos \varphi - j \cdot \sin \varphi$ . The voltages and currents available from the EMT simulation are first transformed from instantaneous values in the  $\alpha\beta\gamma$  system using the Clarke transformation. The same transformation as above is used for transforming to the dq rotating reference frame.

#### 6.7.2.1 Equations for the RMS model

The stator dynamics are relatively fast for stability studies. Therefore, for RMS-simulations, the derivatives of the stator quantities are not considered in the equations. Taking into account this simplification, the stator voltage equations can be written as:

$$\begin{aligned} u_d &= -r_{str} \cdot i_d - n \cdot \psi_q \\ u_q &= -r_{str} \cdot i_q + n \cdot \psi_d \end{aligned} \tag{188}$$

Similar as in the standard *PowerFactory* RMS model, additional simplification can be made to the model by modifying the effect of the speed variation on the stator voltages (option located on the *Advanced* tab of the *RMS-Simulation* page of the *TypSym* edit dialog). Depending on the option selected, Equation 188 is modified as follows:

- Effect of speed variation considered

The equations have the form as already presented and the speed is considered in the equations.

- Effect of speed variation neglected

The speed is set equal to the initial speed in both equations. It is assumed that the speed changes are small and they don't have a big effect on the stator voltage [3]. The model is then valid for speed deviations around initial speed.

Using the reactance matrix:

$$\mathbf{X} = \begin{bmatrix} x_{ad} + x_{rl} + x_{1d} - \frac{x_{ad}^2}{2 \cdot x_d} & x_{ad} + x_{rl} - \frac{x_{ad}^2}{2 \cdot x_d} & 0 \\ x_{ad} + x_{rl} - \frac{x_{ad}^2}{2 \cdot x_d} & x_{ad} + x_{rl} + x_{fd} - \frac{x_{ad}^2}{2 \cdot x_d} & 0 \\ 0 & 0 & x_{aq} + x_{1q} - \frac{x_{aq}^2}{2 \cdot x_q} \end{bmatrix} \quad (189)$$

the following relationship between the fluxes and the rotor currents can be written:

$$\begin{bmatrix} \psi_{1d} - \frac{x_{ad}}{2 \cdot x_d} \cdot \psi_d \\ \psi_{fd} - \frac{x_{ad}}{2 \cdot x_d} \cdot \psi_d \\ \psi_{1q} - \frac{x_{aq}}{2 \cdot x_q} \cdot \psi_q \end{bmatrix} = \mathbf{X} \cdot \begin{bmatrix} i_{1d} \\ i_{fd} \\ i_{1q} \end{bmatrix} \quad (190)$$

where:

$$\begin{aligned} x_d &= x_l + \frac{x_{ad}}{2} \\ x_q &= x_l + \frac{x_{aq}}{2} \end{aligned} \quad (191)$$

The rotor currents can be now expressed using the inverse of the reactance matrix  $\mathbf{B} = \mathbf{X}^{-1}$  as:

$$\begin{bmatrix} i_{1d} \\ i_{fd} \\ i_{1q} \end{bmatrix} = \mathbf{B} \cdot \begin{bmatrix} \psi_{1d} - \frac{x_{ad}}{2 \cdot x_d} \cdot \psi_d \\ \psi_{fd} - \frac{x_{ad}}{2 \cdot x_d} \cdot \psi_d \\ \psi_{1q} - \frac{x_{aq}}{2 \cdot x_q} \cdot \psi_q \end{bmatrix} \quad (192)$$

The stator flux equations in the d- and q-axis have the following form:

$$\begin{aligned} \psi_d &= -x_d \cdot i_d + x_{ad} \cdot (i_{1d} + i_{fd}) \\ \psi_q &= -x_q \cdot i_q + x_{aq} \cdot i_{aq} \end{aligned} \quad (193)$$

The rotor flux derivatives equations in the d- and q-axis have the following form:

$$\begin{aligned}\frac{d\psi_{fd}}{dt} &= (v_{fd} - r_{fd} \cdot i_{fd}) \cdot \omega_n \\ \frac{d\psi_{1d}}{dt} &= -r_{1d} \cdot i_{1d} \cdot \omega_n \\ \frac{d\psi_{1q}}{dt} &= -r_{1q} \cdot i_{1q} \cdot \omega_n\end{aligned}\quad (194)$$

The electrical torque is calculated using the stator currents and stator fluxes and the rated power factor  $\cos n$ :

$$t_e = \frac{i_q \cdot \psi_d - i_d \cdot \psi_q}{\cos n} \quad \text{p.u.} \quad (195)$$

### 6.7.2.2 Equations for the EMT model

The stator voltage equation used for the EMT model is the following:

$$u_s = -r_{str} \cdot i_s + \frac{1}{\omega_n} \cdot \frac{d\psi_s}{dt} \quad (196)$$

where  $\omega_n = 2 \cdot \pi \cdot f_{nom}$  is the nominal angular frequency.

The rotor voltage equations for the d-axis and q-axis have the following form:

$$\begin{aligned}0 &= r_{1d} \cdot i_{1d} \cdot \omega_n + \frac{d\psi_{ad}}{dt} + (x_{rl} + x_{1d}) \cdot \frac{di_{1d}}{dt} + x_{rl} \cdot \frac{di_{fd}}{dt} \\ v_{fd} \cdot \omega_n &= r_{fd} \cdot i_{fd} \cdot \omega_n + \frac{d\psi_{ad}}{dt} + x_{rl} \cdot \frac{di_{1d}}{dt} + (x_{rl} + x_{fd}) \cdot \frac{di_{fd}}{dt} \\ 0 &= r_{1q} \cdot i_{1q} \cdot \omega_n + \frac{d\psi_{aq}}{dt} + x_{1q} \cdot \frac{di_{1q}}{dt}\end{aligned}\quad (197)$$

The stator and rotor flux equations in the d- and q-axis are:

$$\begin{aligned}\psi_s &= \psi_d \cdot \cos \varphi - \psi_q \cdot \sin \varphi \\ 0 &= \psi_d \cdot \sin \varphi + \psi_q \cdot \cos \varphi \\ \psi_d &= \psi_{ad} - x_l \cdot i_d \\ \psi_q &= \psi_{aq} + x_l \cdot i_q\end{aligned}\quad (198)$$

$$\begin{aligned}\psi_{1d} &= \psi_{ad} + (x_{rl} + x_{1d}) \cdot i_{1d} + x_{rl} \cdot i_{fd} \\ \psi_{fd} &= \psi_{ad} + x_{rl} \cdot i_{1d} + (x_{rl} + x_{fd}) \cdot i_{fd} \\ \psi_{1q} &= \psi_{aq} + x_{1q} \cdot i_{1q}\end{aligned}\quad (199)$$

where  $\psi_{ad}$  and  $\psi_{aq}$  are the d- and q-axis components of the magnetising flux:

$$\begin{aligned}\psi_{ad} &= x_{ad} \cdot (-i_d + i_{1d} + i_{fd}) \\ \psi_{aq} &= x_{aq} \cdot (-i_q + i_{1q})\end{aligned}\quad (200)$$

The electrical torque is calculated as the sum of the partial derivatives of the flux equations versus the angle times the current flowing in the winding:

$$\begin{aligned}t_e &= -2 \cdot ((x_{ad} - x_{aq})/2 \cdot \sin(2\varphi + \pi) \cdot i_s^2 - x_{ad} \cdot \cos(\varphi + \pi/2) \cdot i_s \cdot i_{fd} \\ &\quad - x_{ad} \cdot \cos(\varphi + \pi/2) \cdot i_s \cdot i_{1d} + x_{aq} \cdot \sin(\varphi + \pi/2) \cdot i_s \cdot i_{1q}) / \cos n\end{aligned}\quad (201)$$

where  $\cos n$  is the rated power factor.

### 6.7.2.3 Mechanical Equations, Rotor Angles and Delta Speed Input Signal

The mechanical equations, together with the definitions for mechanical torque, damping torque and acceleration time constant is described in Section 6.1.2.3.

### 6.7.3 Saturation

Saturation is not supported by the single-phase machine model.

### 6.7.4 Excitation system interfacing

Refer to Section 6.1.5.

### 6.7.5 Inputs/Outputs/State Variables of the Dynamic Model

#### 6.7.5.1 Stability Model (RMS)

Table 6.44: Input Definition of the RMS-Model

| Input Signal | Symbol    | Description                                    | Unit |
|--------------|-----------|------------------------------------------------|------|
| ve           | $v_e$     | Excitation voltage                             | p.u. |
| pt           |           | Turbine power                                  | p.u. |
| xmdm         |           | Torque input                                   | p.u. |
| fref         | $f_{ref}$ | Reference frequency                            | p.u. |
| freflocal    |           | Reference frequency of local reference machine | p.u. |
| dw           |           | Delta speed                                    | p.u. |

Table 6.45: State Variables Definition of the RMS-Model

| Parameter | Symbol      | Description                 | Unit |
|-----------|-------------|-----------------------------|------|
| psifd     | $\psi_{fd}$ | Field (excitation) flux     | p.u. |
| psi1d     | $\psi_{1d}$ | Flux in 1d-damper winding   | p.u. |
| psi1q     | $\psi_{1q}$ | Flux in 1q-damper winding   | p.u. |
| psid      | $\psi_d$    | Stator Flux, d-axis, d-axis | p.u. |
| psiq      | $\psi_q$    | Stator Flux, q-axis         | p.u. |
| speed     | $n$         | Speed                       | p.u. |
| phi       | $\varphi$   | Rotor position angle        | rad  |



Table 6.46: Output Definition of the RMS-Model

| Parameter | Symbol | Description                                                                  | Unit |
|-----------|--------|------------------------------------------------------------------------------|------|
| pgt       |        | Electrical Power (based on rated active power)                               | p.u. |
| ie        | $i_e$  | Excitation Current (in non-reciprocal p.u. system)                           | p.u. |
| xphi      |        | Rotor Angle ( $xphi = phi$ )                                                 | rad  |
| xspeed    |        | Speed ( $xspeed = speed$ )                                                   | p.u. |
| xme       | $t_e$  | Electrical Torque                                                            | p.u. |
| xmt       | $t_m$  | Mechanical Torque                                                            | p.u. |
| fe        |        | Frequency Output ( $fe = xspeed$ )                                           | p.u. |
| outofstep |        | Out of step (pole slip) is "1" if generator is out of step and "0" otherwise |      |

### 6.7.5.2 EMT-Model

Table 6.47: Input Definition of the EMT-Model

| Input Signal | Symbol | Description        | Unit |
|--------------|--------|--------------------|------|
| ve           | $v_e$  | Excitation Voltage | p.u. |
| pt           |        | Turbine Power      | p.u. |
| xmdm         |        | Torque Input       | p.u. |
| dw           |        | Delta speed        | p.u. |

Table 6.48: State Variables Definition of the EMT-Model

| Parameter | Symbol      | Description                                        | Unit |
|-----------|-------------|----------------------------------------------------|------|
| i1d       | $i_{1d}$    | Current in 1d-damper winding, d-axis               | p.u. |
| ifd       | $i_{fd}$    | Current in field winding (excitation flux), d-axis | p.u. |
| i1q       | $i_{1q}$    | Current in 1q-damper winding, q-axis               | p.u. |
| psiad     | $\psi_{ad}$ | Magnetisation flux, d-axis                         | p.u. |
| psiaq     | $\psi_{aq}$ | Magnetisation flux, q-axis                         | p.u. |
| psid      | $\psi_d$    | Stator flux, d-axis                                | p.u. |
| psiq      | $\psi_q$    | Stator flux, q-axis                                | p.u. |
| psis      | $\psi_s$    | Stator flux                                        | p.u. |
| speed     | $n$         | Speed                                              | p.u. |
| phi       | $\varphi$   | Rotor position angle                               | rad  |

Table 6.49: Output Definition of the EMT-Model

| Parameter | Symbol | Description                                        | Unit |
|-----------|--------|----------------------------------------------------|------|
| pgt       |        | Electrical Power (based on rated active power)     | p.u. |
| ie        | $i_e$  | Excitation Current (in non-reciprocal p.u. system) | p.u. |
| xphi      |        | Rotor Angle ( $xphi = phi$ )                       | rad  |
| xspeed    | $n$    | Speed ( $xspeed = speed$ )                         | p.u. |
| xme       | $t_e$  | Electrical Torque                                  | p.u. |
| xmt       | $t_m$  | Mechanical Torque                                  | p.u. |
| fe        |        | Frequency Output ( $fe = xspeed$ )                 | p.u. |

## 7 References

- [1] P. Krause, O. Wasynczuk, S. Sudhoff, and S. Pekarek, *Analysis of Electric Machinery and Drive Systems*. Wiley, 2013.
- [2] R. D. Doncker, D. W. Pulle, and A. Veltman, *Advanced Electrical Drives: Analysis, Modeling, Control*. Springer, second ed., 2020.
- [3] P. Kundur, *Power System Stability and Control*. McGraw-Hill, Inc, 1994.
- [4] Ontario Hydro, "Determination of Synchronous Machine Stability Study Constants, Volume 2," Tech. Rep. EL-1424-V2, EPRI, 1980.
- [5] P. Dandeno and J. Service, "Experience with translation of turbogenerator operational test data and corresponding d and q axis stability models, into standard inductance and time constant forms," *PSCC*, 1990.
- [6] B. Oswald, *Netzberechnung 2: Berechnung transients Vorgänge in Elektroenergieversorgungs-netzen*. VDE-Verlag, 1 ed., 1996.
- [7] B. Oswald, *Berechnung von Drehstromnetzen: Berechnung stationärer und nichtstationärer Vorgänge mit Symmetrischen Komponenten und Raumzeigern*. Springer Vieweg, 2 ed., 2013.
- [8] IEEE, "Guide for Synchronous Generator Modelling Practices and Applications in Power System Stability Analyses," Tech. Rep. 1110-2002, IEEE, 2002.
- [9] M. Canay, "Determination of model parameters of synchronous machines," *IEE Proceedings B*, vol. 130, no. 2, 1983.
- [10] M. Winkler and B. Oswald, "Ermittlung und Dokumentation der Modellparameter für die Simulation des nichtstationären Betriebsverhaltens von Elektroenergiesystemen," *Wissenschaftliche Zeitschrift der Technischen Universität Dresden*, vol. 37, no. 4, 1988.
- [11] I. Erlich and G. Rasulyar, "Quasistationäre Synchronmaschinenmodelle zur Simulation elektromechanischer Ausgleichsvorgänge," *Elektrie, Berlin*, vol. 47, no. 9, 1993.
- [12] WECC, "White Paper on GENQEC Model in Power System Studies," tech. rep., WECC, August 12, 2021.
- [13] M. Canay, "Equivalent Circuits of Synchronous Machines for Calculating Quantities of the Rotor during Transient Processes and Asynchronous Starting Part II. Salient-Pole Machines," *Brown Boveri Rev.*, vol. 3, 1970.
- [14] M. Canay, "Equivalent Circuits of Synchronous Machines for Calculating Quantities of the Rotor during Transient Processes and Asynchronous Starting Part I. Turbogenerators," *Brown Boveri Rev.*, vol. 2, 1969.
- [15] M. Canay, "Asynchronous starting of synchronous machines with or without rectifiers in the field circuit," *Proceedings IEE*, vol. 119, no. 12, 1972.
- [16] M. Canay, "Physical significance of sub-subtransient quantities in dynamic behaviour of synchronous machines," *Proceedings IEE*, vol. 135, no. 6, 1988.
- [17] G. Müller and B. Ponick, *Theorie elektrischer Maschinen*. WILEY-VCH, 2009.
- [18] Schweizerische Bundesbahnen SBB AG.

# Appendices

## A Base values for single- and three-phase machines

The impedance base is calculated using the rated voltage and rated apparent power as:

$$Z_{base} = \frac{ugn^2}{sgn} \quad [\Omega] \quad (202)$$

where:

- For three-phase machines:
  - $sgn$  is the rated three-phase apparent power.
  - $ugn$  is the rated line-line voltage.
- For single-phase machines:
  - $sgn$  is the rated single-phase apparent power.
  - $ugn$  is the rated line-line voltage for phase to phase connections and the rated line-ground voltage for phase to neutral connections.

According to [17], the behaviour of the single-phase machine can be derived from the single-phase operation of a three-phase machine. Impedances of a single-phase machine have double the values of the impedances of a three-phase machine loaded between two phases. So, if a three-phase machine with equal base voltage and apparent power is used in two phase mode, the resistances and reactances have to be set to half of the values of the single phase machine. The transient and subtransient time constants have the same value.

The rotor variables are referred to the stator side.

The base torque is the ratio between the electrical active power and the nominal mechanical angular frequency:

$$t_{base} = \frac{sgn \cdot \cos n \cdot 1e^6}{\omega_{mech.n}} \quad \text{Nm} \quad (203)$$

$$\omega_{mech.n} = \frac{\omega_n}{\text{polepairs}} \quad \text{mech.rad/s} \quad (204)$$

where the nominal angular frequency  $\omega_n$  is calculated using the nominal frequency  $F_{nom}$ :

$$\omega_n = 2\pi \cdot F_{nom} \quad \text{elec.rad/s} \quad (205)$$

The base flux is the ratio of the peak line-earth voltage and the nominal angular frequency:

$$\psi_{base} = \frac{\sqrt{2} \cdot \frac{ugn \cdot 1e^3}{\sqrt{3}}}{\omega_n} \quad \text{Wb} \quad (206)$$

When an inductance is given in H, the reactance in p.u. can be calculated as:

$$x = \frac{\omega_n \cdot L}{Z_{base}} \quad \text{p.u.} \quad (207)$$

## B Additional calculation parameters (RMS/EMT simulation)

In this appendix, the calculation of some additional parameters available for the RMS and EMT models is presented:

- $P_{tspin}$  is the *Total Turbine Power of Area* in MW and is calculated using all machines belonging to a synchronous area as:

$$P_{tspin} = \sum_{ElmSym}^{Synch.area} (pt \cdot sgn \cdot cosn \cdot ngnum) \quad (208)$$

- $P_{nomspin}$  is the *Total Nominal Power of Spinning Machines in Area* in MW and is calculated using all machines belonging to a synchronous area as:

$$P_{nomspin} = \sum_{ElmSym}^{Synch.area} (sgn \cdot cosn \cdot ngnum) \quad (209)$$

- $P_{maxspin}$  is the *Total Maximum Power of Spinning Machines in Area* in MW and is calculated using all machines belonging to a synchronous area as:

$$P_{maxspin} = \sum_{ElmSym}^{Synch.area} P_{max} \quad (210)$$

where  $P_{max}$  is the smaller value between  $P_{max\_uc} \cdot ngnum$  and  $sgn \cdot cosn \cdot pmaxratf \cdot ngnum$ .

- $P_{resspin}$  is the *Spinning Reserve of Area* in MW and is calculated using all machines belonging to a synchronous area as:

$$P_{resspin} = P_{maxspin} - P_{tspin} \quad (211)$$

- $Tagav$  is the *System Inertia of Area* in s and is calculated using all machines belonging to a synchronous area as:

$$Tagav = \left( \sum_{ElmSym}^{Synch.area} (Tag \cdot sgn \cdot cosn \cdot ngnum) \right) / P_{nomspin} \quad (212)$$

- $dorhz$  is the *Speed Deviation* in Hz and is calculated as:

$$dorhz = (speed + dw - 1) \cdot F_{nom} \quad (213)$$

- $v_{e\_rated}$  is the rated excitation voltage in p.u. (non-reciprocal system). It is calculated in the same manner as  $v_e$  but for 1p.u. rated voltage, rated load current of  $cosn - j \cdot \sqrt{1 - cosn^2}$ , nominal speed and saturation.

Table B.1 lists the parameters used in the parameter calculation.

Table B.1: List of parameters

| Parameter | Location    | Description                  | Unit |
|-----------|-------------|------------------------------|------|
| pt        | Signal      | Turbine power                | p.u. |
| sgn       | Type        | Rated apparent power         | MVA  |
| cosn      | Type        | Rated power factor           |      |
| ngnum     | Element     | Number of parallel machines  |      |
| Pmax      | Calculation | Upper limit of active power  | MW   |
| Pmax_uc   | Element     | Maximum active power limit   | MW   |
| pmaxratf  | Element     | Rating factor (active power) |      |
| Tag       | Calculation | Acceleration time constant   | s    |
| speed     | Signal      | Speed of the machine         | p.u. |
| dw        | Signal      | Delta speed                  | p.u. |

## List of Figures

|      |                                                                                                                                                               |    |
|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|----|
| 2.1  | Basic concept of a controlled synchronous machine . . . . .                                                                                                   | 2  |
| 2.2  | Voltage Q-Droop Control . . . . .                                                                                                                             | 3  |
| 2.3  | Voltage Q-Droop Control . . . . .                                                                                                                             | 4  |
| 2.4  | Voltage Iq-Droop Control . . . . .                                                                                                                            | 4  |
| 2.5  | Voltage Iq-Droop Control . . . . .                                                                                                                            | 6  |
| 2.6  | Q(P)-Characteristic . . . . .                                                                                                                                 | 7  |
| 2.7  | Base capability curve of the synchronous machine . . . . .                                                                                                    | 9  |
| 3.1  | Single-phase equivalent circuit diagrams of a generator for short-circuit current calculations which include the modelling of the field attenuation . . . . . | 14 |
| 3.2  | Short-circuit model for a synchronous machine . . . . .                                                                                                       | 15 |
| 5.1  | Harmonic load flow impedance model . . . . .                                                                                                                  | 19 |
| 5.2  | Harmonic load flow thevenin equivalent model . . . . .                                                                                                        | 19 |
| 5.3  | Frequency domain representation of synchronous machine using the option <i>Use frequency transfer functions</i> . . . . .                                     | 21 |
| 6.1  | d-axis equivalent circuit . . . . .                                                                                                                           | 24 |
| 6.2  | q-axis equivalent circuit - salient rotor . . . . .                                                                                                           | 24 |
| 6.3  | q-axis equivalent circuit - round rotor . . . . .                                                                                                             | 25 |
| 6.4  | Rotor angle definitions example . . . . .                                                                                                                     | 38 |
| 6.5  | Open-circuit saturation characteristic . . . . .                                                                                                              | 40 |
| 6.6  | d- and q-axis saturation characteristics . . . . .                                                                                                            | 41 |
| 6.7  | Application for Delta Speed input signal . . . . .                                                                                                            | 45 |
| 6.8  | Integrated AVR for motor starting . . . . .                                                                                                                   | 46 |
| 6.9  | d-axis equivalent circuit . . . . .                                                                                                                           | 56 |
| 6.10 | q-axis equivalent circuit . . . . .                                                                                                                           | 56 |
| 6.11 | Classical model equivalent circuit . . . . .                                                                                                                  | 66 |
| 6.12 | d-axis equivalent circuit . . . . .                                                                                                                           | 70 |
| 6.13 | q-axis equivalent circuit . . . . .                                                                                                                           | 70 |

## List of Tables

|      |                                                                            |    |
|------|----------------------------------------------------------------------------|----|
| 6.1  | Standard input parameters of the synchronous machine . . . . .             | 25 |
| 6.2  | Model parameters of the synchronous machine . . . . .                      | 26 |
| 6.3  | Input Definition of the RMS-Model . . . . .                                | 46 |
| 6.4  | State Variables Definition of the RMS-Model . . . . .                      | 47 |
| 6.5  | Output Definition of the RMS-Model . . . . .                               | 47 |
| 6.6  | Input Definition of the EMT-Model . . . . .                                | 47 |
| 6.7  | State Variables Definition of the EMT-Model . . . . .                      | 47 |
| 6.8  | Output Definition of the EMT-Model . . . . .                               | 48 |
| 6.9  | Standard input parameters of the synchronous machine GENQEC model . . . .  | 49 |
| 6.10 | Alternative input parameters of the synchronous machine GENQEC model . . . | 50 |
| 6.11 | Input Definition of the RMS-Model . . . . .                                | 54 |
| 6.12 | State Variables Definition of the RMS-Model . . . . .                      | 54 |
| 6.13 | Output Definition of the RMS-Model . . . . .                               | 54 |
| 6.14 | Input Definition of the EMT-Model . . . . .                                | 55 |
| 6.15 | State Variables Definition of the EMT-Model . . . . .                      | 55 |
| 6.16 | Output Definition of the EMT-Model . . . . .                               | 55 |
| 6.17 | Input data from operational reactances . . . . .                           | 57 |
| 6.18 | Model parameters of the model 3.3 synchronous machine . . . . .            | 57 |
| 6.19 | Input Definition of the RMS-Model . . . . .                                | 61 |
| 6.20 | State Variables Definition of the RMS-Model . . . . .                      | 61 |
| 6.21 | Output Definition of the RMS-Model . . . . .                               | 61 |
| 6.22 | Input Definition of the EMT-Model . . . . .                                | 62 |
| 6.23 | State Variables Definition of the EMT-Model . . . . .                      | 62 |
| 6.24 | Output Definition of the EMT-Model . . . . .                               | 62 |
| 6.25 | Input Definition of the RMS-Model . . . . .                                | 64 |
| 6.26 | State Variables Definition of the RMS-Model . . . . .                      | 64 |
| 6.27 | Output Definition of the RMS-Model . . . . .                               | 64 |
| 6.28 | Input Definition of the EMT-Model . . . . .                                | 64 |
| 6.29 | State Variables Definition of the EMT-Model . . . . .                      | 65 |

|                                                                      |    |
|----------------------------------------------------------------------|----|
| 6.30 Output Definition of the EMT-Model . . . . .                    | 65 |
| 6.31 Input Definition of the RMS-Model . . . . .                     | 67 |
| 6.32 State Variables Definition of the RMS-Model . . . . .           | 68 |
| 6.33 Output Definition of the RMS-Model . . . . .                    | 68 |
| 6.34 Input Definition of the EMT-Model . . . . .                     | 68 |
| 6.35 State Variables Definition of the EMT-Model . . . . .           | 68 |
| 6.36 Output Definition of the EMT-Model . . . . .                    | 69 |
| 6.37 Model parameters of the model 3.3 synchronous machine . . . . . | 71 |
| 6.38 Input Definition of the RMS-Model . . . . .                     | 75 |
| 6.39 State Variables Definition of the RMS-Model . . . . .           | 75 |
| 6.40 Output Definition of the RMS-Model . . . . .                    | 76 |
| 6.41 Input Definition of the EMT-Model . . . . .                     | 76 |
| 6.42 State Variables Definition of the EMT-Model . . . . .           | 76 |
| 6.43 Output Definition of the EMT-Model . . . . .                    | 77 |
| 6.44 Input Definition of the RMS-Model . . . . .                     | 81 |
| 6.45 State Variables Definition of the RMS-Model . . . . .           | 81 |
| 6.46 Output Definition of the RMS-Model . . . . .                    | 82 |
| 6.47 Input Definition of the EMT-Model . . . . .                     | 82 |
| 6.48 State Variables Definition of the EMT-Model . . . . .           | 82 |
| 6.49 Output Definition of the EMT-Model . . . . .                    | 82 |
| B.1 List of parameters . . . . .                                     | 86 |