

加古川大堰操作記録Ⅰ

2017年04月18日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン	流入 量判定	印字要因									
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)						本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト												
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸																	
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段																					
	T. Pm	T. Pm	10³m³	m³/s	m³/s																															
0:10	12.52	8.33	1657	282.62	374.68	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	定刻									
0:20	12.59	8.41	1718	310.28	405.47	113.27	0.00	0.24	0.00	0.24	0.00	0.24	0.00	113.27	0.00	27.54	27.74		46.07		46.07				1	2	定刻									
						145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
0:30	12.67	8.51	1789	334.59	445.31	123.16	0.00	2.27	0.00	2.27	0.00	2.27	0.00	123.16	0.00	28.37	28.57		47.70		47.70				1	2	定刻									
						145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
0:40	12.74	8.61	1852	366.57	483.28	134.79	0.00	5.89	0.00	5.89	0.00	5.89	0.00	134.79	0.00	29.33	29.53		49.60		49.60				1	2	定刻									
						145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
0:40	12.74	8.61	1852	366.57	483.28	145.26	0.00	9.88	0.00	9.88	0.00	9.88	0.00	145.26	0.00	30.18	30.38		51.28		51.28	1 C			1	2	制御終了									
						145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
0:40	12.74	8.61	1852	366.57	483.28	145.26	0.00	9.88	0.00	9.88	0.00	9.88	0.00	145.26	0.00	30.18	30.38		51.28		51.28	1 C			1	2	制御不能									
						145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
0:50	12.81	8.71	1916	398.09	523.67	145.26	0.00	9.88	0.00	9.88	0.00	9.88	0.00	145.26	0.00	30.18	30.38		51.28		51.28				1	2	定刻									
						145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
0:53	12.83	8.74	1935	409.53	535.66	155.97	0.00	14.51	0.00	14.51	0.00	14.51	0.00	155.97	0.00	31.03	31.23		52.97		52.97				2	2	制御開始									
						145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E														
1:00	12.88	8.81	1981	438.21	566.35	159.08	0.00	15.94	0.00	15.94	0.00	15.94	0.00	159.08	0.00	31.28	31.48		53.46		53.46				2	2	定刻									
						145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:00	12.88	8.81	1981	438.21	566.35	166.95	0.00	19.69	0.00	19.69	0.00	19.69	0.00	166.95	0.00	31.90	32.10		54.69		54.69				2	2	制御開始									
						145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E														
1:05	12.92	8.85	2018	456.93	693.74	166.95	0.00	19.69	0.00	19.69	0.00	19.69	0.00	166.95	0.00	31.90	32.10		54.69		54.69				2	2	機器動作									
						145	0	71	0	0	40	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E														
1:10	12.90	9.01	1999	478.15	682.41	173.33	0.00	22.88	0.00	0.00	124.97	22.88	0.00	173.33	0.00	32.39	32.60		55.68		55.68				2	2	定刻									
						145	0	71	0	0	40	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:10	12.90	9.01	1999	478.15	682.41	170.13	0.00	21.27	0.00	0.00	124.75	21.27	0.00	170.13	0.00	32.15	32.35		55.18		55.18	2 E			2	2	制御開始									
						145	0	71	0	0	40	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:15	12.91	9.10	2008	503.38	805.93	170.13	0.00	21.27	0.00	0.00	124.75	21.27	0.00	170.13	0.00	32.15	32.35		55.18		55.18				2	2	機器動作									
						145	0	0	35	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E														
1:20	12.87	9.22	1971	523.44	786.12	171.72	0.00	0.00	109.53	0.00	155.29	22.07	0.00	171.72	0.00	32.27	32.47		55.43		55.43				2	2	定刻									
						145	0	0	35	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:20	12.87	9.22	1971	523.44	786.12	165.36	0.00	0.00	109.13	0.00	154.72	18.92	0.00	165.36	0.00	31.77	31.98		54.44		54.44	2 E			2	2	制御開始									
						145	0	0	35	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:25	12.85	9.29	1953	540.23	888.89	165.36	0.00	0.00	109.13	0.00	154.72	18.92	0.00	165.36	0.00	31.77	31.98		54.44		54.44				2	2	機器動作									
						145	0	0	50	0	50	0	30	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E														
1:30	12.79	9.41	1898	564.77	860.94	162.21	0.00	0.00	154.43	0.00	154.43	0.00	84.45	162.21	0.00	31.53	31.73		53.95		53.95				2	2	定刻									
						145	0	0	50	0	50	0	30	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:30	12.79	9.41	1898	564.77	860.94	152.89	0.00	0.00	153.57	0.00	153.57	0.00	81.26	152.89	0.00	30.79	30.99		52.49		52.49	2 E			2	2	制御開始									
						145	0	0	50	0	50	0	30	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:32	12.78	9.43	1889	570.79	988.24	152.89	0.00	0.00	153.57	0.00	153.57	0.00	81.26	152.89	0.00	30.79	30.99		52.49		52.49	2 E			2	2	機器動作									
						145	0	0	50	0	70	0	50	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:40	12.66	9.58	1780	610.02	917.14	151.35	0.00	0.00	153.43	0.00	212.64	0.00	153.43	151.35	0.00	30.67	30.87		52.25		52.25				2	2	定刻									
						145	0	0	50	0	70	0	50	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:40	12.66	9.58	1780	610.02	917.14	133.32	0.00	0.00	141.49	0.00	210.18	0.00	141.49	133.32	0.00	29.21	29.41		49.36		49.36	2 E			2	2	制御開始									
						145	0	0	50	0	70	0	50	146	0	9.02	8.99	G=4	9.55	G=4	9.55															
1:41	12.65	9.58	1771	613.95	998.06	133.32	0.00	0.00	141.49	0.00	210.18	0.00	141.49	133.32	0.00	29.21	29.41		49.36		49.36	2 E			2	2	機器動作									

加古川大堰操作記録Ⅰ

2017年04月18日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 パター ン	流入 量判 定	印字要因									
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)						本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト												
						1号		2号		3号		4号		5号		左岸	右岸	左岸	右岸																	
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段																					
	T. Pm	T. Pm	10³m³	m³/s	m³/s																															
1:50	12.50	9.67	1640	646.53	921.42	145	0	0	50	0	100	0	50	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始									
1:51	12.49	9.68	1632	648.91	1020.15	110.50	0.00	0.00	131.73	0.00	290.96	0.00	131.73	110.50	0.00	27.30	27.50		45.60		45.60				2	2	機器動作									
						145	0	0	80	0	100	0	50	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:00	12.34	9.73	1510	682.39	955.61	109.12	0.00	0.00	234.93	0.00	290.66	0.00	131.01	109.12	0.00	27.19	27.38		45.37		45.37				2	2	定刻									
						145	0	0	80	0	100	0	50	146	0	9.02	8.99	G=4	9.55	G=4	9.55				2	2										
2:00	12.34	9.73	1510	682.39	955.61	89.15	0.00	0.00	231.30	0.00	286.08	0.00	124.97	89.15	0.00	25.44	25.64		41.94		41.94	2 E			2	2	制御開始									
						145	0	0	80	0	100	0	50	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:01	12.33	9.73	1502	686.54	1039.20	89.15	0.00	0.00	231.30	0.00	286.08	0.00	124.97	89.15	0.00	25.44	25.64		41.94		41.94	2 E			2	2	機器動作									
						145	0	0	100	0	100	0	60	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:10	12.18	9.77	1382	716.71	974.61	87.87	0.00	0.00	285.77	0.00	285.77	0.00	157.63	87.87	0.00	25.33	25.52		41.72		41.72				2	2	定刻									
						145	0	0	100	0	100	0	60	146	0	9.02	8.99	G=4	9.55	G=4	9.55				2	2										
2:10	12.18	9.77	1382	716.71	974.61	69.39	0.00	0.00	281.12	0.00	281.12	0.00	149.36	69.39	0.00	23.63	23.82		38.39		38.39				2	2	制御開始									
						145	0	0	100	0	100	0	60	146	0	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:18	12.16	9.67	1366	740.66	1084.37	69.39	0.00	0.00	281.12	0.00	281.12	0.00	149.36	69.39	0.00	23.63	23.82		38.39		38.39				2	2	機器動作									
						0	50	0	100	0	100	0	60	0	50	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:20	12.05	9.76	1281	740.66	1047.27	0.00	122.56	0.00	280.50	0.00	280.50	0.00	155.36	0.00	122.56	23.40	23.59		37.95		37.95				2	2	定刻									
						0	50	0	100	0	100	0	60	0	50	9.02	8.99	G=4	9.55	G=4	9.55				2	2										
2:20	12.05	9.76	1281	740.66	1047.27	0.00	116.14	0.00	277.03	0.00	277.03	0.00	145.22	0.00	116.14	22.18	22.37		35.58		35.58				2	2	制御開始									
						0	50	0	100	0	100	0	60	0	50	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:21	12.03	9.78	1266	744.99	1147.09	0.00	116.14	0.00	277.03	0.00	277.03	0.00	145.22	0.00	116.14	22.18	22.37		35.58		35.58				2	2	機器動作									
						0	50	0	100	0	100	0	90	0	50	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:30	11.88	9.90	1154	776.41	1107.00	0.00	114.87	0.00	276.40	0.00	276.40	0.00	250.14	0.00	114.87	21.96	22.15		35.15		35.15				2	2	定刻									
						0	50	0	100	0	100	0	90	0	50	9.02	8.99	G=4	9.55	G=4	9.55				2	2										
2:30	11.88	9.90	1154	776.41	1107.00	0.00	106.55	0.00	271.59	0.00	271.59	0.00	245.83	0.00	106.55	20.34	20.53		32.01		32.01	2 E			2	2	制御開始									
						0	50	0	100	0	100	0	90	0	50	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:31	11.87	9.90	1147	773.84	1215.67	0.00	106.55	0.00	271.59	0.00	271.59	0.00	245.83	0.00	106.55	20.34	20.53		32.01		32.01				2	2	機器動作									
						0	80	0	100	0	100	0	100	0	50	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:40	11.66	9.96	998	803.25	1115.20	0.00	191.33	0.00	271.27	0.00	271.27	0.00	271.27	0.00	106.27	20.24	20.42		31.80		31.80				2	2	定刻									
						0	80	0	100	0	100	0	100	0	50	9.02	8.99	G=4	9.55	G=4	9.55				2	2										
2:50	11.53	9.92	909	833.24	1065.76	0.00	173.24	0.00	250.79	0.00	250.79	0.00	250.79	0.00	98.17	18.04	18.22		27.58		27.58				2	2	定刻									
						0	80	0	100	0	100	0	100	0	50	9.02	8.99	G=4	9.55	G=4	9.55				2	2										
2:50	11.53	9.92	909	833.24	1065.76	0.00	168.94	0.00	239.12	0.00	239.12	0.00	239.12	0.00	95.69	16.73	16.90		25.07		25.07	2 E			2	2	制御開始									
						0	80	0	100	0	100	0	100	0	50	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
2:51	11.53	9.92	909	837.85	1170.38	0.00	168.94	0.00	239.12	0.00	239.12	0.00	239.12	0.00	95.69	16.73	16.90		25.07		25.07				2	2	機器動作									
						0	100	0	100	0	100	0	100	0	65	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
3:00	11.40	9.94	826	863.80	1072.39	0.00	239.12	0.00	239.12	0.00	239.12	0.00	239.12	0.00	130.13	16.73	16.90		25.07		25.07				2	2	定刻									
						0	100	0	100	0	100	0	100	0	65	9.02	8.99	G=4	9.55	G=4	9.55				2	2										
3:00	11.40	9.94	826	863.80	1072.39	0.00	218.15	0.00	218.15	0.00	218.15	0.00	218.15	0.00	123.43	15.44	15.62		22.65		22.65	2 E			2	2	制御開始									
						0	100	0	100	0	100	0	100	0	65	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
3:02	11.38	9.94	814	873.23	1155.78	0.00	218.15	0.00	218.15	0.00	218.15	0.00	218.15	0.00	123.43	15.44	15.62		22.65		22.65				2	2	機器動作									
						0	100	0	100	0	100	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2										
3:10	11.28	9.96	751	887.48	1087.46	0.00	216.11	0.00	216.11	0.00	216.11	0.00	216.11	0.00	216.11	15.25	15.42		22.28		22.28				2	2	定刻									
						0	100	0	100	0	100	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55				2	2										
3:10	11.28	9.96	751	887.48																																

加古川大堰操作記録Ⅰ

2017年04月18日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制 御 パ タ ー ン	流 入 量 判 定	印 字 要 因
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト					
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸								
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段												
	T. Pm	T. Pm	10³ m³	m³/s	m³/s																						
3:20	11.20	9.98	701	921.28	1145.77	0	100	0	100	0	125	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2	定刻
						0.00	193.61	0.00	193.61	0.00	305.92	0.00	193.61	0.00	193.61	13.54	13.71		19.08		19.08						
3:20	11.20	9.98	701	921.28	1145.77	0	100	0	100	0	125	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
						0.00	193.61	0.00	193.61	0.00	305.92	0.00	193.61	0.00	193.61	13.54	13.71		19.08		19.08						
3:21	11.20	9.98	701	921.28	1247.21	0	100	0	115	0	150	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2	機器動作
						0.00	193.61	0.00	239.53	0.00	361.44	0.00	193.61	0.00	193.61	13.54	13.71		19.08		19.08						
3:30	11.13	10.01	660	955.81	1194.81	0	100	0	115	0	150	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2	定刻
						0.00	183.65	0.00	224.49	0.00	357.68	0.00	183.65	0.00	183.65	12.89	13.06		17.87		17.87						
3:30	11.13	10.01	660	955.81	1194.81	0	100	0	115	0	150	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
						0.00	183.65	0.00	224.49	0.00	357.68	0.00	183.65	0.00	183.65	12.89	13.06		17.87		17.87						
3:31	11.12	10.01	655	953.18	1301.94	0	100	0	140	0	150	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2	機器動作
						0.00	182.74	0.00	335.42	0.00	357.14	0.00	182.74	0.00	182.74	12.80	12.96		17.70		17.70						
3:40	11.09	10.04	637	986.00	1278.66	0	100	0	140	0	150	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2	定刻
						0.00	176.54	0.00	333.91	0.00	355.51	0.00	176.54	0.00	176.54	12.53	12.69		17.20		17.20						
3:40	11.09	10.04	637	986.00	1278.66	0	100	0	140	0	150	0	100	0	100	9.02	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
						0.00	176.54	0.00	333.91	0.00	355.51	0.00	176.54	0.00	176.54	12.53	12.69		17.20		17.20						
3:41	11.09	10.04	637	991.09	1384.90	0	100	0	150	0	150	0	130														

操 作 モ ー ド	1 文字目：運転モード	2 文字目：制御モード		
	1：自動	A：定水位Ⅰ（微調節）	E：事前放流	I：貯留回復Ⅱ
	2：半自動	B：全開（微調節）	F：定水位	J：開度一回
	3：遠方手動	C：定水位Ⅰ（調節上段）	G：全開	
	4：機側	D：設定流量	H：貯留回復Ⅰ	

制 御 パ タ ー ン	1：平水 2：洪水
----------------------------	--------------

流入量判定	1：堰水位 換算流入量 2：上流流入量
-------	---------------------------

G	最高天端高 1～3：魚道ゲートグループNo 4：制水ゲート
---	-------------------------------------

加古川大堰操作記録Ⅰ

2017年04月17日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン	流入 量判定	印字要因									
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)						本川 ゲート	微 調節 ゲート	魚道 ゲート												
						1号		2号		3号		4号		5号		左岸	右岸	左岸	右岸																	
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段																					
	T. Pm	T. Pm	10³m³	m³/s	m³/s																															
19:11	11.56	7.10	929	24.97	23.83	101	0	71	0	71	0	71	0	101	0	9.80	9.80	G=2	11.45	G=2	11.43				1	1	機器動作									
19:20	11.56	7.11	929	26.05	23.83	1.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.24	0.00	10.30	10.30		0.33		0.42				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.80	9.80	G=2	11.45	G=2	11.43															
19:28	11.56	7.11	929	26.83	23.74	1.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.24	0.00	10.30	10.30		0.33		0.42				1	1	機器動作									
						101	0	71	0	71	0	71	0	101	0	9.80	9.80	G=2	11.45	G=2	11.45															
19:30	11.56	7.11	929	26.68	23.74	1.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.24	0.00	10.30	10.30		0.33		0.33				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.80	9.80	G=2	11.45	G=2	11.45															
19:37	11.57	7.11	936	27.16	24.53	1.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.24	0.00	10.30	10.30		0.33		0.33				1	1	機器動作									
						101	0	71	0	71	0	71	0	101	0	9.80	9.80	G=2	11.47	G=2	11.45															
19:40	11.57	7.12	936	27.97	24.53	1.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.56	0.00	10.38	10.38		0.28		0.37				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.80	9.80	G=2	11.47	G=2	11.45															
19:40	11.57	7.12	936	27.97	24.53	1.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.56	0.00	10.38	10.38		0.28		0.37	1 A			1	1	制御開始									
						101	0	71	0	71	0	71	0	101	0	9.80	9.80	G=2	11.47	G=2	11.45															
19:41	11.57	7.12	936	28.25	29.41	1.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.56	0.00	10.38	10.38		0.28		0.37	1 A			1	1	機器動作									
						101	0	71	0	71	0	71	0	101	0	9.51	9.51	G=2	11.47	G=2	11.45															
19:50	11.57	7.15	936	29.30	29.41	1.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.56	0.00	12.82	12.82		0.28		0.37				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.51	9.51	G=2	11.47	G=2	11.45															
20:00	11.58	7.17	943	30.35	30.39	1.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.56	0.00	12.82	12.82		0.28		0.37				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.51	9.51	G=2	11.47	G=2	11.45															
20:00	11.58	7.17	943	30.35	30.39	1.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.90	0.00	12.92	12.92		0.33		0.42	1 A			1	1	制御開始									
						101	0	71	0	71	0	71	0	101	0	9.51	9.51	G=2	11.47	G=2	11.45															
20:01	11.58	7.17	943	30.53	35.31	1.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.90	0.00	12.92	12.92		0.33		0.42	1 A			1	1	機器動作									
						101	0	71	0	71	0	71	0	101	0	9.23	9.23	G=2	11.47	G=2	11.45															
20:10	11.58	7.19	943	32.78	35.31	1.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.90	0.00	15.38	15.38		0.33		0.42				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.23	9.23	G=2	11.47	G=2	11.45															
20:15	11.58	7.19	943	33.73	35.22	1.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.90	0.00	15.38	15.38		0.33		0.42				1	1	機器動作									
						101	0	71	0	71	0	71	0	101	0	9.23	9.23	G=2	11.47	G=2	11.47															
20:20	11.59	7.20	950	35.08	36.32	1.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.90	0.00	15.38	15.38		0.33		0.33				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.23	9.22	G=2	11.47	G=2	11.47															
20:20	11.59	7.20	950	35.08	36.32	2.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.27	0.00	15.48	15.56		0.37		0.37	1 A			1	1	制御開始									
						101	0	71	0	71	0	71	0	101	0	9.23	9.23	G=2	11.47	G=2	11.47															
20:21	11.59	7.20	950	35.47	40.12	2.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.27	0.00	15.48	15.56		0.37		0.37	1 A			1	1	機器動作									
						101	0	71	0	71	0	71	0	101	0	9.02	8.99	G=2	11.47	G=2	11.47															
20:22	11.59	7.20	950	35.88	40.08	2.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.27	0.00	17.33	17.51		0.37		0.37				1	1	機器動作									
						101	0	71	0	71	0	71	0	101	0	9.02	8.99	G=2	11.48	G=2	11.47															
20:30	11.59	7.21	950	39.01	40.08	2.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.27	0.00	17.33	17.51		0.33		0.37				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.02	8.99	G=2	11.48	G=2	11.47															
20:37	11.60	7.21	957	40.11	41.06	2.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.27	0.00	17.33	17.51		0.33		0.37				1	1	機器動作									
						101	0	71	0	71	0	71	0	101	0	9.02	8.99	G=2	11.50	G=2	11.47															
20:40	11.60	7.22	957	40.91	41.06	2.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.66	0.00	17.43	17.61		0.28		0.42				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.02	8.99	G=2	11.50	G=2	11.47															
20:42	11.60	7.22	957	41.63	40.97	2.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.66	0.00	17.43	17.61		0.28		0.42				1	1	機器動作									
						101	0	71	0	71	0	71	0	101	0	9.02	8.99	G=2	11.50	G=2	11.49															
20:50	11.61	7.22	964	45.21	42.08	2.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.66	0.00	17.43	17.61		0.28		0.33				1	1	定刻									
						101	0	71	0	71	0	71	0	101	0	9.02	8.99	G=2	11.50	G=2	11.49															
20:54	11.62	7.22																																		

加古川大堰操作記録Ⅰ

2017年04月17日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 パター ン	流入 量判 定	印字要因
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト					
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸								
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段												
	T.Pm	T.Pm	10³m³	m³/s	m³/s																						
20:57	11.62	7.22	971	48.46	43.03	101	0	71	0	71	0	71	0	101	0	9.02	8.99	G=2	11.52	G=2	11.51				1	1	機器動作
21:00	11.63	7.23	977	50.03	44.22	3.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.49	0.00	17.63	17.81		0.28		0.33				1	1	定刻
						101	0	71	0	71	0	101	0	9.02	8.99	G=2	11.52	G=2	11.51								
21:04	11.64	7.23	984	51.56	45.36	3.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.94	0.00	17.73	17.91		0.33		0.37				1	1	機器動作
						101	0	71	0	71	0	101	0	9.02	8.99	G=2	11.54	G=2	11.51								
21:06	11.64	7.23	984	52.29	45.27	4.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.40	0.00	17.84	18.02		0.28		0.42				1	1	機器動作
						101	0	71	0	71	0	101	0	9.02	8.99	G=2	11.54	G=2	11.53								
21:10	11.65	7.24	991	53.96	46.52	4.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.40	0.00	17.84	18.02		0.28		0.33				1	1	定刻
						101	0	71	0	71	0	101	0	9.02	8.99	G=2	11.54	G=2	11.53								
21:13	11.66	7.24	998	55.86	47.72	4.88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.88	0.00	17.94	18.12		0.33		0.37				1	1	機器動作
						101	0	71	0	71	0	101	0	9.02	8.99	G=2	11.56	G=2	11.53								
21:14	11.66	7.24	998	56.44	47.63	5.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.38	0.00	18.04	18.22		0.28		0.42				1	1	機器動作
						101	0	71	0	71	0	101	0	9.02	8.99	G=2	11.56	G=2	11.55								
21:19	11.68	7.25	1011	59.93	50.13	5.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.38	0.00	18.04	18.22		0.28		0.33				1	1	機器動作
						101	0	71	0	71	0	101	0	9.02	8.99	G=2	11.58	G=2	11.57								
21:20	11.69	7.25	1018	60.71	51.50	6.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.42	0.00	18.25	18.43		0.28		0.33				1	1	定刻
						101	0	71	0	71	0	101	0	9.02	8.99	G=2	11.58	G=2	11.57								
21:22	11.70	7.26	1025	62.47	52.73	6.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.96	0.00	18.35	18.53		0.33		0.37				1	1	機器動作
						101	0	71	0	71	0	101															

操 作 モ ー ド	1 文字目：運転モード	2 文字目：制御モード		
	1：自動	A：定水位Ⅰ（微調節）	E：事前放流	I：貯留回復Ⅱ
	2：半自動	B：全開（微調節）	F：定水位	J：開度一回
	3：遠方手動	C：定水位Ⅰ（調節上段）	G：全開	
	4：機側	D：設定流量	H：貯留回復Ⅰ	

制 御 パ タ ー ン	1：平水 2：洪水
----------------------------	--------------

流入量判定	1：堰水位 換算流入量 2：上流流入量
-------	---------------------------

G	最高天端高 1～3：魚道ゲートグループNo 4：制水ゲート
---	-------------------------------------

加古川大堰操作記録Ⅰ

2017年04月17日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 パター ン	流 入 量 判 定	印 字 要 因			
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト								
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸											
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段															
	T. Pm	T. Pm	10³ m³	m³/s	m³/s																									
22:30	12.03	7.65	1266	123.76	150.71	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=1	11.92	G=4	11.74	1 C			1	2	定刻			
						52.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	52.43	0.00	21.96	22.15		0.33		1.41									
22:40	12.08	7.76	1303	174.84	181.87	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=1	12.49	G=4	10.33							1	2	定刻
						57.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	57.91	0.00	22.51	22.70		0.00		20.84									
22:50	12.12	7.84	1334	170.62	211.66	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=1	11.34	G=4	9.67							1	2	定刻
						62.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	62.42	0.00	22.96	23.15		6.20		34.51									
23:00	12.16	7.90	1366	170.58	256.97	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55							1	2	定刻
						67.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	67.04	0.00	23.40	23.59		37.95		37.95									
23:02	12.17	7.91	1374	170.80	259.97	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1 C			1	2	制御終了
						68.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	68.21	0.00	23.51	23.70		38.17		38.17									
23:02	12.17	7.91	1374	170.80	259.97	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1 C			1	2	制御不能
						68.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	68.21	0.00	23.51	23.70		38.17		38.17									
23:04	12.17	7.94	1374	172.98	259.97	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	1 C			1	2	制御開始			
						68.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	68.21	0.00	23.51	23.70		38.17		38.17									
23:07	12.17	7.98	1374	175.26	259.97	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55		3		1	2	機器動作			
						68.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	68.21	0.00	23.51	23.70		38.17		38.17									
23:10	12.19	8.01	1390	179.61	266.05	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	定刻			
						70.58	0.00	0.00	0.00	0.00	0.00	0.00	0.00	70.58	0.00	23.74	23.93		38.61		38.61									
23:20	12.22	8.06	1414	190.36	275.25	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	定刻			
						74.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	74.18	0.00	24.08	24.27		39.27		39.27									
23:30	12.26	8.09	1446	203.19	287.69	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	定刻			
						79.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	79.07	0.00	24.53	24.72		40.15		40.15									
23:40	12.31	8.14	1486	218.12	303.57	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	定刻			
						85.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	85.32	0.00	25.10	25.29		41.27		41.27									
23:50	12.38	8.19	1541	236.00	326.40	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	定刻			
						94.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	94.35	0.00	25.90	26.10		42.85		42.85									
24:00	12.44	8.26	1590	256.28	346.48	145	0	71	0	71	0	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	定刻			
						102.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	102.32	0.00	26.60	26.80		44.22		44.22									

操 作 モ ー ド	1文字目：運転モード	2文字目：制御モード	制 御 パ タ ー ン	1：平水 2：洪水	流 入 量 判 定	1：堰水位 換算流入量 2：上流流入量	G	最高天端高 1～3：魚道ゲートグループNo 4：制水ゲート
	1：自動 2：半自動 3：遠方手動 4：機側	A：定水位Ⅰ（微調節） B：全開（微調節） C：定水位Ⅰ（調節上段） D：設定流量 E：事前放流 F：定水位 G：全開 H：貯留回復Ⅰ I：貯留回復Ⅱ J：開度一回						