

加古川大堰操作記録Ⅰ

2024年04月09日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン ー ン	流入 量 判定	印字要因	
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本川 ゲート	微 調節 ゲート	魚 道 ゲート						
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸									
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段													
	T. Pm	T. Pm	10³m³	m³/s	m³/s																							
0:00	12. 53	7. 19	1666	43. 95	37. 75	0	0	71	0	71	0	71	0	0	0	10. 07	10. 07	G=1	12. 41	G=1	12. 38		1 A		1	1	制御開始	
0:01	12. 53	7. 19	1666	44. 25	42. 69	0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	17. 33	17. 33		0. 37		0. 52		1 A		1	1	機器動作	
						0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	19. 80	19. 80		0. 37		0. 52							
0:10	12. 53	7. 21	1666	44. 52	42. 69	0	0	71	0	71	0	71	0	0	0	9. 81	9. 81	G=1	12. 41	G=1	12. 38			1	1	定刻		
						0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	19. 80	19. 80		0. 37		0. 52							
0:20	12. 53	7. 22	1666	45. 20	42. 69	0	0	71	0	71	0	71	0	0	0	9. 81	9. 81	G=1	12. 41	G=1	12. 38			1	1	定刻		
						0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	0. 44	0. 00	19. 80	19. 80		0. 37		0. 52							
0:30	12. 54	7. 22	1675	48. 20	44. 17	0	0	71	0	71	0	71	0	0	0	9. 81	9. 81	G=1	12. 41	G=1	12. 38			1	1	定刻		
						0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	19. 91	19. 91		0. 42		0. 58							
0:30	12. 54	7. 22	1675	48. 20	44. 17	0	0	71	0	71	0	71	0	0	0	9. 81	9. 81	G=1	12. 41	G=1	12. 38	1 A		1	1	制御開始		
						0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	19. 91	19. 91		0. 42		0. 58							
0:31	12. 54	7. 22	1675	48. 59	49. 05	0	0	71	0	71	0	71	0	0	0	9. 56	9. 56	G=1	12. 41	G=1	12. 38	1 A		1	1	機器動作		
						0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	22. 35	22. 35		0. 42		0. 58							
0:36	12. 54	7. 23	1675	49. 95	48. 94	0	0	71	0	71	0	71	0	0	0	9. 56	9. 56	G=1	12. 41	G=1	12. 40			1	1	機器動作		
						0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	22. 35	22. 35		0. 42		0. 47							
0:39	12. 54	7. 24	1675	50. 57	48. 89	0	0	71	0	71	0	71	0	0	0	9. 56	9. 56	G=1	12. 42	G=1	12. 40			1	1	機器動作		
						0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	22. 35	22. 35		0. 37		0. 47							
0:40	12. 54	7. 24	1675	50. 56	48. 89	0	0	71	0	71	0	71	0	0	0	9. 56	9. 56	G=1	12. 42	G=1	12. 40			1	1	定刻		
						0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	22. 35	22. 35		0. 37		0. 47							
0:50	12. 54	7. 25	1675	50. 65	48. 89	0	0	71	0	71	0	71	0	0	0	9. 56	9. 56	G=1	12. 42	G=1	12. 40			1	1	定刻		
						0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	0. 67	0. 00	22. 35	22. 35		0. 37		0. 47							
1:00	12. 55	7. 25	1684	53. 49	50. 56	0	0	71	0	71	0	71	0	0	0	9. 56	9. 56	G=1	12. 42	G=1	12. 40			1	1	定刻		
						0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	22. 46	22. 46		0. 42		0. 52							
1:00	12. 55	7. 25	1684	53. 49	50. 56	0	0	71	0	71	0	71	0	0	0	9. 56	9. 56	G=1	12. 42	G=1	12. 40	1 A		1	1	制御開始		
						0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	22. 46	22. 46		0. 42		0. 52							
1:02	12. 55	7. 25	1684	53. 93	60. 24	0	0	71	0	71	0	71	0	0	0	9. 09	9. 07	G=1	12. 42	G=1	12. 40	1 A		1	1	機器動作		
						0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	27. 20	27. 40		0. 42		0. 52							
1:10	12. 55	7. 27	1684	55. 51	60. 24	0	0	71	0	71	0	71	0	0	0	9. 09	9. 07	G=1	12. 42	G=1	12. 40			1	1	定刻		
						0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	27. 20	27. 40		0. 42		0. 52							
1:15	12. 55	7. 27	1684	56. 72	60. 19	0	0	71	0	71	0	71	0	0	0	9. 09	9. 07	G=1	12. 43	G=1	12. 40			1	1	機器動作		
						0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	27. 20	27. 40		0. 37		0. 52							
1:20	12. 55	7. 28	1684	58. 17	60. 19	0	0	71	0	71	0	71	0	0	0	9. 09	9. 07	G=1	12. 43	G=1	12. 40			1	1	定刻		
						0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	0. 94	0. 00	27. 20	27. 40		0. 37		0. 52							
1:27	12. 56	7. 29	1692	60. 83	61. 93	0	0	71	0	71	0	71	0	0	0	9. 09	9. 07	G=1	12. 43	G=1	12. 42			1	1	機器動作		
						1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	27. 32	27. 52		0. 42		0. 47							
1:30	12. 56	7. 29	1692	61. 66	61. 93	0	0	71	0	71	0	71	0	0	0	9. 09	9. 07	G=1	12. 43	G=1	12. 42			1	1	定刻		
						1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	27. 32	27. 52		0. 42		0. 47							
1:30	12. 56	7. 29	1692	61. 66	61. 93	0	0	71	0	71	0	71	0	0	0	9. 09	9. 07	G=1	12. 43	G=1	12. 42	1 A		1	1	制御開始		
						1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	27. 32	27. 52		0. 42		0. 47							
1:31	12. 56	7. 29	1692	51. 10	62. 53	0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 45	G=1	12. 42			1	2	機器動作		
						1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	1. 24	0. 00	27. 32	28. 21		0. 33		0. 47							
1:40	12. 57	7. 29	1701	51. 99	64. 46	0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 45	G=1	12. 42			1	2	定刻		
						1. 56	0. 00	1. 56	0. 00	1. 56	0. 00	1. 56	0. 00	1. 56	0. 00	27. 44	28. 33		0. 37		0. 52							
1:49	12. 58	7. 30	1710	53. 98	66. 40	0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 45	G=1	12. 44			1	2	機器動作		
						1. 90	0. 00	1. 90	0. 00	1. 90	0. 00	1. 90	0. 00	1. 90	0. 00	27. 56	28. 45		0. 42		0. 47							
1:50	12. 58	7. 30	1710	53. 98	66. 40	0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 45	G=1	12. 44			1	2	定刻		
						1. 90	0. 00	1. 90	0. 00	1. 90	0. 00	1. 90	0. 00	1. 90	0. 00	27. 56	28. 45		0. 42		0. 47							

加古川大堰操作記録Ⅰ

2024年04月09日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン ン	流入 量 判定	印字要因	
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本川 ゲート	微 調節 ゲート	魚 道 ゲート						
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸									
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段													
	T. Pm	T. Pm	10³m³	m³/s	m³/s																							
1:52	12. 58	7. 30	1710	54. 93	66. 31	0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 47	G=1	12. 44	1 C			1	2	機器動作	
2:00	12. 59	7. 31	1718	57. 98	68. 49	1. 90	0. 00	1. 90	0. 00	1. 90	0. 00	1. 90	0. 00	1. 90	0. 00	27. 56	28. 45		0. 33		0. 47				1	2	定刻	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 47	G=1	12. 44							
2:07	12. 60	7. 32	1727	60. 07	70. 68	2. 27	0. 00	2. 27	0. 00	2. 27	0. 00	2. 27	0. 00	2. 27	0. 00	27. 68	28. 57		0. 37		0. 52				1	2	機器動作	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 47	G=1	12. 46							
2:08	12. 60	7. 32	1727	61. 17	70. 59	2. 66	0. 00	2. 66	0. 00	2. 66	0. 00	2. 66	0. 00	2. 66	0. 00	27. 80	28. 69		0. 42		0. 47				1	2	機器動作	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 49	G=1	12. 46							
2:10	12. 60	7. 32	1727	61. 17	70. 59	2. 66	0. 00	2. 66	0. 00	2. 66	0. 00	2. 66	0. 00	2. 66	0. 00	27. 80	28. 69		0. 33		0. 47				1	2	定刻	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 49	G=1	12. 46							
2:18	12. 61	7. 33	1736	63. 36	72. 93	2. 66	0. 00	2. 66	0. 00	2. 66	0. 00	2. 66	0. 00	2. 66	0. 00	27. 80	28. 69		0. 33		0. 47				1	2	機器動作	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 50	G=1	12. 46							
2:20	12. 61	7. 33	1736	63. 36	72. 93	3. 07	0. 00	3. 07	0. 00	3. 07	0. 00	3. 07	0. 00	3. 07	0. 00	27. 92	28. 81		0. 33		0. 52				1	2	定刻	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 50	G=1	12. 46							
2:24	12. 62	7. 33	1745	63. 36	75. 25	3. 07	0. 00	3. 07	0. 00	3. 07	0. 00	3. 07	0. 00	3. 07	0. 00	27. 92	28. 81		0. 33		0. 52				1	2	機器動作	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 50	G=1	12. 48							
2:30	12. 63	7. 35	1753	64. 48	77. 84	3. 49	0. 00	3. 49	0. 00	3. 49	0. 00	3. 49	0. 00	3. 49	0. 00	28. 03	28. 93		0. 37		0. 47				1	2	定刻	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 50	G=1	12. 48							
2:38	12. 64	7. 36	1762	67. 90	80. 38	3. 94	0. 00	3. 94	0. 00	3. 94	0. 00	3. 94	0. 00	3. 94	0. 00	28. 15	29. 05		0. 42		0. 52				1	2	機器動作	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
2:40	12. 64	7. 36	1762	67. 90	80. 38	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	28. 27	29. 17		0. 47		0. 47				1	2	定刻	
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
2:40	12. 64	7. 36	1762	67. 90	80. 38	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	28. 27	29. 17		0. 47		0. 47	1 C		1	2	制御開始		
						0	0	71	0	71	0	71	0	0	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
2:41	12. 64	7. 36	1762	67. 90	96. 48	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	28. 27	29. 17		0. 47		0. 47	1 C		1	2	機器動作		
						15	0	71	0	71	0	71	0	15	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
2:50	12. 65	7. 45	1771	70. 26	99. 62	12. 45	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	12. 45	0. 00	28. 27	29. 17		0. 47		0. 47			1	2	定刻		
						15	0	71	0	71	0	71	0	15	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
2:50	12. 65	7. 45	1771	70. 26	99. 62	13. 13	0. 00	4. 88	0. 00	4. 88	0. 00	4. 88	0. 00	13. 13	0. 00	28. 39	29. 29		0. 52		0. 52	1 C		1	2	制御開始		
						15	0	71	0	71	0	71	0	15	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
2:50	12. 65	7. 45	1771	70. 26	117. 50	13. 13	0. 00	4. 88	0. 00	4. 88	0. 00	4. 88	0. 00	13. 13	0. 00	28. 39	29. 29		0. 52		0. 52	1 C		1	2	機器動作		
						27	0	71	0	71	0	71	0	27	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
3:00	12. 64	7. 54	1762	73. 81	114. 12	22. 07	0. 00	4. 88	0. 00	4. 88	0. 00	4. 88	0. 00	22. 07	0. 00	28. 39	29. 29		0. 52		0. 52			1	2	定刻		
						27	0	71	0	71	0	71	0	27	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
3:10	12. 64	7. 54	1762	77. 46	114. 12	21. 27	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	21. 27	0. 00	28. 27	29. 17		0. 47		0. 47			1	2	定刻		
						27	0	71	0	71	0	71	0	27	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
3:20	12. 65	7. 55	1771	82. 49	117. 50	21. 27	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	21. 27	0. 00	28. 27	29. 17		0. 47		0. 47			1	2	定刻		
						27	0	71	0	71	0	71	0	27	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
3:20	12. 65	7. 55	1771	82. 49	117. 50	22. 07	0. 00	4. 88	0. 00	4. 88	0. 00	4. 88	0. 00	22. 07	0. 00	28. 39	29. 29		0. 52		0. 52	1 C		1	2	制御開始		
						27	0	71	0	71	0	71	0	27	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
3:20	12. 65	7. 55	1771	82. 49	136. 40	22. 07	0. 00	4. 88	0. 00	4. 88	0. 00	4. 88	0. 00	22. 07	0. 00	28. 39	29. 29		0. 52		0. 52	1 C		1	2	機器動作		
						38	0	71	0	71	0	71	0	38	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
3:30	12. 64	7. 61	1762	97. 00	132. 82	31. 52	0. 00	4. 88	0. 00	4. 88	0. 00	4. 88	0. 00	31. 52	0. 00	28. 39	29. 29		0. 52		0. 52			1	2	定刻		
						38	0	71	0	71	0	71	0	38	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
3:40	12. 65	7. 62	1771	98. 35	136. 40	30. 62	0. 00	4. 40	0. 00	4. 40	0. 00	4. 40	0. 00	30. 62	0. 00	28. 27	29. 17		0. 47		0. 47			1	2	定刻		
						38	0	71	0	71	0	71	0	38	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
3:40	12. 65	7. 62	1771	98. 35	136. 40	31. 52	0. 00	4. 88	0. 00	4. 88	0. 00	4. 88	0. 00	31. 52	0. 00	28. 39	29. 29		0. 52		0. 52			1	2	定刻		
						38	0	71	0	71	0	71	0	38	0	9. 09	8. 99	G=1	12. 50	G=1	12. 50							
3:40	12. 65	7. 62	1771	98. 35	136. 40	31. 52	0. 00	4. 88	0. 00	4. 88	0. 00	4. 88	0. 00	31. 52	0. 00	28. 39	29. 29		0. 52		0. 52	1 C		1	2	制御開始		
						31. 52	0. 00	4. 88	0. 00	4. 88	0. 00	4. 88	0. 00	31. 52	0. 00	28. 39	29. 29		0. 52		0. 52							

加古川大堰操作記録Ⅰ

2024年04月09日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン ー ン	流入 量 判定	印字要因	
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト						
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸									
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段													
	T. Pm	T. Pm	10³m³	m³/s	m³/s																							
3:40	12.65	7.62	1771	98.35	155.44	48	0	71	0	71	0	71	0	48	0	9.09	8.99	G=1	12.50	G=1	12.50	1 C			1	2	機器動作	
3:50	12.64	7.67	1762	105.57	151.68	41.04	0.00	4.88	0.00	4.88	0.00	4.88	0.00	41.04	0.00	28.39	29.29		0.52		0.52				1	2	定刻	
						48	0	71	0	71	0	71	0	48	0	9.09	8.99	G=1	12.50	G=1	12.50							
4:00	12.65	7.69	1771	114.52	155.44	40.05	0.00	4.40	0.00	4.40	0.00	4.40	0.00	40.05	0.00	28.27	29.17		0.47		0.47				1	2	定刻	
						48	0	71	0	71	0	71	0	48	0	9.09	8.99	G=1	12.50	G=1	12.50							
4:00	12.65	7.69	1771	114.52	155.44	41.04	0.00	4.88	0.00	4.88	0.00	4.88	0.00	41.04	0.00	28.39	29.29		0.52		0.52	1 C			1	2	制御開始	
						48	0	71	0	71	0	71	0	48	0	9.09	8.99	G=1	12.50	G=1	12.50							
4:10	12.66	7.76	1780	123.88	180.49	41.04	0.00	4.88	0.00	4.88	0.00	4.88	0.00	41.04	0.00	28.39	29.29		0.52		0.52				1	2	定刻	
						58	0	71	0	71	0	71	0	58	0	9.09	8.99	G=1	12.43	G=1	12.50							
4:10	12.66	7.76	1780	123.88	180.49	52.43	0.00	5.38	0.00	5.38	0.00	5.38	0.00	52.43	0.00	28.51	29.41		0.99		0.58	1 C			1	2	制御開始	
						58	0	71	0	71	0	71	0	58	0	9.09	8.99	G=1	12.43	G=1	12.50							
4:20	12.65	7.84	1771	135.09	209.44	52.43	0.00	5.38	0.00	5.38	0.00	5.38	0.00	52.43	0.00	28.51	29.41		0.99		0.58				1	2	定刻	
						70	0	71	0	71	0	71	0	70	0	9.09	8.99	G=4	11.82	G=1	12.44							
4:21	12.65	7.85	1771	138.28	210.05	64.72	0.00	4.88	0.00	4.88	0.00	4.88	0.00	64.72	0.00	28.39	29.29		6.81		0.87	1 C			1	2	制御終了	
						70	0	71	0	71	0	71	0	70	0	9.09	8.99	G=4	11.82	G=1	12.35							
4:21	12.65	7.85	1771	138.28	210.05	64.72	0.00	4.88	0.00	4.88	0.00	4.88	0.00	64.72	0.00	28.39	29.29		6.81		1.48	1 C			1	2	制御不能	
						70	0	71	0	71	0	71	0	70	0	9.09	8.99	G=4	11.82	G=1	12.35							
4:22	12.65	7.85	1771	138.28	210.51	64.72	0.00	4.88	0.00	4.88	0.00	4.88	0.00	64.72	0.00	28.39	29.29		6.81		1.48	1 C			1	2	制御開始	
						70	0	71	0	71	0	71	0	70	0	9.09	8.99	G=4	11.82	G=1	12.29							
4:30	12.64	7.87	1762	151.45	221.64	64.72	0.00	4.88	0.00	4.88	0.00	4.88	0.00	64.72	0.00	28.39	29.29		6.81		1.94				1	2	定刻	
						70	0	71	0	71	0	71	0	70	0	9.09	8.99	G=4	11.10	G=4	11.82							
4:40	12.65	7.92	1771	170.61	236.50	63.56	0.00	4.40	0.00	4.40	0.00	4.40	0.00	63.56	0.00	28.27	29.17		17.20		6.68				1	2	定刻	
						70	0	71	0	71	0	71	0	70	0	9.09	8.99	G=4	11.10	G=4	11.10							
4:40	12.65	7.92	1771	167.00	236.50	64.72	0.00	4.88	0.00	4.88	0.00	4.88	0.00	64.72	0.00	28.39	29.29		17.37		17.37	1 C			1	2	機器動作	
						70	0	71	0	71	0	71	0	70	0	9.09	8.99	G=4	11.10	G=4	11.10							
4:40	12.65	7.92	1771	170.61	236.50	64.72	0.00	4.88	0.00	4.88	0.00	4.88	0.00	64.72	0.00	28.39	29.29		17.37		17.37				1	2	制御開始	
						70	0	71	0	71	0	71	0	70	0	9.09	8.99	G=4	11.10	G=4	11.10							
4:42	12.64	7.94	1762	174.24	271.67	64.72	0.00	4.88	0.00	4.88	0.00	4.88	0.00	64.72	0.00	28.39	29.29		17.37		17.37				1	2	機器動作	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	10.50	G=4	11.10							
4:50	12.62	8.03	1745	183.56	272.41	77.83	0.00	4.40	0.00	4.40	0.00	4.40	0.00	77.83	0.00	28.27	29.17		28.17		17.20				1	2	定刻	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	10.50	G=4	10.57							
4:50	12.62	8.03	1745	183.56	273.77	75.39	0.00	3.49	0.00	3.49	0.00	3.49	0.00	75.39	0.00	28.03	28.93		27.78		26.42				1	2	機器動作	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	10.50	G=4	10.50							
4:55	12.61	8.05	1736	189.28	279.83	75.39	0.00	3.49	0.00	3.49	0.00	3.49	0.00	75.39	0.00	28.03	28.93		27.78		27.78				1	2	機器動作	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	10.00	G=4	10.50							
5:00	12.61	8.06	1736	195.09	282.42	74.18	0.00	3.07	0.00	3.07	0.00	3.07	0.00	74.18	0.00	27.92	28.81		37.95		27.58				1	2	定刻	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	10.00	G=4	10.37							
5:02	12.60	8.07	1727	197.08	285.87	74.18	0.00	3.07	0.00	3.07	0.00	3.07	0.00	74.18	0.00	27.92	28.81		37.95		30.17				1	2	機器動作	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	10.00	G=4	10.00							
5:07	12.60	8.07	1727	202.93	296.08	72.97	0.00	2.66	0.00	2.66	0.00	2.66	0.00	72.97	0.00	27.80	28.69		37.73		37.73				1	2	機器動作	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	9.55	G=4	10.00							
5:10	12.59	8.08	1718	206.91	293.12	72.97	0.00	2.66	0.00	2.66	0.00	2.66	0.00	72.97	0.00	27.80	28.69		47.94		37.73				1	2	定刻	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	9.55	G=4	9.94							
5:12	12.59	8.09	1718	210.93	302.00	71.77	0.00	2.27	0.00	2.27	0.00	2.27	0.00	71.77	0.00	27.68	28.57		47.70		38.82				1	2	機器動作	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	9.55	G=4	9.55							
5:20	12.59	8.10	1718	217.06	302.00	71.77	0.00	2.27	0.00	2.27	0.00	2.27	0.00	71.77	0.00	27.68	28.57		47.70		47.70				1	2	機器動作	
						82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	9.55	G=4	9.55							
						71.77	0.00	2.27	0.00	2.27	0.00	2.27	0.00	71.77	0.00	27.68	28.57		47.70		47.70					1	2	定刻

加古川大堰操作記録Ⅰ

2024年04月09日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン ン	流入 量 判定	印字要因
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト					
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸								
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段												
	T. Pm	T. Pm	10³m³	m³/s	m³/s																						
5:30	12.60	8.10	1727	229.57	306.29	82	0	71	0	71	0	71	0	82	0	9.09	8.99	G=4	9.55	G=4	9.55	1 C			1	2	定刻
5:30	12.60	8.10	1727	229.57	306.29	72.97	0.00	2.66	0.00	2.66	0.00	2.66	0.00	72.97	0.00	27.80	28.69		47.94		47.94				1	2	制御開始
5:30	12.60	8.10	1727	229.57	336.09	72.97	0.00	2.66	0.00	2.66	0.00	2.66	0.00	72.97	0.00	27.80	28.69		47.94		47.94	1 C			1	2	機器動作
5:40	12.59	8.16	1718	240.26	331.64	93	0	71	0	71	0	71	0	93	0	9.09	8.99	G=4	9.55	G=4	9.55	1 C			1	2	定刻
5:50	12.59	8.17	1718	251.25	331.64	87.87	0.00	2.66	0.00	2.66	0.00	2.66	0.00	87.87	0.00	27.80	28.69		47.94		47.94				1	2	定刻
6:00	12.60	8.18	1727	262.45	336.09	93	0	71	0	71	0	71	0	93	0	9.09	8.99	G=4	9.55	G=4	9.55	1 C			1	2	定刻
6:00	12.60	8.18	1727	262.45	336.09	86.59	0.00	2.27	0.00	2.27	0.00	2.27	0.00	86.59	0.00	27.68	28.57		47.70		47.70				1	2	定刻
6:00	12.60	8.18	1727	262.45	336.09	93	0	71	0	71	0	71	0	93	0	9.09	8.99	G=4	9.55	G=4	9.55	1 C			1	2	定刻
6:00	12.60	8.18	1727	262.45	367.69	87.87	0.00	2.66	0.00	2.66	0.00	2.66	0.00	87.87	0.00	27.80	28.69		47.94		47.94				1 C		
6:10	12.60	8.25	1727	271.56	367.69	107	0	71	0	71	0	71	0	107	0	9.09	8.99	G=4	9.55	G=4	9.55	1 C			1	2	機器動作
6:20	12.61	8.27	1736	283.27	372.34	103.67	0.00	2.66	0.00	2.66	0.00	2.66	0.00	103.67	0.00	27.80	28.69		47.94		47.94				1	2	定刻
6:20	12.61	8.27	1736	283.27	372.34	107	0	71	0	71	0	71	0	107	0	9.09	8.99	G=4	9.55	G=4	9.55	1 C			1	2	定刻
6:20	12.61	8.27	1736	283.27	372.34	103.67	0.00	2.66	0.00	2.66	0.00	2.66	0.00	103.67	0.00	27.80	28.69		47.94		47.94				1 C		
6:21	12.61	8.27	1736	283.27	405.76	107	0	71	0	71	0	71	0	107	0	9.09	8.99	G=4	9.55	G=4	9.55	1 C			1	2	機器動作
6:30	12.61	8.32	1736	295.30	405.76	129	0	71	0	71	0	71	0	129	0	9.09	8.99	G=4	9.55	G=4	9.55				1 C		
6:40	12.62	8.34	1745	307.64	410.57	121.73	0.00	3.07	0.00	3.07	0.00	3.07	0.00	121.73	0.00	27.92	28.81		48.18		48.18	1 C			1	2	定刻
6:40	12.62	8.34	1745	307.64	410.57	129	0	71	0	71	0	71	0	129	0	9.09	8.99	G=4	9.55	G=4	9.55				1 C		
6:41	12.62	8.34	1745	310.02	419.21	123.16	0.00	3.49	0.00	3.49	0.00	3.49	0.00	123.16	0.00	28.03	28.93		48.41		48.41	1 C			1	2	機器動作
6:50	12.63	8.36	1753	322.70	424.18	144	0	71	0	71	0	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55				1 C		
6:56	12.64	8.37	1762	330.23	429.20	127.48	0.00	3.49	0.00	3.49	0.00	3.49	0.00	127.48	0.00	28.03	28.93		48.41		48.41	1 C			1	2	制御終了
6:56	12.64	8.37	1762	330.23	429.20	144	0	71	0	71	0	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55				2 E		
7:00	12.65	8.38	1771	338.13	434.26	130.39	0.00	4.40	0.00	4.40	0.00	4.40	0.00	130.39	0.00	28.27	29.17		48.89		48.89	2 E			2	2	定刻
7:00	12.65	8.38	1771	338.13	434.26	144	0	71	0	71	0	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55				2 E		
7:05	12.66	8.38	1780	343.36	505.89	131.85	0.00	4.88	0.00	4.88	0.00	4.88	0.00	131.85	0.00	28.39	29.29		49.12		49.12	2 E			2	2	機器動作
7:10	12.62	8.48	1745	348.64	485.41	144	0	71	0	0	25	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55				2 E		
7:10	12.62	8.48	1745	348.64	485.41	127.48	0.00	3.49	0.00	0.00	69.69	3.49	0.00	127.48	0.00	28.03	28.93		48.41		48.41	2 E			2	2	制御開始
						144	0	71	0	0	25	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55				2 E		
						127.48	0.00	3.49	0.00	0.00	69.69	3.49	0.00	127.48	0.00	28.03	28.93		48.41		48.41						

加古川大堰操作記録Ⅰ

2024年04月09日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン	流入 量判定	印字要因	
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本川 ゲート	微 調節 ゲート	魚 道 ゲート						
						1号		2号		3号		4号		5号		左岸	右岸	左岸	右岸									
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段													
	T. Pm	T. Pm	10³m³	m³/s	m³/s																							
7:11	12.62	8.49	1745	348.64	566.82	144	0	71	0	0	50	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	機器動作	
7:20	12.54	8.64	1675	356.79	531.52	127.48	0.00	3.49	0.00	0.00	151.10	3.49	0.00	127.48	0.00	28.03	28.93		48.41		48.41				2	2	定刻	
						144	0	71	0	0	50	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55							
7:20	12.54	8.64	1675	356.79	531.52	116.07	0.00	0.67	0.00	0.00	149.92	0.67	0.00	116.07	0.00	27.09	27.97		46.53		46.53			2 E		2	2	制御開始
						144	0	71	0	0	50	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
7:25	12.51	8.65	1649	362.18	600.93	116.07	0.00	0.67	0.00	0.00	149.92	0.67	0.00	116.07	0.00	27.09	27.97		46.53		46.53			2 E		2	2	機器動作
						144	0	0	30	0	50	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
7:30	12.42	8.72	1574	365.08	566.33	111.88	0.00	0.00	81.61	0.00	149.47	0.08	0.00	111.88	0.00	26.73	27.62		45.83		45.83			2 E		2	2	定刻
						144	0	0	30	0	50	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
7:30	12.42	8.72	1574	365.08	566.33	99.64	0.00	0.00	79.15	0.00	148.13	0.00	0.00	99.64	0.00	25.69	26.56		43.76		43.76			2 E		2	2	制御開始
						144	0	0	30	0	50	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
7:31	12.42	8.73	1574	365.08	635.31	99.64	0.00	0.00	79.15	0.00	148.13	0.00	0.00	99.64	0.00	25.69	26.56		43.76		43.76			2 E		2	2	機器動作
						144	0	0	50	0	50	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
7:40	12.29	8.81	1470	370.53	588.86	99.64	0.00	0.00	148.13	0.00	148.13	0.00	0.00	99.64	0.00	25.69	26.56		43.76		43.76			2 E		2	2	定刻
						144	0	0	50	0	50	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
7:40	12.29	8.81	1470	370.53	588.86	82.80	0.00	0.00	146.18	0.00	146.18	0.00	0.00	82.80	0.00	24.20	25.06		40.82		40.82			2 E		2	2	制御開始
						144	0	0	50	0	50	71	0	146	0	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
7:45	12.24	8.80	1430	376.03	647.03	82.80	0.00	0.00	146.18	0.00	146.18	0.00	0.00	82.80	0.00	24.20	25.06		40.82		40.82			2 E		2	2	機器動作
						144	0	0	50	0	50	0	30	146	0	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
7:50	12.13	8.87	1342	378.59	607.70	76.61	0.00	0.00	145.42	0.00	145.42	0.00	75.43	76.61	0.00	23.63	24.49		39.71		39.71			2 E		2	2	定刻
						144	0	0	50	0	50	0	30	146	0	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
7:50	12.13	8.87	1342	378.59	607.70	63.56	0.00	0.00	143.73	0.00	143.73	0.00	72.86	63.56	0.00	22.40	23.26		37.30		37.30			2 E		2	2	制御開始
						144	0	0	50	0	50	0	30	146	0	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
7:58	12.11	8.76	1326	384.15	684.07	63.56	0.00	0.00	143.73	0.00	143.73	0.00	72.86	63.56	0.00	22.40	23.26		37.30		37.30			2 E		2	2	機器動作
						0	50	0	50	0	50	0	30	0	25	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
8:00	11.97	8.85	1221	384.15	640.76	0.00	143.42	0.00	143.42	0.00	143.42	0.00	74.26	0.00	60.61	22.18	23.04		36.86		36.86			2 E		2	2	定刻
						0	50	0	50	0	50	0	30	0	25	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
8:00	11.97	8.85	1221	384.15	640.76	0.00	133.97	0.00	133.97	0.00	133.97	0.00	70.92	0.00	58.01	20.66	21.50		33.88		33.88			2 E		2	2	制御開始
						0	50	0	50	0	50	0	30	0	25	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
8:01	11.95	8.88	1206	389.76	700.79	0.00	133.97	0.00	133.97	0.00	133.97	0.00	70.92	0.00	58.01	20.66	21.50		33.88		33.88			2 E		2	2	機器動作
						0	50	0	50	0	50	0	30	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
8:10	11.75	9.04	1061	395.39	628.77	0.00	130.49	0.00	130.49	0.00	130.49	0.00	70.19	0.00	130.49	20.44	21.28		33.46		33.46			2 E		2	2	定刻
						0	50	0	50	0	50	0	30	0	50	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
8:20	11.53	9.02	909	403.31	589.36	0.00	116.90	0.00	116.90	0.00	116.90	0.00	64.94	0.00	116.90	18.34	19.15		29.37		29.37			2 E		2	2	定刻
						0	50	0	50	0	50	0	30	0	50	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
8:30	11.35	8.97	795	414.42	562.05	0.00	111.08	0.00	111.08	0.00	111.08	0.00	61.89	0.00	111.08	16.11	16.90		25.07		25.07			2 E		2	2	定刻
						0	50	0	50	0	50	0	30	0	50	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
8:30	11.35	8.97	795	414.42	562.05	0.00	107.33	0.00	107.33	0.00	107.33	0.00	59.78	0.00	107.33	14.36	15.13		21.73		21.73			2 E		2	2	制御開始
						0	50	0	50	0	50	0	30	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
8:31	11.34	8.97	789	414.42	635.62	0.00	107.33	0.00	107.33	0.00	107.33	0.00	59.78	0.00	107.33	14.36	15.13		21.73		21.73			2 E		2	2	機器動作
						0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2		
8:40	11.12	9.01	655	422.61	578.96	0.00	107.02	0.00	107.02	0.00	135.14	0.00	107.02	0.00	107.02	14.27	15.03		21.55		21.55			2 E		2	2	定刻
						0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
8:50	10.96	8.96	565	430.93	552.17	0.00	98.71	0.00	98.71	0.00	123.53	0.00	98.71	0.00	98.71	12.23	12.96		17.70		17.70			2 E		2	2	定刻
						0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
9:00	10.84	8.91	500	445.33	534.22	0.00	95.16	0.00	95.16	0.00	119.06	0.00	95.16	0.00	95.16	10.81	11.52		15.07		15.07			2 E		2	2	定刻
						0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55				2	2		
						0.00	92.84	0.00	92.84	0.00	116.21	0.00	92.84	0.00	92.84	9.79	10.48		13.19		13.19					2	2	定刻

加古川大堰操作記録Ⅰ

2024年04月09日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン ン	流入 量 判定	印字要因
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本川 ゲート	微 調節 ゲート	魚 道 ゲート					
						1号		2号		3号		4号		5号		左岸	右岸	左岸	右岸								
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段												
	T. Pm	T. Pm	10³m³	m³/s	m³/s																						
9:10	10.76	8.87	460	456.72	523.41	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	定刻
9:10	10.76	8.87	460	456.72	523.41	0.00	91.48	0.00	91.48	0.00	114.60	0.00	91.48	0.00	91.48	9.12	9.81		11.98		11.98				2	2	制御開始
9:11	10.75	8.87	455	459.81	521.07	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
9:12	10.75	8.87	455	459.81	521.07	0.00	91.13	0.00	91.13	0.00	114.13	0.00	91.13	0.00	91.13	9.04	9.72		11.83		11.83				2 E		
9:13	10.74	8.86	450	459.66	520.71	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
9:14	10.74	8.86	450	462.75	520.71	0.00	91.14	0.00	91.14	0.00	114.19	0.00	91.14	0.00	91.14	8.96	9.64		11.68		11.68				2 E		
9:20	10.71	8.84	435	468.57	517.66	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	定刻
9:20	10.71	8.84	435	468.57	517.66	0.00	90.81	0.00	90.81	0.00	113.83	0.00	90.81	0.00	90.81	8.72	9.39		11.24		11.24				2 E		
9:21	10.71	8.84	435	468.57	517.66	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
9:22	10.71	8.84	435	468.57	517.66	0.00	90.81	0.00	90.81	0.00	113.83	0.00	90.81	0.00	90.81	8.72	9.39		11.24		11.24				2 E		
9:23	10.70	8.84	430	468.57	515.31	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
9:24	10.70	8.83	430	471.57	517.32	0.00	90.45	0.00	90.45	0.00	113.36	0.00	90.45	0.00	90.45	8.64	9.31		11.10		11.10				2 E		
9:30	10.69	8.83	425	477.62	514.94	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	定刻
9:30	10.69	8.83	425	477.62	514.94	0.00	90.46	0.00	90.46	0.00	113.42	0.00	90.46	0.00	90.46	8.55	9.23		10.95		10.95				2 E		
9:31	10.69	8.82	425	477.62	516.95	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
9:32	10.68	8.82	420	477.62	514.59	0.00	90.83	0.00	90.83	0.00	113.95	0.00	90.83	0.00	90.83	8.55	9.23		10.95		10.95				2 E		
9:33	10.68	8.82	420	480.67	514.59	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
9:34	10.68	8.82	420	480.67	514.59	0.00	90.47	0.00	90.47	0.00	113.47	0.00	90.47	0.00	90.47	8.47	9.15		10.81		10.81				2 E		
9:40	10.68	8.82	420	486.81	514.59	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	定刻
9:40	10.68	8.82	420	486.81	514.59	0.00	90.47	0.00	90.47	0.00	113.47	0.00	90.47	0.00	90.47	8.47	9.15		10.81		10.81				2 E		
9:41	10.68	8.82	420	483.75	514.59	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
9:42	10.68	8.81	420	483.75	516.61	0.00	90.47	0.00	90.47	0.00	113.47	0.00	90.47	0.00	90.47	8.47	9.15		10.81		10.81				2 E		
9:43	10.67	8.81	415	483.75	514.24	0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
9:44	10.68	8.81	420	486.84	516.61	0.00	90.48	0.00	90.48	0.00	113.53	0.00	90.48	0.00	90.48	8.39	9.06		10.67		10.67				2 E		
						0	50	0	50	0	60	0	50	0	50	9.09	8.99	G=4	9.55	G=4	9.55	2 E			2	2	制御開始
						0.00	90.84	0.00	90.84	0.00	114.01	0.00	90.84	0.00	90.84	8.47	9.15		10.81		10.81						