

加古川大堰操作記録Ⅰ

2017年08月18日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 パター ン	流入 量判 定	印字要因	
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト						
						1号		2号		3号		4号		5号		左岸	右岸	左岸	右岸									
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段													
	T. Pm	T. Pm	10³m³	m³/s	m³/s																							
0:10	12.47	7.02	1615	21.88	13.96	0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.35				1	1	定刻	
0:20	12.47	7.01	1615	21.88	13.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.37				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.35							
0:29	12.47	7.01	1615	21.88	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.37				1	1	機器動作	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
0:30	12.47	7.01	1615	21.88	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
0:40	12.47	7.01	1615	21.88	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
0:50	12.47	7.01	1615	21.90	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
1:00	12.47	7.01	1615	21.91	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
1:10	12.47	7.01	1615	21.93	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
1:20	12.47	7.01	1615	21.94	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
1:30	12.47	7.01	1615	21.96	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
1:40	12.47	7.01	1615	21.96	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
1:50	12.47	7.01	1615	21.97	14.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
2:00	12.46	7.01	1607	20.86	13.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.61	6.61		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
2:00	12.46	7.01	1607	20.86	13.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.52	6.52		0.33		0.42				1	1	制御開始	
						0	0	71	0	71	0	71	0	0	0	11.24	11.24	G=1	12.35	G=1	12.33							
2:01	12.46	7.01	1607	20.63	10.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.52	6.52		0.33		0.42				1	1	機器動作	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
2:10	12.46	7.00	1607	19.47	10.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.06	5.06		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
2:20	12.46	6.99	1607	18.94	10.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.06	5.06		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
2:30	12.46	6.98	1607	18.42	10.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.06	5.06		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
2:40	12.46	6.98	1607	17.89	10.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.06	5.06		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
2:50	12.46	6.98	1607	17.37	10.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.06	5.06		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
3:00	12.46	6.98	1607	17.95	10.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.06	5.06		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
3:10	12.46	6.98	1607	18.82	10.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.06	5.06		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
3:20	12.47	6.98	1615	19.04	11.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.06	5.06		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
3:30	12.47	6.98	1615	21.06	11.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.13	5.13		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
						0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.13	5.13		0.37		0.47							

加古川大堰操作記録Ⅰ

2017年08月18日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン ン	流入 量 判定	印字要因	
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本川 ゲート	微 調節 ゲート	魚 道 ゲート						
						1号		2号		3号		4号		5号		左岸	右岸	左岸	右岸									
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段													
	T. Pm	T. Pm	10³m³	m³/s	m³/s																							
3:40	12.47	6.98	1615	21.10	11.10	0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33				1	1	定刻	
3:50	12.47	6.98	1615	21.14	11.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.13	5.13		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
4:00	12.47	6.98	1615	21.18	11.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.13	5.13		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
4:10	12.47	6.98	1615	21.22	11.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.13	5.13		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
4:20	12.47	6.98	1615	21.05	11.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.13	5.13		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
4:30	12.47	6.98	1615	19.07	11.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.13	5.13		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
4:40	12.47	6.98	1615	19.08	11.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.13	5.13		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.33							
4:45	12.47	6.98	1615	19.08	11.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.13	5.13		0.37		0.47				1	1	機器動作	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.35							
4:50	12.48	6.98	1623	19.30	11.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.21	5.21		0.42		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.35	G=1	12.35							
4:55	12.48	6.98	1623	20.42	11.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.21	5.21		0.33		0.42				1	1	機器動作	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.37	G=1	12.35							
5:00	12.48	6.98	1623	21.31	11.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.21	5.21		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.37	G=1	12.35							
5:10	12.48	6.98	1623	21.32	11.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.21	5.21		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.37	G=1	12.35							
5:20	12.48	6.98	1623	21.31	11.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.21	5.21		0.33		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.37	G=1	12.35							
5:30	12.49	6.98	1632	22.31	11.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.21	5.21		0.33		0.42				1	1	機器動作	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.37	G=1	12.35							
5:40	12.49	6.98	1632	23.85	11.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.28	5.28		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.37	G=1	12.35							
5:50	12.49	6.98	1632	23.66	11.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.28	5.28		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.37	G=1	12.35							
6:00	12.49	6.98	1632	21.67	11.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.28	5.28		0.37		0.47				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.37	G=1	12.35							
6:05	12.49	6.98	1632	21.68	11.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.28	5.28		0.37		0.47				1	1	機器動作	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.37	G=1	12.37							
6:10	12.50	6.98	1640	22.35	11.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.36	5.36		0.37		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.38	G=1	12.37							
6:10	12.50	6.98	1640	22.35	11.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.36	5.36		0.37		0.42				1	1	機器動作	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.38	G=1	12.37							
6:20	12.50	6.98	1640	23.93	11.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.36	5.36		0.37		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.38	G=1	12.37							
6:30	12.50	6.98	1640	22.96	11.51	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	5.36	5.36		0.37		0.42				1	1	定刻	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.38	G=1	12.37							
6:33	12.51	6.98	1649	22.72	12.06	0.08	0.00	0.08	0.00	0.08	0.00	0.08	0.00	0.08	0.00	5.43	5.43		0.33		0.47				1	1	機器動作	
						0	0	71	0	71	0	71	0	0	0	11.44	11.44	G=1	12.40	G=1	12.37							
6:40	12.51	6.98	1649	23.75	12.06	0.08	0.00	0.08	0.00	0.08	0.00	0.08	0.00	0.08	0.00	5.43	5.43		0.33		0.47				1	1	定刻	

加古川大堰操作記録Ⅰ

2017年08月18日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 パター ン	流入 量判 定	印字要因
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本川 ゲート	微調 節ゲート	魚道 ゲート					
						1号		2号		3号		4号		5号		左岸	右岸	左岸	右岸								
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段												
	T. Pm	T. Pm	10³m³	m³/s	m³/s																						
6:50	12. 51	6. 98	1649	24. 10	11. 96	0	0	71	0	71	0	71	0	0	0	11. 44	11. 44	G=1	12. 40	G=1	12. 39				1	1	定刻
						0.08	0.00	0.08	0.00	0.08	0.00	0.08	0.00	0.08	0.00	5. 43	5. 43		0.33		0.37						
6:50	12. 51	6. 98	1649	24. 10	11. 96	0	0	71	0	71	0	71	0	0	0	11. 44	11. 44	G=1	12. 40	G=1	12. 39				1	1	機器動作
						0.08	0.00	0.08	0.00	0.08	0.00	0.08	0.00	0.08	0.00	5. 43	5. 43		0.33		0.37						
7:00	12. 52	6. 98	1657	26. 29	13. 01	0	0	71	0	71	0	71	0	0	0	11. 44	11. 44	G=1	12. 40	G=1	12. 39				1	1	定刻
						0.24	0.00	0.24	0.00	0.24	0.00	0.24	0.00	0.24	0.00	5. 51	5. 51		0.37		0.42						
7:09	12. 53	6. 99	1666	27. 09	14. 18	0	0	71	0	71	0	71	0	0	0	11. 44	11. 44	G=1	12. 42	G=1	12. 39				1	1	機器動作
						0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	5. 59	5. 59		0.33		0.47						
7:10	12. 53	6. 99	1666	27. 16	14. 18	0	0	71	0	71	0	71	0	0	0	11. 44	11. 44	G=1	12. 42	G=1	12. 39				1	1	定刻
						0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	5. 59	5. 59		0.33		0.47						
7:10	12. 53	6. 99	1666	27. 16	14. 18	0	0	71	0	71	0	71	0	0	0	11. 44	11. 44	G=1	12. 42	G=1	12. 39	1 A			1	1	制御開始
						0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	5. 59	5. 59		0.33		0.47						
7:12	12. 53	6. 99	1666	27. 30	19. 10	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 42	G=1	12. 39	1 A			1	1	機器動作
						0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	8. 05	8. 05		0.33		0.47						
7:20	12. 53	7. 02	1666	27. 93	19. 10	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 42	G=1	12. 39				1	1	定刻
						0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	8. 05	8. 05		0.33		0.47						
7:25	12. 53	7. 03	1666	28. 57	19. 00	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 42	G=1	12. 41				1	1	機器動作
						0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	0.44	0.00	8. 05	8. 05		0.33		0.37						
7:28	12. 56	7. 04	1692	30. 46	23. 69	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 44	G=1	12. 41				1	1	機器動作
						1.24	0.00	1.24	0.00	1.24	0.00	1.24	0.00	1.24	0.00	8. 30	8. 30		0.37		0.52						
7:28	12. 56	7. 04	1692	30. 46	23. 59	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 44	G=1	12. 43				1	1	機器動作
						1.24	0.00	1.24	0.00	1.24	0.00	1.24	0.00	1.24	0.00	8. 30	8. 30		0.37		0.42						
7:30	12. 60	7. 04	1727	33. 71	31. 54	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 46	G=1	12. 46				1	1	定刻
						2.66	0.00	2.66	0.00	2.66	0.00	2.66	0.00	2.66	0.00	8. 65	8. 65		0.47		0.47						
7:32	12. 65	7. 05	1771	39. 02	43. 64	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 50	G=1	12. 50				1	1	機器動作
						4.88	0.00	4.88	0.00	4.88	0.00	4.88	0.00	4.88	0.00	9. 10	9. 10		0.52		0.52						
7:40	12. 85	7. 32	1953	85. 42	112. 65	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 50	G=1	12. 50				1	1	定刻
						17.41	0.00	17.41	0.00	17.41	0.00	17.41	0.00	17.41	0.00	10.94	10.94		1.86		1.86						
7:43	12. 92	7. 45	2018	107. 67	142. 52	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 50	G=1	12. 50	1 B			1	1	制御終了
						22.88	0.00	22.88	0.00	22.88	0.00	22.88	0.00	22.88	0.00	11.61	11.61		2.45		2.45						
7:43	12. 92	7. 45	2018	107. 67	142. 52	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 50	G=1	12. 50	1 B			1	1	制御不能
						22.88	0.00	22.88	0.00	22.88	0.00	22.88	0.00	22.88	0.00	11.61	11.61		2.45		2.45						
7:44	12. 94	7. 50	2036	115. 20	151. 51	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 50	G=1	12. 50	1 C			1	1	制御開始
						24.53	0.00	24.53	0.00	24.53	0.00	24.53	0.00	24.53	0.00	11.80	11.80		2.63		2.63						
7:50	13. 06	7. 76	2148	101. 58	209. 67	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 50	G=1	12. 50				1	2	定刻
						35.23	0.00	35.23	0.00	35.23	0.00	35.23	0.00	35.23	0.00	12.99	12.99		3.77		3.77						
7:52	13. 10	7. 86	2185	137. 86	230. 49	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	12. 50	G=1	12. 50		3		1	2	機器動作
						39.07	0.00	39.07	0.00	39.07	0.00	39.07	0.00	39.07	0.00	13.39	13.39		4.18		4.18						
8:00	13. 23	8. 20	2307	272. 83	316. 17	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=1	11. 99	G=1	12. 01				1	2	定刻
						52.43	0.00	52.43	0.00	52.43	0.00	52.43	0.00	52.43	0.00	14.73	14.73		12.43		12.13						
8:09	13. 33	8. 48	2401	370. 71	382. 78	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=4	11. 82	G=4	11. 82	1 C			1	2	制御終了
						63.56	0.00	63.56	0.00	63.56	0.00	63.56	0.00	63.56	0.00	15.79	15.79		16.70		16.70						
8:09	13. 33	8. 48	2401	370. 71	382. 78	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=4	11. 82	G=4	11. 82	1 C			1	2	制御不能
						63.56	0.00	63.56	0.00	63.56	0.00	63.56	0.00	63.56	0.00	15.79	15.79		16.70		16.70						
8:10	13. 34	8. 51	2411	380. 72	389. 14	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=4	11. 82	G=4	11. 82				1	2	定刻
						64.72	0.00	64.72	0.00	64.72	0.00	64.72	0.00	64.72	0.00	15.90	15.90		16.87		16.87						
8:10	13. 34	8. 51	2411	380. 72	389. 14	0	0	71	0	71	0	71	0	0	0	11. 12	11. 12	G=4	11. 82	G=4	11. 82	J			1	2	制御開始
						64.72	0.00	64.72	0.00	64.72	0.00	64.72	0.00	64.72	0.00	15.90	15.90		16.87		16.87						

加古川大堰

操 作 モ ー ド	1 文字目：運転モード		2 文字目：制御モード			制 御 パ タ ー ン	1：平水 2：洪水	流 入 量 判 定	1：堰水位 換算流入量 2：上流流入量	G	最高天端高 1～3：魚道ゲートグループNo 4：制水ゲート
	1：自動	A：定水位Ⅰ（微調節）	E：事前放流	I：貯留回復Ⅱ							
	2：半自動	B：全開（微調節）	F：定水位	J：開度一回							
	3：遠方手動	C：定水位Ⅰ（調節上段）	G：全開								
	4：機側	D：設定流量	H：貯留回復Ⅰ								

加古川大堰操作記録Ⅰ

2017年08月18日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 ボタン	流入 量判定	印字要因	
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本川 ゲート	微 調節 ゲート	魚 道 ゲート						
						1号		2号		3号		4号		5号		左岸	右岸	左岸	右岸									
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段													
	T. Pm	T. Pm	10³m³	m³/s	m³/s																							
8:35	13.19	9.23	2270	526.69	686.80	145	0	71	0	0	0	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55	J			2	2	制御開始	
8:37	13.19	9.20	2270	530.23	846.04	218.41	0.00	48.18	0.00	0.00	0.00	48.18	0.00	218.41	0.00	14.31	14.31								1	2	制御終了	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
8:37	13.19	9.20	2270	530.23	846.04	218.41	0.00	48.18	0.00	0.00	159.24	48.18	0.00	218.41	0.00	14.31	14.31					J			1	2	機器動作	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
8:40	13.10	9.29	2185	542.23	789.30	218.41	0.00	48.18	0.00	0.00	159.24	48.18	0.00	218.41	0.00	14.31	14.31								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
8:50	13.04	9.34	2129	566.63	752.68	203.00	0.00	39.07	0.00	0.00	157.98	39.07	0.00	203.00	0.00	13.39	13.39								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
9:00	12.99	9.31	2083	595.79	722.87	192.94	0.00	33.36	0.00	0.00	157.14	33.36	0.00	192.94	0.00	12.79	12.79								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
9:10	12.97	9.27	2064	621.37	711.17	184.68	0.00	28.83	0.00	0.00	156.43	28.83	0.00	184.68	0.00	12.29	12.29								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
9:20	12.95	9.25	2046	634.79	699.58	181.41	0.00	27.09	0.00	0.00	156.15	27.09	0.00	181.41	0.00	12.09	12.09								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
9:30	12.95	9.24	2046	648.37	699.58	178.16	0.00	25.38	0.00	0.00	155.86	25.38	0.00	178.16	0.00	11.90	11.90								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
9:40	12.95	9.24	2046	657.66	699.58	178.16	0.00	25.38	0.00	0.00	155.86	25.38	0.00	178.16	0.00	11.90	11.90								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
9:50	12.95	9.24	2046	671.49	699.58	178.16	0.00	25.38	0.00	0.00	155.86	25.38	0.00	178.16	0.00	11.90	11.90								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
10:00	12.95	9.24	2046	675.97	699.58	178.16	0.00	25.38	0.00	0.00	155.86	25.38	0.00	178.16	0.00	11.90	11.90								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
10:10	12.95	9.24	2046	676.47	699.58	178.16	0.00	25.38	0.00	0.00	155.86	25.38	0.00	178.16	0.00	11.90	11.90								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	11.12	G=4	9.55	G=4	9.55							
10:20	12.98	9.28	2073	686.00	720.43	178.16	0.00	25.38	0.00	0.00	155.86	25.38	0.00	178.16	0.00	11.90	11.90								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	11.12	10.75	G=4	9.55	G=4	9.55							
10:30	13.00	9.36	2092	698.51	764.35	183.04	0.00	27.95	0.00	0.00	156.29	27.95	0.00	183.04	0.00	12.19	15.63								1	2	定刻	
						145	0	71	0	0	50	71	0	146	0	9.65	8.99	G=4	9.55	G=4	9.55							
10:32	13.00	9.38	2092	695.25	770.99	186.32	0.00	29.72	0.00	0.00	156.57	29.72	0.00	186.32	0.00	26.76	33.60								1	2	機器動作	
						145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	3						
10:34	13.01	9.39	2101	701.15	776.98	186.32	0.00	29.72	0.00	0.00	156.57	29.72	0.00	186.32	0.00	33.40	33.60								1	2	制御開始	
						145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J						
10:34	13.01	9.39	2101	701.15	776.98	187.97	0.00	30.62	0.00	0.00	156.71	30.62	0.00	187.97	0.00	33.52	33.73								1	2	制御開始	
						145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J						
10:35	13.01	9.41	2101	701.85	837.55	187.97	0.00	30.62	0.00	0.00	156.71	30.62	0.00	187.97	0.00	33.52	33.73								1	2	制御終了	
						145	0	71	0	0	70	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55							
10:35	13.01	9.41	2101	701.85	837.55	187.97	0.00	30.62	0.00	0.00	217.28	30.62	0.00	187.97	0.00	33.52	33.73					J			1	2	機器動作	
						145	0	71	0	0	70	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55							
10:40	13.00	9.49	2092	716.15	831.50	187.97	0.00	30.62	0.00	0.00	217.28	30.62	0.00	187.97	0.00	33.52	33.73								1	2	定刻	
						145	0	71	0	0	70	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55							
10:50	12.96	9.52	2055	726.17	807.63	186.32	0.00	29.72	0.00	0.00	217.08	29.72	0.00	186.32	0.00	33.40	33.60								1	2	定刻	
						145	0	71	0	0	70	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55							
11:00	12.92	9.50	2018	731.36	784.24	179.78	0.00	26.23	0.00	0.00	216.28	26.23	0.00	179.78	0.00	32.89	33.10								1	2	定刻	
						145	0	71	0	0	70	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55							
11:10	12.89	9.47	1990	732.25	766.99	173.33	0.00	22.88	0.00	0.00	215.47	22.88	0.00	173.33	0.00	32.39	32.60								1	2	定刻	
						145	0	71	0	0	70	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55							
						168.53	0.00	20.47	0.00	0.00	214.87	20.47	0.00	168.53	0.00	32.02	32.22								1	2	定刻	

加古川大堰操作記録Ⅰ

2017年08月18日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制 御 パ タ ー ン	流 入 量 判 定	印 字 要 因																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																										
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																						
	T. Pm	T. Pm	10³m³	m³/s	m³/s																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																</

加古川大堰操作記録Ⅰ

2017年08月18日
加古川大堰

時刻	堰上水位	堰下水位	貯水量	流入量	堰放流量	本川ゲート										微調節ゲート		魚道ゲート				操作モード			制御 パター ン	流入 量判 定	印字要因
						開度 (cm) / 放流量 (m³/s)										開度 (T.Pm) / 放流量 (m³/s)				本 川 ゲ ー ト	微 調 節 ゲ ー ト	魚 道 ゲ ー ト					
						1 号		2 号		3 号		4 号		5 号		左岸	右岸	左岸	右岸								
						上段	下段	上段	下段	上段	下段	上段	下段	上段	下段												
	T. Pm	T. Pm	10³m³	m³/s	m³/s																						
14:55	12.35	8.89	1518	509.97	492.07	145	0	71	0	0	60	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J			1	2	制御終了
14:56	12.35	8.89	1518	513.83	492.07	90.44	0.00	0.00	0.00	0.00	175.54	0.00	0.00	90.44	0.00	25.56	25.75		42.17		42.17				1	2	機器動作
						145	0	71	0	0	60	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55						
15:00	12.34	8.83	1510	506.12	488.61	145	0	71	0	0	60	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J			1	2	定刻
15:10	12.34	8.79	1510	493.92	488.61	89.15	0.00	0.00	0.00	0.00	175.35	0.00	0.00	89.15	0.00	25.44	25.64		41.94		41.94				1	2	定刻
						145	0	71	0	0	60	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55						
15:20	12.33	8.77	1502	482.60	485.20	145	0	71	0	0	60	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J			1	2	定刻
15:30	12.32	8.76	1494	471.42	481.77	87.87	0.00	0.00	0.00	0.00	175.17	0.00	0.00	87.87	0.00	25.33	25.52		41.72		41.72				1	2	定刻
						145	0	71	0	0	60	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55						
15:30	12.32	8.76	1494	471.42	481.77	86.59	0.00	0.00	0.00	0.00	174.99	0.00	0.00	86.59	0.00	25.21	25.41		41.49		41.49	J			1	2	定刻
15:30	12.32	8.76	1494	471.42	481.77	145	0	71	0	0	60	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	制御開始
						86.59	0.00	0.00	0.00	0.00	174.99	0.00	0.00	86.59	0.00	25.21	25.41		41.49		41.49						
15:30	12.32	8.76	1494	471.42	481.77	145	0	71	0	0	60	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J			1	2	制御開始
						86.59	0.00	0.00	0.00	0.00	174.99	0.00	0.00	86.59	0.00	25.21	25.41		41.49		41.49	1			2	制御終了	
15:31	12.32	8.76	1494	471.42	453.41	145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	1			2	制御終了	
15:31	12.32	8.76	1494	471.42	453.41	86.59	0.00	0.00	0.00	0.00	146.63	0.00	0.00	86.59	0.00	25.21	25.41		41.49		41.49	J			1	2	機器動作
						145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	機器動作
						86.59	0.00	0.00	0.00	0.00	146.63	0.00	0.00	86.59	0.00	25.21	25.41		41.49		41.49						
15:40	12.34	8.69	1510	459.66	460.19	145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J			1	2	定刻
15:50	12.34	8.68	1510	448.74	460.19	89.15	0.00	0.00	0.00	0.00	146.93	0.00	0.00	89.15	0.00	25.44	25.64		41.94		41.94				1	2	定刻
						145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55						
16:00	12.34	8.67	1510	437.96	460.19	89.15	0.00	0.00	0.00	0.00	146.93	0.00	0.00	89.15	0.00	25.44	25.64		41.94		41.94	J			1	2	定刻
16:10	12.34	8.67	1510	430.15	460.19	145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	定刻
						89.15	0.00	0.00	0.00	0.00	146.93	0.00	0.00	89.15	0.00	25.44	25.64		41.94		41.94						
16:20	12.33	8.66	1502	419.60	456.81	145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J			1	2	定刻
16:30	12.31	8.64	1486	409.19	450.05	87.87	0.00	0.00	0.00	0.00	146.78	0.00	0.00	87.87	0.00	25.33	25.52		41.72		41.72				1	2	定刻
						145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55						
16:30	12.31	8.64	1486	409.19	450.05	85.32	0.00	0.00	0.00	0.00	146.48	0.00	0.00	85.32	0.00	25.10	25.29		41.27		41.27	J			1	2	定刻
16:30	12.31	8.64	1486	409.19	450.05	145	0	71	0	0	50	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	制御開始
						85.32	0.00	0.00	0.00	0.00	146.48	0.00	0.00	85.32	0.00	25.10	25.29		41.27		41.27						
16:30	12.31	8.64	1486	409.19	421.41	145	0	71	0	0	40	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J			1	2	制御終了
16:31	12.31	8.64	1486	409.19	421.41	85.32	0.00	0.00	0.00	0.00	117.84	0.00	0.00	85.32	0.00	25.10	25.29		41.27		41.27	1			2	制御終了	
						145	0	71	0	0	40	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55						
16:40	12.31	8.57	1486	401.63	421.41	85.32	0.00	0.00	0.00	0.00	117.84	0.00	0.00	85.32	0.00	25.10	25.29		41.27		41.27	J			1	2	機器動作
						145	0	71	0	0	40	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55				1	2	機器動作
						85.32	0.00	0.00	0.00	0.00	117.84	0.00	0.00	85.32	0.00	25.10	25.29		41.27		41.27						
16:50	12.31	8.56	1486	391.44	421.41	145	0	71	0	0	40	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	J			1	2	定刻
17:00	12.31	8.55	1486	381.38	421.41	85.32	0.00	0.00	0.00	0.00	117.84	0.00	0.00	85.32	0.00	25.10	25.29		41.27		41.27				1	2	定刻
						145	0	71	0	0	40	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55						
17:00	12.31	8.55	1486	381.38	421.41	85.32	0.00	0.00	0.00	0.00	117.84	0.00	0.00	85.32	0.00	25.10	25.29		41.27		41.27	J			1	2	制御開始
						145	0	71	0	0	40	71	0	146	0	9.02	8.99	G=4	9.55	G=4	9.55	1			2	制御開始	
						85.32	0.00	0.00	0.00	0.00	117.84	0.00	0.00	85.32	0.00	25.10	25.29		41.27		41.27						

操 作 モ ー ド	1 文字目：運転モード	2 文字目：制御モード		制 御 パ タ ー ン	1：平水 2：洪水	流 入 量 判 定	1：堰水位 換算流入量 2：上流流入量	G	最高天端高 1～3：魚道ゲートグループNo 4：制水ゲート
	1：自動 2：半自動 3：遠方手動 4：機側	A：定水位Ⅰ（微調節） B：全開（微調節） C：定水位Ⅰ（調節上段） D：設定流量	E：事前放流 F：定水位 G：全開 H：貯留回復Ⅰ						