

Citrus Tracker-Row Inspection

Operations Procedure · TRC-8 / Fault P09

DOCUMENT	CIT-SOP-TRK-014
VERSION	1.4
EFFECTIVE	July 2, 2026
STATUS	Approved — Synthetic
OWNER	Citrus Solar Operations (Synthetic)

4. Field Inspection

Use this procedure for a TRC-8 tracker row placed in Safe Stow Hold after P09. These steps authorize observation from outside the row movement envelope only.

4.1 Preconditions

- Confirm row identifier, P09 event time, Safe Stow Hold, and control-room work authorization.
- Establish and maintain the marked movement exclusion zone for the full affected row.
- Record commanded angle, measured angle, deviation, and drive-current summaries.
- Stop for structural damage, loose modules, electrical hazards, unstable ground, or any condition requiring entry into the movement envelope.

Stop-work boundary: This procedure does not authorize motion commands, entry beneath or between moving members, removal of guards, or contact with the drive, linkage, torque tube, or position sensor.

4.2 Authorized tracker-row inspection

- 1 Verify TRK-01 remains in Safe Stow Hold and notify the control room that observation is beginning.
- 2 From outside the movement envelope, inspect for vegetation, debris, pooled material, and row or module interference.
- 3 Observe modules, supports, torque-tube alignment, linkage, and drive housing for displacement, bending, loose material, or impact evidence. Do not touch components.
- 4 Compare commanded and measured angle. Record whether feedback is present, stable, and responsive; record abnormal or sustained drive-current loading.
- 5 If deviation remains above 5.0 degrees, feedback is unstable, current remains above 7.5 amperes, or the path is not clear, retain Safe Stow Hold and create a qualified-maintenance work order.

Escalate to qualified maintenance when

- A check requires entry into the movement envelope or component contact.
- An obstruction cannot be characterized from outside the exclusion zone.
- Disagreement or elevated loading persists after the visible path is clear.