



APPENDIX C-1

MONTHLY SAFETY BOARD AND EQUIPMENT INSPECTION
CHECKLIST No. 01 - PGIA-MAN-VAES-001

Document No.:	PGIA-CL-VAES-01
Frequency:	Monthly
Responsible:	Electrical Maintenance Supervisor
Supervisor / Reviewer:	Operations Manager
Date of Inspection:	_____
Time Commenced:	_____
Time Completed:	_____
Weather / Visibility Conditions:	_____
Systems Affected / AOC Impact:	Yes ☐ No ☐ (if yes — notify Operations Manager immediately)
Responsible Signature:	_____
Supervisor Signature:	_____

Item to Verify	SAT ✓	NOSAT X	N/A	Remarks / Corrective Action
Safety board is mounted and accessible in or adjacent to the lighting vault	☐	☐	☐	
Rubber insulating gloves — present, tested, and within certification date	☐	☐	☐	
Grounding cables — present and in serviceable condition	☐	☐	☐	
Safety goggles — present and in serviceable condition	☐	☐	☐	
Face shield — present and in serviceable condition	☐	☐	☐	
Fire extinguisher (Class C or ABC) present, fully charged, within inspection date	☐	☐	☐	
First aid kit — fully stocked and within all expiry dates	☐	☐	☐	



VOM / DMM — calibration date verified and current (record date: _____)	☐	☐	☐	
Megohmmeter — calibration date verified and current (record date: _____)	☐	☐	☐	
True-RMS clamp-on ammeter — calibration date verified and current (record date: _____)	☐	☐	☐	
Infrared thermometer — calibration date verified and current	☐	☐	☐	
Ground rod resistance tester — calibration date verified and current	☐	☐	☐	
Cable/fault locator — operational, batteries fresh	☐	☐	☐	
Photometer — calibration date verified and current (if available)	☐	☐	☐	
All calibration certificates filed in the Technical Library	☐	☐	☐	
No expired or damaged test equipment in active service	☐	☐	☐	
LOTO kit — all padlocks, tags, and hasps present and functional	☐	☐	☐	
Gas monitor for confined space entry — operational, batteries charged, calibration current	☐	☐	☐	