



APPENDIX C-4

SEMI-ANNUAL RUNWAY/TAXIWAY PHOTOMETRIC MEASUREMENT
CHECKLIST No. 04 -PGIA-MAN-VAES-004

Document No.:	PGIA-CL-VAES-04
Frequency:	Semi-Annual (minimum twice per year per BCAR-139.311)
Responsible:	Electrical Maintenance Supervisor / Electrical Engineer Consultant
Supervisor / Reviewer:	Operations Manager
Date of Inspection:	_____
Time Commenced:	_____
Time Completed:	_____
Weather / Visibility Conditions:	_____
Systems Affected / AOC Impact:	Yes ☐ No ☐ (if Yes — notify Operations Manager immediately)
Responsible Signature:	_____
Supervisor Signature:	_____

Item to Verify	SAT ✓	NOSAT X	N/A	Remarks / Corrective Action
Previous 6-month serviceability trend reviewed; areas of concern identified	☐	☐	☐	
Photometric measurement equipment calibrated.	☐	☐	☐	
In-field measurements performed for ALL runway edge lights (or as far as practicable)	☐	☐	☐	
In-field measurements performed for ALL threshold lights	☐	☐	☐	
In-field measurements performed for ALL runway end lights	☐	☐	☐	
Measurement data recorded for each fixture (attach measurement records)	☐	☐	☐	
All lights below 50% of BCAR-14 specification	☐	☐	☐	



identified (unserviceable per BCAR-139.311)				
All lights below 70% of specification identified for scheduled maintenance	☐	☐	☐	
No two adjacent lights simultaneously below 50% specification	☐	☐	☐	
Fixture physical condition inspected: ground elevation, base torque, corrosion	☐	☐	☐	
Semi-Annual Photometric Report prepared and submitted to Operations Manager	☐	☐	☐	