



ANNEX C

Technical Oversight Inspection Field Record

Form: PGIA-PMM-F03

Completed by Civil Engineering Consultant (CEC) quarterly. Annual PCI Survey in October. Written TOI Report submitted to OM and COO within 10 days.

Inspection Date:	
Quarter:	Q1 (Jan) ☐ Q2 (Apr) ☐ Q3 (Jul) ☐ Q4 (Oct — Annual PCI) ☐
CEC Name / License No.:	
Field Technician:	
Previous TOI Date:	
Previous TOI Report No.:	
OM Present During Inspection:	Yes ☐ No ☐
Weather During Inspection:	
Movement Area Clearance Ref.:	
NOTAM Ref. (if issued):	

SECTION A — RUNWAY 07/25: ASPHALT DISTRESS SURVEY (Per ASTM D5340 / AC 150/5320-17A Appendix A)	SAT	NO SAT	Remarks / Location
A-01 Alligator (fatigue) cracking record area (m ²) and severity (Low / Medium / High)	☐	☐	
A-02 Bleeding / flushing asphalt binder pushed to surface; record area and location	☐	☐	
A-03 Block cracking rectangular crack pattern not at joints; record area (m ²)	☐	☐	
A-04 Bumps and sags record location and height differential (mm)	☐	☐	
A-05 Corrugation transverse rippling; record wavelength and depth	☐	☐	
A-06 Depression measure maximum water depth accumulation (mm) and area (m ²)	☐	☐	
A-07 Edge cracking record length (m) and distance from pavement edge	☐	☐	
A-08 Joint / reflection cracking cracks mirroring underlying layer joints; record length (m) and width (mm)	☐	☐	
A-09 Lane / shoulder drop-off measure differential elevation (mm) between pavement edge and shoulder	☐	☐	
A-10 Longitudinal and transverse cracking record length (m), width (mm)	☐	☐	



and severity			
A-11 Patching assesses condition of all existing patches (Good / Moderate / Deteriorated)	☐	☐	
A-12 Polished aggregate / low friction notes extent and proximity to touchdown zone	☐	☐	
A-13 Pothole record count, and for each: length × width × depth (mm)	☐	☐	
A-14 Raveling / weathering record area (m ²) and severity	☐	☐	
A-15 Rutting measure maximum rut depth (mm) with 1.2 m straightedge; record wheel path location	☐	☐	
A-16 Shoving plastic displacement of surface in direction of traffic; record location	☐	☐	
A-17 Slippage cracking crescent-shaped cracks in direction of travel; record location	☐	☐	
A-18 Swell bulge or upward displacement; record location and height	☐	☐	
A-19 Rubber deposits Touchdown Zone 07: Visual Rating: None / Low / Medium / High	☐	☐	
A-20 Rubber deposits Touchdown Zone 25: Visual Rating: None / Low / Medium / High	☐	☐	
A-21 Friction Assessment recommendation: None ☐ Recommended to COO ☐ (if High rubber or reduced texture)	☐	☐	

SECTION B — RUNWAY STRIP, RESA, SHOULDERS (CEC ENGINEERING ASSESSMENT)	SAT	NO SAT	Remarks / Location
B-01 Runway shoulder condition correct elevation (within 25 mm below runway edge)	☐	☐	
B-02 Runway shoulder no erosion undermining pavement edge on either side	☐	☐	
B-03 RESA (Threshold 07): ground bearing appears adequate no soft spots or subsidence	☐	☐	
B-04 RESA (Threshold 07): obstacle height compliant no objects > 7.5 cm	☐	☐	
B-05 RESA (Threshold 25): ground bearing appears adequate no soft spots or subsidence	☐	☐	
B-06 RESA (Threshold 25): obstacle height compliant no objects > 7.5 cm	☐	☐	
B-07 Runway strip ground surface within graded area level and obstacle-free	☐	☐	

SECTION C — TAXIWAYS (ALPHA, BRAVO, CHARLIE): CONCRETE DISTRESS SURVEY (Per ASTM D5340 / AC 150/5320-17A Appendix B)	SAT	NO SAT	Remarks / Location
C-01 Blowup / buckling sudden upward displacement at joints; record location	☐	☐	



C-02 Corner break triangular piece broken from slab corner; record count and slab ID	☐	☐	
C-03 Divided slab full-depth cracks in 4+ pieces; record count	☐	☐	
C-04 Durability (D-cracking) closely spaced cracking parallel to joints; record area	☐	☐	
C-05 Faulting differential elevation at joints; measure with straightedge (mm); record all joints > 6 mm	☐	☐	
C-06 Joint seal damage inspects ALL joints: rate each section as Good / Cracked / Missing / Extruded	☐	☐	
C-07 Large patch assess condition of all existing patches > 0.1 m ²	☐	☐	
C-08 Linear cracking record length (m), width (mm); assess if full-depth	☐	☐	
C-09 Shrinkage / map cracking hairline network cracking on slab surface; record area (m ²)	☐	☐	
C-10 Popouts broken pieces pulled from slab surface; record count per 10 m ²	☐	☐	
C-11 Pumping evidence of water/fines ejected at joints; check with wheel loading	☐	☐	
C-12 Shattered slab multiple intersecting cracks; record count	☐	☐	
C-13 Spalling (corner) fragment broken from corner without full-depth crack; record count	☐	☐	
C-14 Spalling (joint) concrete broken along joint edge; record linear meters per joint	☐	☐	
C-15 Alkali-silica reaction (ASR) map cracking with gel staining near aggregate; record if suspected	☐	☐	

SECTION D — TURN PADS	SAT	NO SAT	Remarks / Location
D-01 Turn pad Threshold 07: surface distress survey per Section C above (PCC) complete	☐	☐	
D-02 Turn pad Threshold 25: surface distress survey per Section C above (PCC) complete	☐	☐	
D-03 Both turn pads: joint sealant condition assessed	☐	☐	
D-04 Both turn pads: drainage adequate, no standing water	☐	☐	

SECTION E — AIRCRAFT PARKING APRON (CONCRETE)	SAT	NO SAT	Remarks / Location
E-01 Full distress survey completed for all apron slabs per Section C methodology	☐	☐	
E-02 All joint conditions mapped and rated	☐	☐	



E-03 Drainage channels and sumps structurally sound and at correct grade	☐	☐	
E-04 Evidence of differential settlement between stands or between aprons and taxiway junction	☐	☐	
E-05 Fuel/oil contamination zones record area and recommend surface treatment if warranted	☐	☐	

SECTION F — PAVEMENT MARKINGS (TECHNICAL ASSESSMENT)	SAT	NO SAT	Remarks / Location
F-01 Retroreflectivity measurements conducted (if retroreflectometer available): record values	☐	☐	
F-02 Runway centerline dimensions per BCAR-14 / FAA AC 150/5340-1M; condition	☐	☐	
F-03 Threshold bar count and dimensions compliant with BCAR-14	☐	☐	
F-04 Aiming point dimensions compliant with BCAR-14	☐	☐	
F-05 Touchdown zone markings dimensions compliant	☐	☐	
F-06 Holding position markings correct geometry and color on all intersections	☐	☐	
F-07 Taxiway centerlines width and continuity compliant	☐	☐	
F-08 Paint showing crazing, peeling, or delamination from surface record location	☐	☐	
F-09 Markings obscured by rubber deposits record length affected (m) by zone	☐	☐	
F-10 Apron markings stand layout conforming to approved apron design plan	☐	☐	

SECTION G — DRAINAGE STRUCTURAL ASSESSMENT (Annual: March / September)	SAT	NO SAT	Remarks / Location
G-01 All runway edge channels: slope $\geq$ 1%, structurally sound, headwalls intact	☐	☐	
G-02 All taxiway drainage gutters: slope $\geq$ 1%, clear of sediment, structurally sound	☐	☐	
G-03 Apron drainage channels: slope $\geq$ 1%, all sumps accessible and clear	☐	☐	
G-04 All culverts: structurally sound pipes, clear inverts, intact headwalls and wingwalls	☐	☐	
G-05 No evidence of subsurface voids (detected by hammer sounding adjacent to pavement joints)	☐	☐	
G-06 No evidence of pavement edge erosion creating differential between pavement and shoulder	☐	☐	
G-07 Saturated Zone Map updated new zones or expansion of existing zones documented	☐	☐	



SECTION H — AIRFIELD SIGNS (CEC ANNUAL STRUCTURAL ASSESSMENT)	SAT	NO SAT	Remarks / Location
H-01 All mandatory instruction signs structures base integrity sound, no corrosion affecting structural adequacy	☐	☐	
H-02 All mandatory signs face panels intact, correctly dimensioned, legend and colors correct per BCAR-14	☐	☐	
H-03 All location signs face panels intact, dimensions correct	☐	☐	
H-04 All direction signs face panels intact, arrows correct, dimensions correct	☐	☐	
H-05 All runway distance remaining signs present, correct numerals, positions correct	☐	☐	
H-06 No signs with inadequate setback from pavement edge creating FOD or collision risk	☐	☐	

SECTION I — ANNUAL PCI SURVEY (October TOI only — Per ASTM D5340)	SAT	NO SAT	Remarks / Location
I-01 PCI survey completed for Runway 07/25 all ASTM D5340 sample units surveyed	☐	☐	
I-02 PCI survey completed for Taxiway Alpha	☐	☐	
I-03 PCI survey completed for Taxiway Bravo	☐	☐	
I-04 PCI survey completed for Taxiway Charlie	☐	☐	
I-06 PCI survey completed for Aircraft Parking Apron	☐	☐	
I-07 PCI survey completed for Turn Pads	☐	☐	
I-08 All PCI values recorded in Pavement Condition Index Database	☐	☐	
I-09 PCI trend analysis updated and compared against prior 3 years	☐	☐	
I-10 Maintenance and rehabilitation recommendations issued based on PCI results	☐	☐	

CEC CERTIFICATION STATEMENT:

I, the undersigned Civil Engineering Consultant, certify that this inspection was conducted in accordance with the procedures of the PGIA Maintenance Paved and Unpaved Manual (PGIA-OPS-PMM-001), that all entries are accurate records of conditions observed, and that a full written Technical Oversight Inspection Report will be submitted to the Operation Manager and Chief Operations Officer within 10 calendar days of the date of this inspection.



CEC (Name / License No. / Signature) Date: _____	OM (Name / Signature) Date: _____	COO Acknowledgment of Receipt (Name / Signature / Date) Date: _____
---	--	--