



APPENDIX C-7

MONTHLY ILLUMINATED GUIDANCE SIGNS INSPECTION

CHECKLIST No. 07 - PGIA-MAN-VAES-007

Document No.:	PGIA-CL-VAES-07
Frequency:	Monthly
Responsible:	Electrical Maintenance Technicians
Supervisor / Reviewer:	Electrical Maintenance Supervisor
Date of Inspection:	_____
Time Commenced:	_____
Time Completed:	_____
Weather / Visibility Conditions:	_____
Systems Affected / AOC Impact:	Yes ☐ No ☐ (if Yes — notify Operations Manager immediately)
Responsible Signature:	_____
Supervisor Signature:	_____

Item to Verify	SAT ✓	NOSAT X	N/A	Remarks / Corrective Action
ATC notified; LOTO applied; de-energization verified with clamp-on ammeter	☐	☐	☐	
All mandatory instruction signs (RED background): face panels clean and fully legible	☐	☐	☐	
All location/direction signs (YELLOW/BLACK): face panels clean and fully legible	☐	☐	☐	
Internal optical surfaces cleaned with approved cleaning agents (no alkaline/acid cleaners)	☐	☐	☐	
Failed lamps replaced with OEM lamps of correct type and wattage	☐	☐	☐	
Post-restoration circuit current verified within design specification: _____ A	☐	☐	☐	
All sign housings and mounting bases in good physical condition	☐	☐	☐	
All electrical connections in junction boxes are	☐	☐	☐	



secure and corrosion-free				
LOTO removed; all signs verified fully illuminated and legible; ATC notified	☐	☐	☐	