



APPENDIX C-8

MONTHLY WIND CONE ASSEMBLY INSPECTION

CHECKLIST No. 08 - PGIA-MAN-VAES-008

Document No.:	PGIA-CL-VAES-08
Frequency:	Monthly
Responsible:	Electrical Maintenance Technicians
Supervisor / Reviewer:	Electrical Maintenance Supervisor
Date of Inspection:	_____
Time Commenced:	_____
Time Completed:	_____
Weather / Visibility Conditions:	_____
Systems Affected / AOC Impact:	Yes ☐ No ☐ (if Yes — notify Operations Manager immediately)
Responsible Signature:	_____
Supervisor Signature:	_____

Item to Verify	SAT ✓	NOSAT X	N/A	Remarks / Corrective Action
Wind cone fabric inspected — no tears, heavy fading, or contamination	☐	☐	☐	
Fabric cleaned as required	☐	☐	☐	
Mechanical rotating frame in good condition; swivel bearing operates freely	☐	☐	☐	
Bearing lubricated by manufacturer's recommendation	☐	☐	☐	
Failed lamps replaced with OEM replacement lamps	☐	☐	☐	
Wind cone fabric fully inflates and rotates freely in wind	☐	☐	☐	
Mast structure — no corrosion, cracks, or loose mounting hardware	☐	☐	☐	
All electrical connections to lighting circuit secure	☐	☐	☐	
All lamps operational and visible from runway circuit	☐	☐	☐	