



APPENDIX C-16

DAILY CCR INSPECTION LOG
CHECKLIST No. 16 -PGIA-MAN-VAES-016

Document No.:	PGIA-CL-VAES-16
Frequency:	Daily
Responsible:	Electrical Maintenance Technician
Supervisor / Reviewer:	Electrical Maintenance Supervisor
Date of Inspection:	_____
Time Commenced:	_____
Time Completed:	_____
Weather / Visibility Conditions:	_____
Systems Affected / AOC Impact:	Yes ☐ No ☐ (if Yes — notify Operations Manager immediately)
Responsible Signature:	_____
Supervisor Signature:	_____

Item to Verify	SAT ✓	NOSAT X	N/A	Remarks / Corrective Action
CCR No. 1: Alarms clear ☐ Step: ____ Output current: ____ A (vs. prev: ____ A)	☐	☐	☐	
CCR No. 2: Alarms clear ☐ Step: ____ Output current: ____ A (vs. prev: ____ A)	☐	☐	☐	
CCR No. 3: Alarms clear ☐ Step: ____ Output current: ____ A (vs. prev: ____ A)	☐	☐	☐	
CCR No. 4: Alarms clear ☐ Step: ____ Output current: ____ A (vs. prev: ____ A)	☐	☐	☐	
No unusual noises (buzzing, clicking, humming) from any CCR	☐	☐	☐	
Air-cooled CCRs — cooling fans operating	☐	☐	☐	
Air-cooled CCRs — air filter condition acceptable (not blocked)	☐	☐	☐	
No evidence of overheating or unusual odors from any CCR	☐	☐	☐	



**AERODROME OPERATIONS MANUAL
PHILIP S.W. GOLDSOIN INTERNATIONAL AIRPORT**

ANNEX 1-2
PGIA 16-15

