



ANNEX D

Drainage System Inspection Checklist

Form: PGIA-PMM-F04

Used for monthly routine drainage inspections and semi-annual CEC structural assessments. Completed form submitted to OM.

Date:	
Inspection Type:	Monthly Routine ☐ Semi-Annual Structural (CEC) ☐ Post-Storm Emergency ☐
Conducted by (Name / Position):	
Rainfall lasts 24 hrs. (mm, if applicable):	

SECTION 1 — RUNWAY DRAINAGE	SAT	NO SAT	Remarks / Location
DR-01 Runway 07 end drainage swale clear of sediment, vegetation, and debris	☐	☐	
DR-02 Runway 25 end drainage swales clear of sediment, vegetation, and debris	☐	☐	
DR-03 Runway east edge drainage channel (full length) free of blockage	☐	☐	
DR-04 Runway west edge drainage channel (full length) free of blockage	☐	☐	
DR-05 Runway drainage outlets water discharging freely to aerodrome drainage network	☐	☐	
DR-06 No ponding adjacent to runway edges 1 hour after end of rainfall	☐	☐	
DR-07 No erosion channels created by surface water at runway edges	☐	☐	

SECTION 2 — TAXIWAY DRAINAGE	SAT	NO SAT	Remarks / Location
DR-08 Taxiway Alpha drainage channels (east and west) clear, flowing	☐	☐	
DR-09 Taxiway Bravo drainage gutters clear	☐	☐	
DR-10 Taxiway Charlie drainage gutters clear	☐	☐	
DR-12 No standing water on any taxiway surface 30 min after end of rainfall	☐	☐	

SECTION 3 — APRON DRAINAGE	SAT	NO SAT	Remarks / Location
DR-13 All apron drainage channels clear and unobstructed	☐	☐	



DR-14 All apron drainage sumps clear and flowing	☐	☐	
DR-15 Apron drainage outlets to aerodrome storm network functioning	☐	☐	
DR-16 No standing water on apron 30 min after end of rainfall	☐	☐	

SECTION 4 — CULVERTS AND CROSS-DRAINAGE STRUCTURES	SAT	NO SAT	Remarks / Location
DR-17 Culvert at [Location 1] invert clear, headwalls intact, no structural cracking	☐	☐	
DR-18 Culvert at [Location 2] invert clear, headwalls intact, no structural cracking	☐	☐	
DR-19 Culvert at [Location 3] invert clear, headwalls intact, no structural cracking	☐	☐	
DR-20 All identified culverts no sedimentation reducing flow area > 25%	☐	☐	
DR-21 All culvert headwalls and wingwalls structurally intact, no separation from embankment	☐	☐	

SECTION 5 — UNPAVED AREA DRAINAGE (CHANNELS AND SWALES)	SAT	NO SAT	Remarks / Location
DR-22 All open channels in runway strips free of vegetation blockage and sediment	☐	☐	
DR-23 All open channels in infield areas free of blockage	☐	☐	
DR-24 All swale slopes at minimum 1% longitudinal gradient to outlet	☐	☐	
DR-25 No channel bank erosion creating structural failure of channel	☐	☐	
DR-26 No channel blockage causing overflow onto adjacent safety areas	☐	☐	
DR-27 Saturated Zone 7 areas no expansion of flooded zone beyond mapped boundaries	☐	☐	

DRAINAGE DEFICIENCIES FOUND (describe location, type, severity, and recommended action):



**AERODROME OPERATIONS MANUAL
PHILIP S.W. GOLDSON INTERNATIONAL AIRPORT**

ANNEX 1-1
PGIA 16-14



Conducted by (Name / Position / Signature)

Date: _____

OM Acknowledgment (Name / Signature / Date)

Date: _____