MAIN BUILDING

FLOOR	ROOM ID	ROOM NAME	AREA	FINISHES				
				FLOOR	CEILING/HEIGHT		WALL	BASEBOARD
FIRST FLOOR	01-1F-001	LOBBY	42.48	F-7	C-4	4.2	W-2	B-2
	01-1F-002	LOBBY TOILET(M)/(F)	5.76/3.30	F-8	C-5	3.2	W-5	B-1
	01-1F-003	VISITOR MEETING ROOM	15.84	F-7	C-4	3.6	W-2	B-2
	01-1F-004	SECURITY 01	9	F-4	C-4	3.6	W-2	B-2
	01-1F-005	SECURITY OFFICE	35.93	F-4	C-4	3.6	W-2	B-2
	01-1F-006	PASSENGER LIFT 01/02	5.17	F-5	-	-	W-1	-
	01-1F-007	ADMIN LOBBY	22	F-7	C-4	4.2	W-2	B-2
	01-1F-008	TOILET(HCP)	4.8	F-8	C-5	3.2	W-5	B-1
	01-1F-009	TOILET&SHOWER(F)	32.43	F-8	C-5	3.2	W-5	B-1
	01-1F-010	TOILET&SHOWER(M)	28.12	F-8	C-5	3.2	W-5	B-1
	01-1F-011	FCC	26.95	F-4	C-2	-	W-2	B-2
	01-1F-012	SOC	49.28	F-4	C-2	-	W-2	B-2
	01-1F-013	MDF-01	15.40	F-6	C-2	-	W-2	B-2
	01-1F-014	ICT ENTRY ROOM-1	23.10	F-6	C-2	-	W-2	B-2
	01-1F-015	STAIR-01	24.48	F-9	C-7	-	W-2	B-3
	01-1F-016	GOODS LIFT 01/02	21.36	F-5	-	-	-	-
	01-1F-017	GOODS LIFT LOBBY 01	48.88	F-4	C-2	-	W-2	B-2
	01-1F-018	UNLOADING 01	152.22	F-2	C-7	-	W-2	B-2
	01-1F-019	STAIR-02	24.48	F-9	C-7	-	W-2	B-3
	01-1F-020	SECURITY 02	16.83	F-4	C-4	3.6	W-2	B-2
	01-1F-021	TOILET 01	5.32	F-8	C-5	3.2	W-5	B-1
	01-1F-022	LCWP-3	4.32	F-5	C-3	-	W-3	B-1
	01-1F-023	VRF-3	3.60	F-5	C-3	-	W-3	B-1
	01-1F-024	DUCT-5	1.80	F-3	-	-	W-3	B-1
	01-1F-025	STAGING 01	37.35	F-4	C-2	-	W-2	B-2
	01-1F-026	STAGING 02	67.72	F-4	C-2	-	W-2	B-2
	01-1F-027	ENCLOSED STAIRCASE 1	24.64	F-3	C-7	-	W-2	B-3
	01-1F-028	MMR A	34.00	F-6	C-6	5	W-2	B-2
	01-1F-029	SERVER ROOM A	49	F-6	C-6	5	W-2	B-2
	01-1F-030	ELECTRICAL ROOM A	47.6	F-4	C-6	5	W-2	B-2
	01-1F-031	MEETING ROOM	48.02	F-7	C-4	3.6	W-2	B-2
	01-1F-032	LCWP-2	4.08	F-5	C-3	-	W-3	B-1
	01-1F-033	VRF-2	4.08	F-5	C-3	-	W-3	B-1
	01-1F-034	DUCT-4	3.74	F-5	-	-	W-3	B-1
	01-1F-035	LCWP-1	8.50	F-5	C-3	-	W-3	B-1
	01-1F-036	DUCT-3	3.40	F-5	-	-	W-3	B-1
	01-1F-037	JANITOR	9.80	F-8	C-5	3.2	W-5	B-1
	01-1F-038	PANTRY	18.36	F-8	C-4	4.2	W-2	B-1
	01-1F-039	DATA HALL ENTRANCE	22.80	F-4	C-7	-	W-2	B-2
	01-1F-040	ADMIN CORRIDOR	120.72	F-7	C-4	4.2	W-2	B-2
	01-1F-041	ELECTRIAL ROOM B	26.52	F-4	C-6	5	W-2	B-2
	01-1F-042	SEVER ROOM B	47.60	F-6	C-6	5	W-2	B-2
	01-1F-043	MMR B	34.00	F-6	C-6	5	W-2	B-2
	01-1F-044	ENCLOSED STAIRCASE 2	28.16	F-3	C-7	-	W-2	B-3
	01-1F-045	STAGING 04	67.72	F-4	C-2	-	W-2	B-2
	01-1F-046	STAGING 03	28.42	F-4	C-2	-	W-2	B-2
	01-1F-047	CWP RISER-1	11.56	F-5	C-3	-	W-3	B-1
	01-1F-048	DUCT-1	1.70	F-5	-	-	W-3	B-1
	01-1F-049	VRF-1	4.25	F-5	C-3	-	W-3	B-1
	01-1F-050	CHW	12.87	F-5	C-3	-	W-3	B-1
	01-1F-051	STAIR-03	24.48	F-9	C-7	-	W-2	B-3
	01-1F-052	SECURITY 03	17.03	F-4	C-4	3.6	W-2	B-2
	01-1F-053	TOILET 02	5.32	F-8	C-5	3.2	W-5	B-1
	01-1F-054	UNLOADING 02	152.21	F-2	C-7	-	W-2	B-2
	01-1F-055	GOODS LIFT LOBBY 02	58.28	F-4	C-2	-	W-2	B-2
	01-1F-056	GOODS LIFT 03/04	21.36	F-5	-	-	-	-
	01-1F-057	DUCT-2		F-3	-	-	W-3	B-1
	01-1F-058	STAIR-04	24.48	F-9	C-7	-	W-2	B-3
	01-1F-059	MDF-02	32.25	F-6	C-2	-	W-2	B-2
	01-1F-060	ICT-ENTRY ROOM-2	2.02	F-6	C-2	5	W-2	B-2
	01-1F-061	CHILER ROOM	1445.46	F-5	C-3	-	W-2	B-3
	01-1F-062	SEVICE CORRIDOR-4	1105.22	F-4	C-7	-	W-2	B-2
	01-1F-063	SEVICE CORRIDOR-1		F-4	C-7	-	W-2	B-2
	01-1F-064	SEVICE CORRIDOR-2		F-4	C-7	-	W-2	B-2
	01-1F-065	SEVICE CORRIDOR-3		F-4	C-7	-	W-2	B-2

MAIN BUILDING

FLOOR	ROOM ID	ROOM NAME	AREA	FINISHES				
				FLOOR	CEILING/HEIGHT		WALL	BASEBOARD
FIRST FLOOR	01-1F-066	FAN WALL 1-3B	236.77	F-13	C-2	-	W-4	B-2
	01-1F-067	DATA HALL 1-3	861.41	F-12	C-6	4.7	W-4	B-2
	01-1F-068	FAN WALL 1-3A	216.48	F-13	C-2	-	W-4	B-2
	01-1F-069	FAN WALL 1-2B	216.48	F-13	C-2	-	W-4	B-2
	01-1F-070	DATA HALL 1-2	861.41	F-12	C-6	4.7	W-4	B-2
	01-1F-071	FAN WALL 1-2A	216.48	F-13	C-2	-	W-4	B-2
	01-1F-072	FAN WALL 1-1B	216.48	F-13	C-2	-	W-4	B-2
	01-1F-073	DATA HALL 1-1	861.41	F-12	C-6	4.7	W-4	B-2
	01-1F-074	FAN WALL 1-1A	236.77	F-13	C-2	-	W-4	B-2
	01-1F-075	STAIR-05	24.48	F-9	C-7	-	W-2	B-3
	01-1F-076	MDF-03	16.72	F-6	C-2	-	W-2	B-2
	01-1F-077	ELE-1	13.2	F-5	C-7	-	W-2	B-1
	01-1F-078	LCWP-4	7.8	F-5	C-3	-	W-3	B-1
	01-1F-079	VRF-4	3.8	F-5	C-3	-	W-3	B-1
	01-1F-080	LCWP-5	6	F-5	C-3	-	W-3	B-1
	01-1F-081	DUCT-6	4	F-5	-	-	W-3	B-1
	01-1F-082	ELV-1	13	F-5	C-7	-	W-2	B-1
	01-1F-083	STAIR-06	24.48	F-9	C-7	-	W-2	B-3
	01-1F-084	ELE-2	11	F-5	C-7	-	W-2	B-1
	01-1F-085	LCWP-6	9.8	F-5	C-3	-	W-3	B-1
	01-1F-086	VRF-5	3.8	F-5	C-3	-	W-3	B-1
	01-1F-087	DUCT-7	4	F-5	-	-	W-3	B-1
	01-1F-088	ALARM VALVE ROOM A	9.12	F-5	C-3	-	W-2	B-1
	01-1F-089	ELE-3	9.6	F-5	C-7	-	W-2	B-1
	01-1F-090	ELV-2	9.2	F-5	C-7	-	W-2	B-1
	01-1F-091	DUCT-8	3.2	F-5	-	-	W-3	B-1
	01-1F-092	LCWP-7	11	F-5	C-3	-	W-3	B-1
	01-1F-093	VRF-6	3.8	F-5	C-3	-	W-3	B-1
	01-1F-094	ELE-4	10.4	F-5	C-7	-	W-2	B-1
	01-1F-095	STAIR-07	24.48	F-9	C-7	-	W-2	B-3
	01-1F-096	ELV-3	6.2	F-5	C-7	-	W-2	B-1
	01-1F-097	CWP RISER-2	22	F-5	C-3	-	W-3	B-1
	01-1F-098	ELE-4	5	F-5	C-7	-	W-2	B-1
	01-1F-099	ELV-5	12	F-5	C-7	-	W-2	B-1
	01-1F-100	STORAGE	7	F-5	C-3	-	W-3	B-1
	01-1F-101	ALARM VALVE ROOM B	9	F-5	C-3	-	W-3	B-1
	01-1F-102	DUCT-9	1.6	F-3	-	-	W-3	-
	01-1F-103	VRF-7	3	F-5	C-3	-	W-3	B-1
	01-1F-104	STAIR-08	24.48	F-9	C-7	-	W-2	B-3
	01-1F-105	MDF-04	14.72	F-6	C-2	-	W-2	B-2
	01-1F-106	STAIR-09	42.52	F-9	C-7	-	-	-
	01-1F-107	GARBAGE ROOM	31.43	F-8	C-3	-	W-2	B-1
	01-1F-108	WASTE STORAGE ROOM	31.75	F-8	C-3	-	W-2	B-1
	01-1F-109	PUMP ROOM	119.09	F-5	C-7	-	W-2	B-1
	01-1F-110	MV-A	100.13	F-4	C-7	-	W-2	B-2
	01-1F-111	FUEL PUMP ROOM A	67.37	F-10	C-7	-	W-2	B-3
	01-1F-112	ELE-6	9.98	F-5	C-7	-	W-2	B-1
	01-1F-113	EXHAUST SHAFT-4	69.62	F-5	-	-	W-1	B-1
	01-1F-114	EXHAUST SHAFT-3	69.62	F-5	-	-	W-1	B-1
	01-1F-115	EXHAUST SHAFT-2	69.62	F-5	-	-	W-1	B-1
	01-1F-116	EXHAUST SHAFT-1	69.62	F-5	-	-	W-1	B-1
	01-1F-117	FUEL PUMP ROOM B	71.15	F-10	C-7	-	W-2	B-3
	01-1F-118	MV-B	90.27	F-4	C-7	-	W-2	B-2
	01-1F-119	ALARM VALVE ROOM C	21.28	F-5	C-3	-	W-2	B-3
	01-1F-120	DOMESTIC WATER PUMP ROOM	65.79	F-5	C-7	-	W-2	B-3
	01-1F-121	FIRE PUMP ROOM	154.36	F-5	C-7	-	W-2	B-3
	01-1F-122	STAIR-10	42.90	F-9	C-7	-	-	-
	01-1F-123	ELECTRICAL GANTRY	2295.49	F-1	C-1	-	-	-
	01-1F-024	ELV-6	3.40	F-5	C-7	-	W-2	B-1

MAIN BUILDING

FLOOR	ROOM ID	ROOM NAME	AREA	FINISHES				
				FLOOR	CEILING/HEIGHT		WALL	BASEBOARD
SECOND FLOOR	01-2F-001	OFFICE	123.2	F-7	C-4	3.6	W-2	B-2
	01-2F-002	MEETING ROOM 01	29.26	F-7	C-4	3.6	W-2	B-2
	01-2F-003	PASSENGER LIFT 01/02	5.17	-	-	-	-	-
	01-2F-004	ADMIN LOBBY	22.4	F-7	C-4	4.2	W-2	B-2
	01-2F-005	TOILET(HCP)	4.8	F-8	C-5	3.2	W-5	B-3
	01-2F-006	TOILET&SHOWER(F)	32.43	F-8	C-5	3.2	W-5	B-3
	01-2F-007	TOILET&SHOWER(M)	28.12	F-8	C-5	3.2	W-5	B-3
	01-2F-008	WAR ROOM	34.65	F-7	C-4	3.6	W-2	B-2
	01-2F-009	NOC	54.67	F-4	C-4	3.6	W-2	B-2
	01-2F-010	NOC(EQUIPMENT)	26.18	F-4	C-4	3.6	W-2	B-1
	01-2F-011	STAIR-01	24.48	F-9	C-7	-	W-2	B-3
	01-2F-012	GOODS LIFT 01/02	21.36	-	-	-	W-1	-
	01-2F-013	GOODS LIFT LOBBY 01	48.88	F-4	C-2	-	W-2	B-2
	01-2F-014	SPARE ROOM 01	57.24	F-4	C-2	-	W-4	B-2
	01-2F-015	CONCRETE ROOF	125.80	F-15	-	-	-	-
	01-2F-016	STAIR-02	24.48	F-9	C-7	-	W-2	B-3
	01-2F-017	LCWP-3	9.36	F-5	C-3	-	W-3	B-1
	01-2F-018	VRF-3	7.80	F-5	C-3	-	W-3	B-1
	01-2F-019	DUCT-5	3.90	-	-	-	W-3	B-1
	01-2F-020	STORAGE ROOM 1	17.16	F-4	C-2	-	W-4	B-2
	01-2F-021	STORAGE ROOM 2	31.86	F-4	C-2	-	W-4	B-2
	01-2F-022	ERAD ROOM	32.45	F-4	C-2	-	W-4	B-2
	01-2F-023	ENCLOSED STAIRCASE 1	24.64	F-3	C-7	-	W-2	B-3
	01-2F-024	MMR A	34.00	F-6	C-6	5	W-2	B-2
	01-2F-025	SERVER ROOM A	47.60	F-6	C-6	5	W-2	B-2
	01-2F-026	ELECTRICAL ROOM A	25.85	F-4	C-6	5	W-2	B-2
	01-2F-027	MEETING ROOM 2	48.02	F-7	C-4	3.6	W-2	B-2
	01-2F-028	LCWP-2	4.08	F-5	C-3	-	W-3	B-1
	01-2F-029	VRF-2	4.08	F-5	C-3	-	W-3	B-1
	01-2F-030	DUCT-4	3.74	-	-	-	W-3	B-1
	01-2F-031	LCWP-1	8.50	F-5	C-3	-	W-3	B-1
	01-2F-032	DUCT-3	3.40	-	-	-	W-3	B-1
	01-2F-033	JANITOR	9.80	F-8	C-5	3.2	W-5	B-1
	01-2F-034	PANTRY	18.36	F-8	C-4	4.2	W-2	B-1
	01-2F-035	DATA HALL ENTRANCE	22.80	F-4	C-7	-	W-2	B-2
	01-2F-036	ADMIN CORRIDOR	111.01	F-7	C-4	4.2	W-2	B-2
	01-2F-037	ELECTRICAL ROOM B	26.52	F-4	C-6	5	W-2	B-2
	01-2F-038	SERVER ROOM B	47.16	F-6	C-6	5	W-2	B-2
	01-2F-039	MMR B	34.00	F-6	C-6	5	W-2	B-2
	01-2F-040	ENCLOSED STAIRCASE 2	28.16	F-3	C-7	-	W-2	B-3
	01-2F-041	STORAGE ROOM 3	64.31	F-4	C-2	-	W-4	B-2
	01-2F-042	CWP RISER-1	25.74	F-5	C-3	-	W-3	B-1
	01-2F-043	DUCT-1	3.90	-	-	-	W-3	B-1
	01-2F-044	VRF-1	9.75	F-5	C-3	-	W-3	B-1
	01-2F-045	CHW	12.87	F-5	C-3	-	W-3	B-1
	01-2F-046	STAIR-03	24.48	F-9	C-7	-	W-2	B-3
	01-2F-047	CONCRETE ROOF	127.04	F-15	-	-	-	-
	01-2F-048	SPARE ROOM 02	56.18	F-4	C-2	-	W-4	B-2
	01-2F-049	GOODS LIFT LOBBY 02	58.28	F-4	C-2	-	W-2	B-2
	01-2F-050	GOODS LIFT 03/04	21.36	-	-	-	W-1	-
	01-2F-051	DUCT-2	2.02	F-5	-	-	W-3	-
	01-2F-052	STAIR-04	24.48	F-9	C-7	-	W-2	B-3
	01-2F-053	SEVICE CORRIDOR-1	1138.62	F-4	C-7	-	W-2	B-2
	01-2F-054	SEVICE CORRIDOR-2		F-4	C-7	-	W-2	B-2
	01-2F-055	SEVICE CORRIDOR-3		F-4	C-7	-	W-2	B-2
	01-2F-056	SEVICE CORRIDOR-4		F-4	C-7	-	W-2	B-2
	01-2F-057	DATA HALL 2-1	861.41	F-12	C-6	4.7	W-4	B-2
	01-2F-058	FAN WALL 2-1A	236.77	F-13	C-2	-	W-4	B-2
	01-2F-059	FAN WALL 2-1B	216.48	F-13	C-2	-	W-4	B-2

MAIN BUILDING

FLOOR	ROOM ID	ROOM NAME	AREA	FINISHES				
				FLOOR	CEILING/HEIGHT		WALL	BASEBOARD
SECOND FLOOR	01-2F-060	DATA HALL 2-2	861.41	F-12	C-6	4.7	W-4	B-2
	01-2F-061	FAN WALL 2-2A	216.48	F-13	C-2	-	W-4	B-2
	01-2F-062	FAN WALL 2-2B	216.48	F-13	C-2	-	W-4	B-2
	01-2F-063	DATA HALL 2-3	861.41	F-12	C-6	4.7	W-4	B-2
	01-2F-064	FAN WALL 2-3A	216.48	F-13	C-2	-	W-4	B-2
	01-2F-065	FAN WALL 2-3B	216.48	F-13	C-2	-	W-4	B-2
	01-2F-066	DATA HALL 2-4	410.55	F-11	C-6	5.5	W-4	B-2
	01-2F-067	FAN WALL 1A	71.40	F-6	C-2	-	W-4	B-2
	01-2F-068	FAN WALL 1B	73.10	F-6	C-2	-	W-4	B-2
	01-2F-069	SUPER CORE 1	676.20	F-11	C-6	5.5	W-4	B-2
	01-2F-070	FAN WALL 2A	117.60	F-6	C-2	-	W-4	B-2
	01-2F-071	FAN WALL 2B	120.40	F-6	C-2	-	W-4	B-2
	01-2F-072	STAIR-05	24.48	F-9	C-7	-	W-2	B-3
	01-2F-073	ELV-5	16.72	F-5	C-7	-	W-2	B-1
	01-2F-074	ELE-1	16.20	F-5	C-7	-	W-2	B-1
	01-2F-075	LCWP-4	4.80	F-5	C-3	-	W-3	B-1
	01-2F-076	VRF-4	3.80	F-5	C-3	-	W-3	B-1
	01-2F-077	LCWP-5	6.00	F-5	C-3	-	W-3	B-1
	01-2F-078	DUCT-6	4.00	-	-	-	W-3	B-1
	01-2F-079	ELV-1	13.00	F-5	C-7	-	W-2	B-1
	01-2F-080	DUCT-12	1.78	-	-	-	W-3	B-1
	01-2F-081	STAIR-06	24.48	F-9	C-7	-	W-2	B-3
	01-2F-082	ELE-2	11.00	F-5	C-7	-	W-2	B-1
	01-2F-083	LCWP-6	9.80	F-5	C-3	-	W-3	B-1
	01-2F-084	VRF-5	3.80	F-5	C-3	-	W-3	B-1
	01-2F-085	DUCT-7	4.00	-	-	-	W-3	B-1
	01-2F-086	ALARM VALVE ROOM A	9.60	F-5	C-3	-	W-2	B-1
	01-2F-087	ELE-3	9.60	F-5	C-7	-	W-2	B-1
	01-2F-088	ELV-2	9.10	F-5	C-7	-	W-2	B-1
	01-2F-089	DUCT-8	3.30	-	-	-	W-3	B-1
	01-2F-090	LCWP-7	11.00	F-5	C-3	-	W-3	B-1
	01-2F-091	VRF-6	3.80	F-5	C-3	-	W-3	B-1
	01-2F-092	ELE-4	10.40	F-5	C-7	-	W-2	B-1
	01-2F-093	STAIR-07	24.48	F-9	C-7	-	W-2	B-3
	01-2F-094	DUCT-11	1.62	-	-	-	W-3	B-1
	01-2F-095	ELV-3	6.20	F-5	C-3	-	W-3	B-1
	01-2F-096	CWP RISER-2	22.00	F-5	C-3	-	W-3	B-1
	01-2F-097	ELV-4	5.00	F-5	C-7	-	W-2	B-1
	01-2F-098	ELE-5	19.20	F-5	C-7	-	W-2	B-1
	01-2F-099	ALARM VALVE ROOM B	9.00	F-5	C-3	-	W-2	B-3
	01-2F-100	DUCT-9	1.60	-	-	-	W-3	B-1
	01-2F-101	VRF-7	3.00	F-5	C-3	-	W-3	B-1
	01-2F-102	STAIR-08	24.48	F-9	C-7	-	W-2	B-3
	01-2F-103	DUCT-10	1.61	-	-	-	W-3	B-1
	01-2F-104	STAIR-09	42.51	F-9	C-7	-	W-2	B-3
	01-2F-105	EXHAUST SHAFT-4	69.62	-	-	-	W-1	B-1
	01-2F-106	EXHAUST SHAFT-3	69.62	-	-	-	W-1	B-1
	01-2F-107	EXHAUST SHAFT-2	69.62	-	-	-	W-1	B-1
	01-2F-108	EXHAUST SHAFT-1	69.62	-	-	-	W-1	B-1
	01-2F-109	STAIR-10	42.51	F-9	C-7	-	W-2	B-3
	01-2F-110	ELECTRICAL GANTRY	3177.36	F-1	C-1	-	-	-
	01-2F-111	ELV-6	3.40	F-5	C-3	-	W-3	B-1

MAIN BUILDING

FLOOR	ROOM ID	ROOM NAME	AREA	FINISHES				
				FLOOR	CEILING/HEIGHT		WALL	BASEBOARD
THIRD FLOOR	01-3F-001	CUSTOMER OFFICE	235.81	F-7	C-4	3.6	W-2	B-2
	01-3F-002	CUSTOMER MEETING ROOM 01	29.26	F-7	C-4	3.6	W-2	B-2
	01-3F-003	PASSENGER LIFT 01/02	5.17	-	-	-	-	-
	01-3F-004	ADMIN LOBBY	22.4	F-7	C-4	4.2	W-2	B-2
	01-3F-005	TOILET(HCP)	4.8	F-8	C-5	3.2	W-5	B-3
	01-3F-006	TOILET&SHOWER(F)	32.43	F-8	C-5	3.2	W-5	B-3
	01-3F-007	TOILET&SHOWER(M)	22.57	F-8	C-5	3.2	W-5	B-3
	01-3F-008	STORAGE ROOM 1	38.5	F-4	C-2	-	W-4	B-2
	01-3F-009	CUSTOMER STORAGE ROOM	52.36	F-4	C-2	-	W-4	B-2
	01-3F-010	CUSTOMER SOC/STORAGE	24.64	F-4	C-4	4.2	W-4	B-2
	01-3F-011	STAIR-01	24.48	F-9	C-7	-	W-2	B-3
	01-3F-012	GOODS LIFT 01/02	21.36	-	-	-	W-1	-
	01-3F-013	GOODS LIFT LOBBY 01	48.88	F-4	C-7	-	W-2	B-2
	01-3F-014	SPARE ROOM 1	57.24	F-4	C-2	-	W-4	B-2
	01-3F-015	STAIR-02	24.48	F-9	C-7	-	W-2	B-3
	01-3F-016	LCWP-3	9.36	F-5	C-3	-	W-3	B-1
	01-3F-017	VRF-3	7.80	F-5	C-3	-	W-3	B-1
	01-3F-018	DUCT-5	3.90	-	-	-	W-3	-
	01-3F-019	STORAGE ROOM 2	17.16	F-4	C-2	-	W-4	B-2
	01-3F-020	CUSTOMER SECURITY STORAGE ROOM/STORAGE	31.86	F-4	C-2	-	W-4	B-2
	01-3F-021	CUSTOMER ERAD ROOM	32.45	F-4	C-2	-	W-4	B-2
	01-3F-022	MMR A	34.00	F-6	C-6	5	W-2	B-2
	01-3F-023	SERVER ROOM A	47.60	F-6	C-6	5	W-2	B-2
	01-3F-024	ELECTRICAL ROOM A	25.85	F-4	C-6	5	W-2	B-2
	01-3F-025	MEETING ROOM 2	48.02	F-7	C-4	3.6	W-2	B-2
	01-3F-026	LCWP-2	4.08	F-5	C-3	-	W-3	B-1
	01-3F-027	VRF-2	4.08	F-5	C-3	-	W-3	B-1
	01-3F-028	DUCT-4	3.74	-	-	-	W-3	-
	01-3F-029	LCWP-1	8.50	F-5	C-3	-	W-3	B-1
	01-3F-030	DUCT-3	3.40	-	-	-	W-3	-
	01-3F-031	JANITOR	9.80	F-8	C-5	3.2	W-5	B-3
	01-3F-032	PANTRY	18.36	F-8	C-4	4.2	W-2	B-3
	01-3F-033	DATA HALL ENTRANCE	22.80	F-4	C-7	-	W-2	B-2
	01-3F-034	ADMIN CORRIDOR	111.01	F-7	C-4	4.2	W-2	B-2
	01-3F-035	ELECTRIAL ROOM B	26.52	F-4	C-6	5	W-2	B-2
	01-3F-036	SEVER ROOM B	47.60	F-6	C-6	5	W-2	B-2
	01-3F-037	MMR B	34.00	F-6	C-6	5	W-2	B-2
	01-3F-038	CUSTOMER SEVER ROOM	121.02	F-6	C-2	-	W-4	B-2
	01-3F-039	CWP RISER-1	25.74	F-5	C-3	-	W-3	B-1
	01-3F-040	DUCT-1	3.90	-	-	-	W-3	-
	01-3F-041	VRF-1	9.75	F-5	C-3	-	W-3	B-1
	01-3F-042	CHW	12.87	F-5	C-3	-	W-3	B-1
	01-3F-043	STAIR-03	24.48	F-9	C-7	-	W-2	B-3
	01-3F-044	SPARE ROOM 2	121.02	F-4	C-2	-	W-4	B-2
	01-3F-045	GOODS LIFT LOBBY 02	58.28	F-4	C-7	-	W-2	B-2
	01-3F-046	GOODS LIFT 03/04	21.36	-	-	-	W-1	-
	01-3F-047	STAIR-04	24.48	F-9	C-7	-	W-2	B-3
	01-3F-048	DUCT-2	2.03	-	-	-	W-3	-
	01-3F-049	ENCLOSED STAIRCASE 2	28.16	F-3	C-7		W-2	B-3
	01-3F-050	ENCLOSED STAIRCASE 1	24.64	F-3	C-7		W-2	B-3
	01-3F-051	SEVICE CORRIDOR 1	1138.62	F-4	C-7	-	W-2	B-2
	01-3F-052	SEVICE CORRIDOR 2		F-4	C-7	-	W-2	B-2
	01-3F-053	SEVICE CORRIDOR 3		F-4	C-7	-	W-2	B-2
	01-3F-054	SEVICE CORRIDOR 4		F-4	C-7	-	W-2	B-2

MAIN BUILDING

FLOOR	ROOM ID	ROOM NAME	AREA	FINISHES				
				FLOOR	CEILING/HEIGHT		WALL	BASEBOARD
THIRD FLOOR	01-3F-055	DATA HALL 3-1	861.41	F-11	C-6	5.5	W-4	B-2
	01-3F-056	FAN WALL 3-1A	236.77	F-6	C-2	-	W-4	B-2
	01-3F-057	FAN WALL 3-1B	216.48	F-6	C-2	-	W-4	B-2
	01-3F-058	DATA HALL 3-2	861.41	F-11	C-6	5.5	W-4	B-2
	01-3F-059	FAN WALL 3-2A	216.48	F-6	C-2	-	W-4	B-2
	01-3F-060	FAN WALL 3-2B	216.48	F-6	C-2	-	W-4	B-2
	01-3F-061	DATA HALL 3-3	861.41	F-11	C-6	5.5	W-4	B-2
	01-3F-062	FAN WALL 3-3A	216.48	F-6	C-2	-	W-4	B-2
	01-3F-063	FAN WALL 3-3B	216.48	F-6	C-2	-	W-4	B-2
	01-3F-064	DATA HALL 3-4	1039.55	F-11	C-6	5.5	W-4	B-2
	01-3F-065	FAN WALL 3-4A	216.48	F-6	C-2	-	W-4	B-2
	01-3F-066	FAN WALL 3-4B	216.48	F-6	C-2	-	W-4	B-2
	01-3F-067	STAIR-05	24.48	F-9	C-7	-	W-2	B-3
	01-3F-068	ELV-5	16.72	F-5	C-7	-	W-2	B-1
	01-3F-069	ELE-1	16.20	F-5	C-7	-	W-2	B-1
	01-3F-070	LCWP-4	4.80	F-5	C-3	-	W-3	B-1
	01-3F-071	VRF-4	3.80	F-5	C-3	-	W-3	B-1
	01-3F-072	LCWP-5	6.00	F-5	C-3	-	W-3	B-1
	01-3F-073	DUCT-6	4.00	-	-	-	W-3	B-1
	01-3F-074	ELV-1	13.00	F-5	C-7	-	W-2	B-1
	01-3F-075	DUCT-12	1.77	-	-	-	W-3	B-1
	01-3F-076	STAIR-06	24.48	F-9	C-7	-	W-2	B-3
	01-3F-077	ELE-2	11.00	F-5	C-7	-	W-2	B-1
	01-3F-078	LCWP-6	9.80	F-5	C-3	-	W-3	B-1
	01-3F-079	VRF-5	3.80	F-5	C-3	-	W-3	B-1
	01-3F-080	DUCT-7	4.00	-	-	-	W-3	B-1
	01-3F-081	ALARM VALVE ROOM A	9.60	F-5	C-3	-	W-3	B-1
	01-3F-082	ELE-3	9.60	F-5	C-7	-	W-2	B-1
	01-3F-083	ELV-2	9.10	F-5	C-7	-	W-2	B-1
	01-3F-084	DUCT-8	3.30	-	-	-	W-3	B-1
	01-3F-085	LCWP-7	11.00	F-5	C-3	-	W-3	B-1
	01-3F-086	VRF-6	3.80	F-5	C-3	-	W-3	B-1
	01-3F-087	ELE-4	10.40	F-5	C-7	-	W-2	B-1
	01-3F-088	STAIR-07	24.48	F-9	C-7	-	W-2	B-3
	01-3F-089	DUCT-11	1.61	-	-	-	W-3	B-1
	01-3F-090	ELV-3	6.20	F-5	C-7	-	W-2	B-1
	01-3F-091	CWP RISER-2	22.00	F-5	C-3	-	W-3	B-1
	01-3F-092	ELV-4	5.00	F-5	C-7	-	W-2	B-1
	01-3F-093	ELE-5	19.20	F-5	C-7	-	W-2	B-1
	01-3F-094	ALARM VALVE ROOM B	9.00	F-5	C-3	-	W-3	B-1
	01-3F-095	DUCT-9	1.60	-	-	-	W-3	-
	01-3F-096	VRF-7	3.00	F-5	C-3		W-3	B-1
	01-3F-097	DUCT-10	1.61	-	-	-	W-3	-
	01-3F-098	STAIR-08	24.48	F-9	C-7	-	W-2	B-3
	01-3F-099	STAIR-09	42.51	F-9	C-7	-	W-2	B-3
	01-3F-100	EXHAUST SHAFT-4	69.62	-	-	-	W-1	-
	01-3F-101	EXHAUST SHAFT-3	69.62	-	-	-	W-1	-
	01-3F-102	EXHAUST SHAFT-2	69.62	-	-	-	W-1	-
	01-3F-103	EXHAUST SHAFT-1	69.62	-	-	-	W-1	-
	01-3F-104	STAIR-10	42.51	F-9	C-7	-	W-2	B-3
	01-3F-105	ELECTRICAL GANTRY	3177.36	F-0	C-1	-	-	-
	01-3F-106	ELV-6	3.40	F-5	C-7	-	W-2	B-1

MAIN BUILDING

FLOOR	ROOM ID	ROOM NAME	AREA	FINISHES				
				FLOOR	CEILING/HEIGHT		WALL	BASEBOARD
LOWER ROOF FLOOR	01-LRF-001	LIQUID WATER PUMP ROOM 1	151.41	F-3	C-3	-	W-2	B-1
	01-LRF-002	LIQUID WATER PUMP ROOM 2	152.44	F-3	C-3	-	W-2	B-1
	01-LRF-003	STAIR-01	34.2	F-9	C-7	-	W-2	B-3
	01-LRF-004	GOODS LIFT 01/02	21.36	-	-	-	W-1	-
	01-LRF-005	GOODS LIFT LOBBY 01	47.43	F-6	C-8	-	W-2	B-2
	01-LRF-006	STAIR-02	24.48	F-9	C-7	-	W-2	B-3
	01-LRF-007	LCWP-3	8.64	F-5	C-3	-	W-3	B-1
	01-LRF-008	VRF-3	7.2	F-5	C-3	-	W-3	B-1
	01-LRF-009	DUCT-5	3.6	-	-	-	W-1	-
	01-LRF-010	ELV-4	4.8	F-5	C-7	-	W-2	B-1
	01-LRF-011	ELE-3	3.2	F-5	C-7	-	W-2	B-1
	01-LRF-012	LCWP-2	3.84	F-5	C-3	-	W-3	B-1
	01-LRF-013	VRF-2	3.84	F-5	C-3	-	W-3	B-1
	01-LRF-014	DUCT-4	3.52	-	-	-	W-3	-
	01-LRF-015	LCWP-1	7.84	F-5	C-3	-	W-3	B-1
	01-LRF-016	DUCT-3	3.20	-	-	-	W-3	B-1
	01-LRF-017	ELE-2	6.46	F-5	C-7	-	W-2	B-1
	01-LRF-018	ELV-2	4.93	F-5	C-7	-	W-2	B-1
	01-LRF-019	CWP RISER-1	24.12	F-5	C-3	-	W-3	B-1
	01-LRF-020	DUCT-1	3.60	-	-	-	W-3	-
	01-LRF-021	VRF-1	9.00	F-5	C-3	-	W-3	B-1
	01-LRF-022	STAIR-03	24.48	F-9	C-7	-	W-2	B-3
	01-LRF-023	GOODS LIFT LOBBY 02	47.43	F-6	C-8	-	W-2	B-2
	01-LRF-024	GOODS LIFT 03/04	21.36	-	-	-	W-1	-
	01-LRF-025	DUCT-2	1.50	-	-	-	W-1	-
	01-LRF-026	STAIR-04	34.2	F-9	C-7	-	W-2	B-3
	01-LRF-027	STAIR-05	24.48	F-9	C-7	-	W-2	B-3
	01-LRF-028	ELV-5	15.48	F-5	C-7	-	W-2	B-1
	01-LRF-029	ELE-1	4.5	F-5	C-7	-	W-2	B-1
	01-LRF-030	LCWP-4	4.32	F-5	C-3	-	W-3	B-1
	01-LRF-031	VRF-4	3.42	F-5	C-3	-	W-3	B-1
	01-LRF-032	LCWP-5	5.4	F-5	C-3	-	W-3	B-1
	01-LRF-033	DUCT-6	3.78	-	-	-	W-3	-
	01-LRF-034	ELV-1	5.94	F-5	C-7	-	W-2	B-1
	01-LRF-035	DUCT-12	1.68	-	-	-	W-3	B-1
	01-LRF-036	STAIR-06	24.48	F-9	C-7	-	W-2	B-3
	01-LRF-037	LCWP-6	8.82	F-5	C-3	-	W-3	B-1
	01-LRF-038	VRF-5	3.42	F-5	C-3	-	W-3	B-1
	01-LRF-039	DUCT-7	3.60	-	-	-	W-3	-
	01-LRF-040	DUCT-8	2.97	-	-	-	W-3	B-1
	01-LRF-041	LCWP-7	5.31	F-5	C-3	-	W-3	B-1
	01-LRF-042	VRF-6	3.60	F-5	C-3	-	W-3	B-1
	01-LRF-043	ELE-4	6.30	F-5	C-7	-	W-2	B-1
	01-LRF-044	STAIR-07	24.48	F-9	C-7	-	W-2	B-3
	01-LRF-045	DUCT-11	1.52	-	-	-	W-3	-
	01-LRF-046	ELV-3	8.82	F-5	C-7	-	W-2	B-1
	01-LRF-047	CWP RISER-3	2.88	F-5	C-3	-	W-3	B-1
	01-LRF-048	CWP RISER-2	9.90	F-5	C-3	-	W-3	B-1
	01-LRF-049	ELE-5	8.82	F-5	C-7	-	W-2	B-1
	01-LRF-050	DUCT-9	4.50	-	-	-	W-3	-
	01-LRF-051	DUCT-10	1.52	-	-	-	W-3	-
	01-LRF-052	VRF-7	4.50	F-5	C-3	-	W-3	B-1
	01-LRF-053	STAIR-08	24.48	F-9	C-7	-	W-2	B-3
	01-LRF-054	STAIR-09	42.51	F-9	C-7	-	-	-
	01-LRF-055	EXHAUST SHAFT-5	108.57	F-3	-	-	W-1	B-1
	01-LRF-056	EXHAUST SHAFT-4	69.62	-	-	-	W-1	B-1
	01-LRF-057	EXHAUST SHAFT-3	69.62	-	-	-	W-1	B-1
	01-LRF-058	EXHAUST SHAFT-2	69.62	-	-	-	W-1	B-1
	01-LRF-059	EXHAUST SHAFT-1	69.62	-	-	-	W-1	B-1
	01-LRF-060	EXHAUST SHAFT-6	93.12	F-3	-	-	W-1	B-1
	01-LRF-061	ELECTRICAL GANTRY	2958.41	F-1	C-1	-	-	-
	01-LRF-062	STAIR-10	42.51	F-9	C-7	-	-	-
UPPER ROOF FLOOR	01-URF-001	STAIR-06	24.48	F-9	C-7	-	W-2	B-3
	01-URF-002	DUCT-12	1.68	-	-	-	W-3	-
	01-URF-003	STAIR-07	24.48	F-9	C-7	-	W-2	B-3
	01-URF-004	DUCT-11	1.52	-	-	-	W-3	-
	01-URF-005	STAIR-09	52.32	F-9	C-7	-	-	-
	01-URF-006	STAIR-10	52.32	F-9	C-7	-	-	-

CLIENT :

GULF EDGE DC 01

CONTRACTOR :

HUASHI DEVELOPMENT CO.,LTD

CONSULTANT :

ARbay

Arbay Company Limited

CONSULTANT :

Qbic Engineers & Architects Co.,Ltd.

QBIC ENGINEERS AND ARCHITECTS CO.,LTD.

CONSULTANT :

MITR

MITR TECHNICAL CONSULTANT CO.,LTD.

Architect :	SIGNATURE
Structural Engineer :	SIGNATURE
Structural Inspector :	SIGNATURE
Electrical Engineer :	SIGNATURE
Mechanical Engineer :	SIGNATURE
Sanitary Engineer :	SIGNATURE

ISSUE/REVISION

REV.	DESCRIPTION	DATE
A	90% DEVELOPED	09/05/2026

PROJECT NAME :
GEDC 01

BUILDING :
MAIN BUILDING
90% DEVELOPED

TITLE :
SCHEDULE OF ROOM DATA SHEETS

JOB NO.		SCALE	1:100
DRAWN	KHJ	REF.	
CHECKED	LJC	DWG.NO.	MPK00-90-A-SC-004
APPROVED	LXD		
DATE	2026.05.09		

NOTE : THIS PRINT IS OF A CONFIDENTIAL NATURE, IT SHALL NOT BE TRACED,PHOTOGRAPHED,PHOTOSTATED OR REPRODUCED IN ANY MANER,NOR USED FOR ANY PURPOSE WHATSOEVER EXCEPT BY WRITTEN PERMISSION