FLOOR HEIGHT(MM)					
	UPPER ROOF LEVEL	UPPER ROOF	MRL		MRL
5400	ROOF LEVEL	M&E	⊓	MRL	⊓
8000	3RD STOREY	DATA HALL	⊓	⊓	⊓
8000	2ND STOREY	DATA HALL	⊓	⊓	⊓
8000	1ST STOREY	DATA HALL	⊓	⊓	⊓
8000	1ST STOREY	DATA HALL	■	■	■
	TYPE OF BUILDING		DATA CENTRE	DATA CENTRE	DATA CENTRE
GENERALSPECIFICATION	LOCATION/GRIDLINE		J-H/4.1-5	J-H/6.1-7	J-H/9-9.1
	LIFT NO.(ARCHITECT CALL OUT)		G-D-03/04	P-D-01/02	G-D-01/02
	QUANTITY		2	2	2
	LIFT TYPE		MACHINEROOM-LESS TRACTION LIFT(MRL)	MACHINEROOM-LESS TRACTION LIFT(MRL)	MACHINEROOM-LESS TRACTION LIFT(MRL)
	LIFT USAGE		GOODS LIFT/FIRE LIFT	PASSENGER	GOODS LIFT
	CAPACITY(PERSONS/KG) SS550-2009		5000KG	1000KG	5000KG
	SPEED (MIS/MPM)		1M/S (60 MPM)	1.5M/S (90 MPM)	1M/S (60 MPM)
	DRIVE SYSTEM		VVVF	VVVF	VVVF
	CONTROL OPERATION		AUTOMATIC DUPLEX SELECTIVE COLLECTVE OPERATION SYSTEM	AUTOMATIC DUPLEX SELECTIVE COLLECTVE OPERATION SYSTEM	AUTOMATIC DUPLEX SELECTIVE COLLECTVE OPERATION SYSTEM
	NO OF STOPS/OPENINGS		4	3	4
	FLOOR SERVED(FRONT)		L1 TO ROOF	L1 TO L3	L1 TO ROOF
	FLOOR SERVED(REAR)		NIL	NIL	NIL
	NO OF NON-STOPS		NIL	NIL	NIL
	NON-STOP FLOOR		NIL	NIL	NIL
	TRAVEL(M)		24.5M	16.0M	24.5M
	POWER SUPPLY		380V,3 PHASE,50 HZ	380V,3 PHASE,50 HZ	380V,3PHASE,50 HZ
	LIGHTING SUPPLY		220V,1 PHASE,50HZ	220V,1 PHASE,50HZ	220V,1 PHASE,50HZ
	MACHINE TYPE		AC GEARED TRACTON TYPE	AC GEARLESS TRACTION TYPE	AC GEARED TRACTON TYPE
	MACHINE LOCATION		MOUNTED ON THE HIGHEST PART OF THE LIFT SHAFT	MOUNTED ON THE HIGHEST PART OF THE LIFT SHAFT	MOUNTED ON THE HIGHEST PART OF THELIFT SHAFT

LEGEND	
▨	LIFT MACHINE ROOM
⊓	HALL ENTRANCE
[ ]	THROUGH HALL ENTRANCE
☒	LIFTSHAFT/ NON-STOP
MRL	MACHINE ROOMLESS
☒ E	EMERGENCY ACCESS DOOR
■	LIFT PIT
⬚	OVER RUN
V	VOIDED
RH	RESCUE HOOKS

CLIENT :

GULF EDGE DC 01

87 Wireless Road, M Thai Tower 11th. Floor, All Seasons Place, Lumpini,
Pathumwan, Bangkok 10330, Thailand

CONTRACTOR :

华西发展(泰国)有限公司
บริษัท หัวซือ ดีเวลลอปเม้นต์ (ประเทศไทย) จำกัด
HUASHI DEVELOPMENT CO.,LTD
No. 202, Room No. 1403, 14/F, Le Concorde Building,
Ratchadapisek Road, Huaykhwang Sub-District,
Huaykhwang District, Bangkok Metropolitan 10310.

CONSULTANT :

ARbay
บริษัท เอ อาร์ เบย์ จำกัด
ARbay Company Limited
31 st Floor Bangkok Insurance Building
25 South Sathorn road Thungmahamek
Sathorn Bangkok 10120 THAILAND
T +66 (0) 2286 8199
F +66 (0) 2286 2863
info@arbay.co.th

CONSULTANT :

Qbic Engineers & Architects Co.,Ltd.
8 Soi KALONG 4 SANAMBINNAM ROAD,
THASAI SUB-DISTRICT, MUANG NONTHABURI DISTRICT
, NONTHABURI.
Tel 662-950-4374
Fax 662-580-3231
E-Mail : qbic@qbic.co.th, www.qbic.co.th
QBIC ENGINEERS AND ARCHITECTS CO.,LTD.

CONSULTANT :

MITR
MITR TECHNICAL CONSULTANT CO.,LTD.
1168/8 12th FLOOR, LUMPINI TOWER BUILDING,
RAMA IV RD., THUNGMAHAMEK, SATHORN, BANGKOK 10120, THAILAND
TEL : 0-2679-9079-84
FAX : 0-2679-9085 E-mail: mitr_dd@mitr.com

Architect :	SIGNATURE
ประกิต พนานุรัตน์ วสถ. 580 ที่อยู่ 251/1 ถ.จารุเมือง แขวงรองเมือง เขตปทุมวัน กรุงเทพมหานคร โทรศัพท์ 02-286-8199	
Structural Engineer :	SIGNATURE
วิศวกรผู้ออกแบบโครงสร้าง	
ณัฐสม สงวนวงษ์ วย 1423 ที่อยู่ 2/1 ซ.รามคำแหง 150 ถ.รามคำแหง แขวง สะพานสูง เขต สะพานสูง กทม. 10240	
Structural Inspector :	SIGNATURE
วิศวกรผู้ตรวจสอบโครงสร้าง	
โกมล จุฑาภัทร วย 964 ที่อยู่ 24/18 ซ.นวมินทร์ 129 ถ. นวมินทร์ แขวง นวลจันทร์ เขต บึงกุ่ม กทม. 10230	
Electrical Engineer :	SIGNATURE
วิศวกรผู้ออกแบบระบบไฟฟ้ากำลัง	
นายสุภัทร บูรณวิทย์ วฟก.1265 ที่อยู่ 21 ซอยทานสัมฤทธิ์ 13 ตำบลท่าทราย อ.เมืองนนทบุรี จ.นนทบุรี 11000	
Mechanical Engineer :	SIGNATURE
วิศวกรผู้ออกแบบระบบเครื่องกลและปรับอากาศ	
นายประสิทธิ์ เกียวสุนทร วก.1221 ที่อยู่ 44/372 ซอยบางกระดี่ 35/1 แขวงแสมดำ เขตบางขุนเทียน กทม. 10150	ประสิทธิ์
Sanitary Engineer :	SIGNATURE
วิศวกรผู้ออกแบบระบบสุขาภิบาล และดับเพลิง	
นายทศวรรษ สันนฤทธิ์ วส. 215 ที่อยู่ บ้านเลขที่ 99/107 หมู่ที่ 3 ต.ศีรษะจรเข้น้อย อ.บางเสาธง จ.สมุทรปราการ 10540	ทศวรรษ

ISSUE/REVISION

REV.	DESCRIPTION	DATE
A	90% DEVELOPED	09/05/2026

PROJECT NAME :

GEDC 01

LOCATION:
Nikhom Phattana district, Rayong ,industrial estate,CPGC

BUILDING :

90% DEVELOPED

TITLE :

VERTICAL TRANSPORTATION
SYSTEM SCHEDULE

JOB NO.	SCALE 1:50
DRAWN LW	REF.
CHECKED LJC	DWG.NO. MPK00-90-VT-SC-001
APPROVED LXD	
DATE 2026.05.09	

NOTE : THIS PRINT IS OF A CONFIDENTIAL NATURE, IT SHALL NOT BE TRACED,PHOTOGRAPHED,PHOTOSTATED OR REPRODUCED IN ANY MANER,NOR USED FOR ANY PURPOSE WHATSOEVER EXCEPT BY WRITTEN PERMISSION