Water Ledger Texas: methods brief

Model version 1.11 · data snapshot 2026-11-09 · waterledger.org · github.com/northlinehydrology/waterledger

What it estimates

For any city, town, village, township or county in Texas, Water Ledger estimates the water a data center campus of a given size and cooling design would withdraw, consume and return on an average day and on a 1-in-10-year peak day, and compares it with the local water system, sewer plant, downstream waters and electric utility. All inputs are public data.

Data

Category	Source	In Texas
Places	Census TIGERweb: incorporated places; county subdivisions that are governments; counties	1,481 places: 1,227 cities, towns and villages; 254 counties
Water supply	EPA community water system service areas, with SDWIS population and connections	4,582 systems; 95% of places have one mapped
Wastewater	EPA Clean Watersheds Needs Survey 2022 (design flow) matched to ECHO (recent flow, receiving water)	1,456 plants; 99.3% of places have one within 40 km
Receiving waters	USGS Watershed Boundary Dataset; EPA ATTAINS (TCEQ, 2026 report)	1,139 watersheds with a downstream path; 3,086 watersheds on those paths
Climate	Copernicus ERA5, 1995-2024, at each place's 0.25-degree cell (the nearest at least half land), corrected toward nearby NOAA and Environment and Climate Change Canada stations; NOAA stations by climate division for rainfall and road salt; Atlas 14 design storms; Climate at a Glance rainfall	616 cells, 563 corrected toward stations; 10 climate divisions
Energy	HIFLD retail service territories (PNNL copy); EIA-861 sales and peaks; EIA-923 plant reports for power-plant water	151 utilities with loads; grid regions: EPE, ERCO, MISO, PNM, SWPP

Overall method (all states)

Weather (model 1.9). Each place takes its hourly temperature and dew point, 1995-2024, from its own ERA5 grid cell (0.25 degrees, about 10 km away), or the nearest cell at least half land where its own is mostly water. Its weather is corrected month by month and by time of day toward up to four weather stations within 100 km: where the cell is under 90% land, stations near the shore, since ERA5 runs cool beside lakes and the sea; elsewhere, stations inland. Hybrid and assist estimates depend most on the hottest hours, and so on this.

Cooling water. Hourly temperature and humidity drive the heat rejected by the campus under four cooling designs: cooling towers; hybrid, evaporative in warm weather only; dry coolers with adiabatic pre-cooling above a switch temperature (20-30 C, assumed); and closed loop with no evaporative cooling. Evaporation is the heat load times the evaporative fraction of Rutberg et al. (2011), as used in the USGS cooling tower method. Blowdown is evaporation divided by cycles of concentration minus one (DOE FEMP).

Uncertainty. Each estimate is 400 Monte Carlo runs, sampling 17 cooling parameters from published or estimated ranges; estimated ranges are marked [A]. We report the 10th, 50th and 90th percentiles. The peak day is the 1-in-10-year maximum day, taken as the 90th percentile of the annual maximum daily withdrawal.

Other water. Staff use, 10-30 gallons a person a day, scaled to the number of people on site; maintenance and cleaning, up to 2,000 gallons a day plus 2-20 per MW, bracketed by applicants' projections; and make-up water for closed loops, which lose 1-5% of their volume a year to leaks.

Source and wastewater. If a community water system is mapped in the place, the campus is served by it. If not, a closed loop connects to the nearest system serving more than 3,300 people when it is within 10 km; all other cases use new wells. Discharge goes to the nearest sewer plant if it is within reach and, for evaporative designs, has enough unused capacity for the blowdown. Otherwise closed loops use an on-site septic system and evaporative designs discharge directly.

Downstream. The place's main HUC-12 watershed is traced downstream for up to 25 watersheds, across state lines where needed, with the EPA-listed impairments and TMDLs for each.

Electricity use. Worked out hour by hour from the same weather and heat balance as the cooling water (after Lei and Masanet 2022): computers, power losses, fans, pumps, and chillers when outside air is too warm. Some inputs are assumptions, marked [A], including how much of a campus is liquid-cooled.

Electricity. Utilities come from the national retail territory layer, ordered by number of customers because it draws many small utilities as whole counties. Power-plant water is each state's own: 2024 plant reports to EIA, with Macknick et al. (2012) factors where a report is implausible or missing, weighted for imports, updated with 2022 reports and Siddik et al. (2024) on the same

basis. States can add their own layers (reported water use, wells, coldwater streams, state rules) on top of this method.

What is specific to Texas

Texas follows the overall method with national data throughout. What is particular to it:

Weather. 616 ERA5 cells; 563 cells corrected toward 67 stations: Abilene Regional Airport, Alice International Arpt, Altus Afb Airport, Amarillo Rick Husband Intl Airport, Angelina County Airport, Aransas County Airport, Austin-Bergstrom Intl Airport, Austin-Camp Mabry, Barksdale Air Force Base, Brownsville/S Padre Island Intl Ap, Burnet Municipal Cradock Field Airport, Cannon Afb Airport, Cavern City Air Trml Arpt, Childress Municipal Arpt, Clayton Municipal Airpark Airport, Clinton-Sherman Airport, Corpus Christi International Airport, Corpus Christi Nas, Cotulla-La Salle Co Arpt, Dallas Executive Airport, Dallas/Ft Worth International Ap, Del Rio International Airport, Denton Municipal Airport, Dyess Air Force Base, East Texas Regional Arpt, Easterwood Field Airport, El Paso International Airport, Fort Stockton-Pecos Co Apt, Fort Worth Alliance Arpt, Fort Worth Naval Air Station Jrb/Carswell Field, Frederick Municipal Airpt, Ft Worth Meacham Intl Arpt, G Bush Intercontinental Ap/Houston Ap, Hobart Municipal Airport, Hondo Municipal Airport, Hooks Memorial Airpt, Kimble County Airport, Kingsville Nas, Lackland Air Force Base (Kelly Field Annex), Lake Charles Regional Airport, Laughlin Afb Airport, Lawton-Fort Sill Rgnl Arpt, Lubbock International Airport, Mc Allen Miller Intl Arpt, Mckinney Municipal Arpt, Midland International Airport, Mineral Wells Airport, Municipal Airport, Palacios Municipal Airport, Randolph Afb Airport, Robert Gray Aff Airport, San Angelo Regional/Maths Field Ap, San Antonio International Airport, Scholes Intl At Glston Apt, Sheppard Afb/Wichita Falls Muni Ap, Shreveport Downtown Arpt, Shreveport Regional Airport, Southeast Texas Regional Airport, Stinson Minicipal Airport, Texarkana Regional Airport-Webb Field, Tucumcari Municipal Arpt, Tyler Pounds Regional Arpt, Valley International Arpt, Victoria Regional Airport, Waco Regional Airport, William P. Hobby Airport, Winkler County Airport. Rainfall and road salt come from 10 NOAA climate divisions, with these stations: Lubbock International Airport; Abilene Regional Airport; Fort Worth Naval Air Station Jrb/Carswell Field; Angelina County Airport; Winkler County Airport; Kimble County Airport; Victoria Regional Airport; G Bush Intercontinental Ap/Houston Ap; Cotulla-La Salle Co Arpt; Mc Allen Miller Intl Arpt.

Places. 1,227 cities, towns and villages; 254 counties. Counties are included so that unincorporated land is covered.

Water quality. Impairments and TMDLs from TCEQ's 2026 integrated report, through EPA ATTAINS.

Not yet added: Texas's reported water use by sector, domestic wells, coldwater streams, lake-source cooling and state rules.

Example: 300 MW of IT capacity in Austin

Million gallons per day, median with the 10th-90th percentile range. Peak day is the 1-in-10-year maximum day. Consumed water is evaporated or otherwise not returned. Source and wastewater are the defaults described above (muni: community water system; sewer: nearest sewer plant).

Design	Withdrawn, average day	Withdrawn, peak day	Consumed, average day	Source / wastewater
Cooling towers	2.26 (1.81-2.80)	2.98 (2.42-3.66)	1.79 (1.41-2.13)	muni / sewer
Hybrid	0.51 (0.41-0.64)	2.16 (1.73-2.66)	0.40 (0.32-0.48)	muni / sewer
Closed loop with assist	0.73 (0.56-0.98)	2.67 (2.08-3.44)	0.58 (0.47-0.74)	muni / sewer
Closed loop	0.01 (<0.01-0.01)	0.01 (<0.01-0.01)	<0.01	muni / sewer

Checks on this snapshot

Coverage of Texas's places: water system 95%, watersheds 100%, utilities 100%, climate division 100%, a sewer plant within 40 km 99.3%. 50 randomly selected places were run through every step and cooling design with 0 errors. Most places without a mapped water system are rural areas on private wells.

Limits

These are screening estimates from public data, intended for comparing designs and sizes before an applicant's figures are available. They are not a substitute for facility design data, a utility capacity analysis or a permit review. Downstream paths are traced between HUC-12 watersheds, not along individual stream reaches. EPA assessments are from each state's most recent integrated report. Weather covers 1995-2024.