Water Ledger Michigan: methods brief

Model version 1.3 · data snapshot 2026-10-30 · waterledger.org · github.com/northlinehydrology/waterledger

What it estimates

For any city or township in Michigan, Water Ledger estimates the water a data center campus of a given size and cooling design would withdraw, consume and return on an average day and on a 1-in-10-year peak day, and compares it with the local water system, sewer plant, downstream waters and electric utility. All inputs are public data.

Data

Category	Source	In Michigan
Places	Census TIGERweb: county subdivisions (Michigan's cities and townships)	1,541 places
Water supply	EPA community water system service areas, with SDWIS population and connections	411 systems
Wastewater	EPA Clean Watersheds Needs Survey 2022 (design flow) matched to ECHO (recent flow, receiving water)	394 plants
Receiving waters	USGS Watershed Boundary Dataset; EPA ATTAINS (Michigan EGLE, 2026 report)	1,085 watersheds with a downstream path; 1,354 watersheds on those paths
Climate	ERA5 reanalysis (Open-Meteo), 1995-2024, at eight Michigan regions; Atlas 14 design storms; Climate at a Glance rainfall	8 regions
Energy	MPSC territories; EIA-861 sales and peaks	57 utilities with loads; grid regions: MISO, PJM

Overall method (all states)

Weather. Hourly NOAA station records, 1995-2024, one station per NOAA climate division. Hybrid and assist estimates depend on the hottest hours and so on the weather source: in tests against ERA5 reanalysis at eight sites, station records gave cooling tower estimates within about 1%, and hybrid and assist estimates 4-50% higher (2-5 times higher at the coolest sites).

Cooling water. Hourly temperature and humidity drive the heat rejected by the campus under four cooling designs: cooling towers; hybrid, evaporative in warm weather only; dry coolers with adiabatic pre-cooling above a switch temperature (20-30 C, assumed); and closed loop with no evaporative cooling. Evaporation is the heat load times the evaporative fraction of Rutberg et al. (2011), as used in the USGS cooling tower method. Blowdown is evaporation divided by cycles of concentration minus one (DOE FEMP).

Uncertainty. Each estimate is 200 Monte Carlo runs, sampling 17 cooling parameters from published or estimated ranges; estimated ranges are marked [A]. We report the 10th, 50th and 90th percentiles. The peak day is the 1-in-10-year maximum day, taken as the 90th percentile of the annual maximum daily withdrawal.

Other water. Staff use, 10-30 gallons a person a day, scaled to the number of people on site; maintenance and cleaning, up to 2,000 gallons a day plus 2-20 per MW, bracketed by applicants' projections; and make-up water for closed loops, which lose 1-5% of their volume a year to leaks.

Source and wastewater. If a community water system is mapped in the place, the campus is served by it. If not, a closed loop connects to the nearest system serving more than 3,300 people when it is within 10 km; all other cases use new wells. Discharge goes to the nearest sewer plant if it is within reach and, for evaporative designs, has enough unused capacity for the blowdown. Otherwise closed loops use an on-site septic system and evaporative designs discharge directly.

Downstream. The place's main HUC-12 watershed is traced downstream for up to 25 watersheds, across state lines where needed, with the EPA-listed impairments and TMDLs for each.

Electricity. Utilities come from the national retail territory layer, ordered by number of customers because it draws many small utilities as whole counties. Power-plant water is each state's own: 2024 plant reports to EIA, with Macknick et al. (2012) factors where a report is implausible or missing, weighted for imports, updated with 2022 reports and Siddik et al. (2024) on the same basis. States can add their own layers (reported water use, wells, coldwater streams, state rules) on top of this method.

What is specific to Michigan

Weather. ERA5 reanalysis at eight Michigan climate regions instead of station records. Michigan stays on ERA5 until a reviewed model update.

Places and electricity. Cities and townships only (county subdivisions); utility territories from the Michigan Public Service Commission.

State layers. EGLE reported water use by county and sector, domestic wells (EGLE Wellogic), designated trout streams (Michigan DNR), Great Lakes lake-source cooling, and Michigan rules (Part 327 withdrawals, Part 22 septic limits, Part 91 soil erosion, Rule 57 and temperature standards). waterledger.org also tracks Michigan data center proposals and moratoria.

Example: 300 MW of IT capacity in Gaines Charter Township

Million gallons per day, median with the 10th-90th percentile range. Peak day is the 1-in-10-year maximum day. Consumed water is evaporated or otherwise not returned. Source and wastewater are the defaults described above (muni: community water system; sewer: nearest sewer plant).

Design	Withdrawn, average day	Withdrawn, peak day	Consumed, average day	Source / wastewater
Cooling towers	1.93 (1.55-2.33)	2.43 (1.93-2.92)	1.54 (1.25-1.84)	muni / sewer
Hybrid	0.07 (0.04-0.13)	1.53 (1.15-2.04)	0.05 (0.03-0.10)	muni / sewer
Closed loop with assist	0.08 (0.02-0.21)	1.06 (0.64-1.88)	0.06 (0.02-0.16)	muni / sewer
Closed loop	0.01 (<0.01-0.01)	0.01 (<0.01-0.01)	<0.01	muni / sewer

Checks on this snapshot

The Michigan snapshot includes the site's own data files, so results are identical from either source. Tests also confirm that the shared-format files match Michigan's for a random sample of places.

Limits

These are screening estimates from public data, intended for comparing designs and sizes before an applicant's figures are available. They are not a substitute for facility design data, a utility capacity analysis or a permit review. Downstream paths are traced between HUC-12 watersheds, not along individual stream reaches. EPA assessments are from each state's most recent integrated report. Weather covers 1995-2024.