# Water Ledger Ohio: methods brief

Model version 1.3 · data snapshot 2026-10-30 · waterledger.org · github.com/northlinehydrology/waterledger

## What it estimates

For any city, town, village, township or county in Ohio, Water Ledger estimates the water a data center campus of a given size and cooling design would withdraw, consume and return on an average day and on a 1-in-10-year peak day, and compares it with the local water system, sewer plant, downstream waters and electric utility. All inputs are public data.

## Data

| Category | Source | In Ohio |
|---|---|---|
| Places | Census TIGERweb: incorporated places; county subdivisions that are governments; counties | 2,318 places: 922 cities, towns and villages; 1,308 townships; 88 counties |
| Water supply | EPA community water system service areas, with SDWIS population and connections | 1,077 systems; 76% of places have one mapped |
| Wastewater | EPA Clean Watersheds Needs Survey 2022 (design flow) matched to ECHO (recent flow, receiving water) | 669 plants; 100% of places have one within 40 km |
| Receiving waters | USGS Watershed Boundary Dataset; EPA ATTAINS (Ohio EPA, 2024 report) | 1,198 watersheds with a downstream path; 1,419 watersheds on those paths |
| Climate | NOAA ISD station records, 1995-2024, one station per NOAA climate division; Atlas 14 design storms; Climate at a Glance rainfall | 10 climate divisions |
| Energy | HIFLD retail service territories (PNNL copy); EIA-861 sales and peaks; EIA-923 plant reports for power-plant water | 121 utilities with loads; grid regions: LGEE, MISO, PJM |

## Overall method (all states)

**Weather.** Hourly NOAA station records, 1995-2024, one station per NOAA climate division. Hybrid and assist estimates depend on the hottest hours and so on the weather source: in tests against ERA5 reanalysis at eight sites, station records gave cooling tower estimates within about 1%, and hybrid and assist estimates 4-50% higher (2-5 times higher at the coolest sites).

**Cooling water.** Hourly temperature and humidity drive the heat rejected by the campus under four cooling designs: cooling towers; hybrid, evaporative in warm weather only; dry coolers with adiabatic pre-cooling above a switch temperature (20-30 C, assumed); and closed loop with no evaporative cooling. Evaporation is the heat load times the evaporative fraction of Rutberg et al. (2011), as used in the USGS cooling tower method. Blowdown is evaporation divided by cycles of concentration minus one (DOE FEMP).

**Uncertainty.** Each estimate is 200 Monte Carlo runs, sampling 17 cooling parameters from published or estimated ranges; estimated ranges are marked [A]. We report the 10th, 50th and 90th percentiles. The peak day is the 1-in-10-year maximum day, taken as the 90th percentile of the annual maximum daily withdrawal.

**Other water.** Staff use, 10-30 gallons a person a day, scaled to the number of people on site; maintenance and cleaning, up to 2,000 gallons a day plus 2-20 per MW, bracketed by applicants' projections; and make-up water for closed loops, which lose 1-5% of their volume a year to leaks.

**Source and wastewater.** If a community water system is mapped in the place, the campus is served by it. If not, a closed loop connects to the nearest system serving more than 3,300 people when it is within 10 km; all other cases use new wells. Discharge goes to the nearest sewer plant if it is within reach and, for evaporative designs, has enough unused capacity for the blowdown. Otherwise closed loops use an on-site septic system and evaporative designs discharge directly.

**Downstream.** The place's main HUC-12 watershed is traced downstream for up to 25 watersheds, across state lines where needed, with the EPA-listed impairments and TMDLs for each.

**Electricity.** Utilities come from the national retail territory layer, ordered by number of customers because it draws many small utilities as whole counties. Power-plant water is each state's own: 2024 plant reports to EIA, with Macknick et al. (2012) factors where a report is implausible or missing, weighted for imports, updated with 2022 reports and Siddik et al. (2024) on the same basis. States can add their own layers (reported water use, wells, coldwater streams, state rules) on top of this method.

## What is specific to Ohio

Ohio follows the overall method with national data throughout. What is particular to it:

**Weather.** 10 NOAA climate divisions, with these stations: Findlay Airport (2 divisions); Cleveland-Hopkins International Ap; J.M.Cox Dayton International Airport; Port Columbus International Airport; Akron-Canton Regional Airport (2 divisions); Cina Muni Apt/Lukn Fd Apt; Tri-State/M.J.Fergus; Zanesville Municipal Arpt.

**Places.** 922 cities, towns and villages; 1,308 townships that are governments; 88 counties. Counties are included so that unincorporated land is covered.

**Water quality.** Impairments and TMDLs from Ohio EPA's 2024 integrated report, through EPA ATTAINS.

**Not yet added:** Ohio's reported water use by sector, domestic wells, coldwater streams, lake-source cooling and state rules.

## Example: 300 MW of IT capacity in Columbus

Million gallons per day, median with the 10th-90th percentile range. Peak day is the 1-in-10-year maximum day. Consumed water is evaporated or otherwise not returned. Source and wastewater are the defaults described above (muni: community water system; sewer: nearest sewer plant).

| Design | Withdrawn, average day | Withdrawn, peak day | Consumed, average day | Source / wastewater |
|---|---|---|---|---|
| Cooling towers | 1.99 (1.59-2.39) | 2.45 (1.94-2.94) | 1.58 (1.28-1.88) | muni / sewer |
| Hybrid | 0.15 (0.08-0.23) | 1.61 (1.26-2.08) | 0.11 (0.06-0.17) | muni / sewer |
| Closed loop with assist | 0.14 (0.05-0.33) | 1.22 (0.76-2.01) | 0.11 (0.04-0.25) | muni / sewer |
| Closed loop | 0.01 (<0.01-0.01) | 0.01 (<0.01-0.01) | <0.01 | muni / sewer |

## Checks on this snapshot

Coverage of Ohio's places: water system 76%, watersheds 100%, utilities 100%, climate division 100%, a sewer plant within 40 km 100%. 50 randomly selected places were run through every step and cooling design with 0 errors. Most places without a mapped water system are rural areas on private wells.

## Limits

These are screening estimates from public data, intended for comparing designs and sizes before an applicant's figures are available. They are not a substitute for facility design data, a utility capacity analysis or a permit review. Downstream paths are traced between HUC-12 watersheds, not along individual stream reaches. EPA assessments are from each state's most recent integrated report. Weather covers 1995-2024.

Planning-level hydrologic assessment. Not engineering design. Built with the open waterledger Python packages (waterledger 3.2.0); methods, parameters and sources: waterledger.org and the package repository. Northline Hydrology.