Water Ledger Virginia: methods brief

Model version 1.2 · data snapshot 2026-10-29 · waterledger.org · github.com/northlinehydrology/waterledger

What it estimates

For any city, town, village, township or county in Virginia, Water Ledger estimates the water a data center campus of a given size and cooling design would withdraw, consume and return on an average day and on a 1-in-10-year peak day, and compares it with the local water system, sewer plant, downstream waters and electric utility. All inputs are public data.

Data

Category	Source	In Virginia
Places	Census TIGERweb: incorporated places; county subdivisions that are governments; counties	322 places: 227 cities, towns and villages; 95 counties
Water supply	EPA community water system service areas, with SDWIS population and connections	903 systems; 89% of places have one mapped
Wastewater	EPA Clean Watersheds Needs Survey 2022 (design flow) matched to ECHO (recent flow, receiving water)	217 plants; 99.7% of places have one within 40 km
Receiving waters	USGS Watershed Boundary Dataset; EPA ATTAINS (21VASWCB, 2024 report)	271 watersheds with a downstream path; 770 watersheds on those paths
Climate	NOAA ISD station records, 1995-2024, one station per NOAA climate division; Atlas 14 design storms; Climate at a Glance rainfall	6 climate divisions
Energy	HIFLD retail service territories (PNNL copy); EIA-861 sales and peaks; Siddik et al. 2024 water per kWh by grid region	36 utilities with loads; grid regions: CPLE, DUK, PJM, TVA

Method

Cooling water. Hourly temperature and humidity for 1995-2024 drive the heat rejected by the campus under four cooling designs: cooling towers; hybrid, evaporative in warm weather only; closed loop with evaporative assist on the hottest hours (dry-bulb above roughly 82-88 F); and closed loop with no evaporative cooling. Evaporation is the heat load times the evaporative fraction of Rutberg et al. (2011), as used in the USGS cooling tower method. Blowdown is evaporation divided by cycles of concentration minus one (DOE FEMP).

Uncertainty. Each estimate is 200 Monte Carlo runs, sampling 15 cooling parameters from published or estimated ranges; estimated ranges are marked [A]. We report the 10th, 50th and 90th percentiles. The peak day is the 1-in-10-year maximum day, taken as the 90th percentile of the annual maximum daily withdrawal.

Other water. Staff use, scaled to the number of people on site, and make-up water for closed loops, which lose 1-5% of their volume a year to leaks.

Source and wastewater. If a community water system is mapped in the place, the campus is served by it. If not, a closed loop connects to the nearest system serving more than 3,300 people when it is within 10 km; all other cases use new wells. Discharge goes to the nearest sewer plant if it is within reach and, for evaporative designs, has enough unused capacity for the blowdown. Otherwise closed loops use an on-site septic system and evaporative designs discharge directly.

Downstream. The place's main HUC-12 watershed is traced downstream for up to 25 watersheds, across state lines where needed, with the EPA-listed impairments and TMDLs for each.

Weather and state data

Weather. NOAA station records, one station per climate division (Richmond International Airport (2 divisions); Lynchburg Rgnl/Preston Glenn Fld Ap; Washington Dulles International Ap; Roanoke Regional/Woodrum Field Ap; Raleigh County Memorial Airport). The weather source matters most for hybrid and assist designs, which depend on the hottest hours. In tests against ERA5 reanalysis at eight sites, station records gave cooling tower estimates within about 1%, and hybrid and assist estimates 4-50% higher (2-5 times higher at the coolest sites).

Not yet included: Virginia's reported water use by sector, domestic wells, coldwater streams, lake-source cooling and state rules. Utilities are ordered by number of customers, because the national territory layer draws many small utilities as whole counties.

Example: 300 MW of IT capacity in Loudoun County

Million gallons per day, median with the 10th-90th percentile range. Peak day is the 1-in-10-year maximum day. Consumed water is evaporated or otherwise not returned. Source and wastewater are the defaults described above (muni: community water system; sewer: nearest sewer plant).

Design	Withdrawn, average day	Withdrawn, peak day	Consumed, average day	Source / wastewater
Cooling towers	2.43 (1.99-2.81)	3.02 (2.46-3.50)	1.94 (1.62-2.25)	muni / sewer
Hybrid	0.23 (0.16-0.33)	2.29 (1.88-2.79)	0.18 (0.12-0.27)	muni / sewer
Closed loop with assist	0.02 (0.01-0.04)	0.37 (0.22-0.55)	0.01 (0.01-0.03)	muni / sewer
Closed loop	<0.01	<0.01	<0.01	muni / sewer

Checks on this snapshot

Coverage of Virginia's places: water system 89%, watersheds 100%, utilities 98%, climate division 99.7%, a sewer plant within 40 km 99.7%. 50 randomly selected places were run through every step and cooling design with 0 errors. Most places without a mapped water system are rural areas on private wells.

Limits

These are screening estimates from public data, intended for comparing designs and sizes before an applicant's figures are available. They are not a substitute for facility design data, a utility capacity analysis or a permit review. Downstream paths are traced between HUC-12 watersheds, not along individual stream reaches. EPA assessments are from each state's most recent integrated report. Weather covers 1995-2024.

Planning-level hydrologic assessment. Not engineering design. Built with the open waterledger Python packages (waterledger 2.0.0); methods, parameters and sources: waterledger.org and the package repository. Northline Hydrology.