Case study

1. Setup

Every controller runs in every situation 100 times, with the seeds 1 to 100. All controllers use the same seeds, so they have the same random numbers. A run has 400 steps. The six situations are: S1 is the start of the program, S2 is an unknown inflow change (u_0 goes from 50 to 62), S3 is a set point change (from 74 to 20), S4 is heavy rain and then strong evaporation, S5 is S2 with noise on the level reading, and S6 is an extreme change of the flows (u_0 goes from 50 to 75).

The weights of the controllers come from the tuning done in modeling of the experimental part:

Controller	Weights
P	K_P= 6
PI	K_P= 3, K_i= 0.2
PID	K_P= 14, K_i= 0.02, K_d= 100
PID+	K_P= 4, K_i= 0.2, K_d= 10
Ours	K_P= 10, K_i= 0.2, K_d= 25, k = 0.1 for f_p, 0.01 for f_i, 0 for f_d, dead-band 0.2

We use the metrics from chapter 6 of the modeling of the experimental part. A smaller IAE means a smaller total error.

2. E1: comparison with P, PI, PID and PID+

Table 4.1 shows the mean IAE of 100 runs, with the standard deviation in brackets.

IAE mean (std)	S1	S2	S3	S4	S5	S6
P	1444 (124)	2450 (125)	2244 (142)	2014 (281)	2474 (118)	3665 (144)
PI	1843 (76)	1963 (76)	2768 (102)	2476 (230)	2015 (76)	2272 (167)
PID	1441 (76)	1394 (90)	1897 (90)	1942 (234)	1633 (107)	1919 (110)
PID+	1142 (147)	1262 (147)	1776 (180)	1733 (193)	1379 (139)	1588 (165)
Ours	1083 (104)	1270 (102)	1631 (130)	1560 (206)	1606 (98)	1757 (118)

Table 4.1. The IAE of the five controllers in the six situations (E1)




Figure 4.1. The IAE of the five controllers in the six situations (E1)

Table 4.2 shows in how many runs (percent) the level stays under 1 percent from the set point until the end, and Table 4.3 shows the valve movement.

Settled runs (%)	S1	S2	S3	S4	S5	S6
P	100	0	100	100	0	0
PI	100	100	100	100	100	100
PID	63	73	82	56	41	17
PID+	100	100	100	100	96	100
Ours	100	81	100	100	22	75

Table 4.2. The percent of settled runs (E1)

Valve movement	S1	S2	S3	S4	S5	S6
P	164	188	303	439	772	254
PI	119	139	221	328	479	203
PID	1130	1127	1131	1138	1158	1131
PID+	100	136	191	390	900	180
Ours	154	258	278	533	1047	275

Table 4.3. The valve movement (the sum of the changes of the valve position) (E1)

Because the runs are paired, we also count in how many runs our controller has a smaller IAE than the other one (Table 4.4). The last column is the mean difference of the IAE between PID+ and ours, so a negative number means that PID+ is better.

Ours is better in (of 100 runs)	vs P	vs PI	vs PID	vs PID+	Mean IAE difference vs PID+
S1	100	100	100	63	59
S2	100	100	91	35	−8
S3	100	100	95	86	145
S4	100	100	96	87	173
S5	100	100	63	6	−227
S6	100	100	92	15	−169

Table 4.4. The paired comparison of the IAE (E1)

What we see:

- **P:** the level stays away from the set point when u_0 is not 50. The final error is 4.00 in S2 and S5 and 8.33 in S6. This is what we calculated in 3.3: with K_P = 6 the valve is u^* = 50 − 3 * e, so for u_0 = 62 we get e = −4, and for u_0 = 75 we get e = −8.33. P never settles in S2, S5 and S6.
- **PI:** the integral removes this error, and PI settles in all the runs. But it is slow at the start and when the set point changes (the overshoot is 25.8 in S1 and 19.7 in S3), and it has the biggest IAE in S3 and S4.
- **PID:** it has about the same valve movement in all the situations (1127 to 1158), 7 times more than ours in S1. The reason is that the derivative of the raw error reacts to the random gain r(k) of the valve. It settles only in 17 to 82 percent of the runs.
- **PID+:** it is the strongest of the four. The filtered derivative and the anti-windup fix the problems of the PID.
- **Ours against P, PI and PID:** our IAE is smaller in all the 100 runs against P and PI in every situation, and in 91 to 100 runs against PID (63 in S5).
- **Ours against PID+:** ours is better in S1 (63 runs of 100), S3 (86) and S4 (87). In S2 the two are almost equal (ours is better in 35 runs, the mean difference is −8). In S5 and S6 PID+ is clearly better (ours is better in only 6 and 15 runs).
- **Start and set point change:** in S1 and S3 ours is the fastest (46 and 30 steps to settle, against 57 and 49 for PID+) and it has a smaller overshoot than PID+ (8.6 against 13.0 in S1, 5.9 against 10.3 in S3). The valve of PID+ changes direction 198 times in S1, and ours only 28 times (in S3, 257 against 48; in S4, 234 against 82).
- **Valve movement:** ours moves the valve more than PID+ in all the situations (154 against 100 in S1, 533 against 390 in S4).

Figure 4.2 shows one run of S3 (seed 1). After the set point goes down to 20, ours reaches it faster than PID+.




Figure 4.2. The level in S3 for PID+ and for our controller (seed 1)