Related work

1. PID control and its extensions

The PID controller is the most used controller in industry [6], [8], [10], and the articles about canals say the same [5]. The first rules for tuning it come from Ziegler and Nichols [9], and in practice the weights are often found by trial. We also found our weights by trial, with a search in the program (chapter 8 in modeling).

- **Anti-windup [7], [11].** When the valve is at its limit, the integral can grow without effect, and this is called windup. The usual solution is to stop adding to the integral at the limit. Our PID+ does this. Our controller limits the integral to ±1500 and it also clears it when the error changes sign. This is different from the usual anti-windup, and in our tests it helps at the start but it hurts when the null position u_0 is not 50.
- **Filtering and noise [13].** Filtered PID and PIDD2 controllers for integrating processes with measurement noise are described in [13]. A tank level is an integrating process. Our smoothing (the average with the previous value) has the same purpose, and our tests show that it is the most important part of our controller.
- **Second derivative (PIDD2) [12], [13], [14].** These articles give tuning rules for controllers with a second derivative, for oscillatory systems with delay [12], for integrating processes [13] and for processes with inertia and delay [14]. The rules start from a model of the process. We use the second derivative too ($\frac{3}{5}$ of the rate and $\frac{2}{5}$ of the acceleration in one derivative part), but we found the weights by search, without a model.

2. Water-level control in canals and reservoirs

The closest problem in the literature is the control of the water level in canals and reservoirs. A classification of the control algorithms for canals is in [16], an overview of the control of irrigation networks is in [17], and the models are in [15]. We took from [15] and from [1] the idea of a tank as an integrator, which is the model of our simulator (chapter 2 of the modeling). The table shows the five articles that we studied in detail.

Article	What it does	Needs a model?	Metrics	Similar to ours	Different from ours
Weyer [1]	PI controllers, one for each pool of a real canal, with a filter and a feedforward term; field tests	Yes, models found by identification are used to design the controllers	Level responses in field tests	PI/PID structure, dead-band on the gate movement (0.015 m), and the outflows to the farmers are not measured,	The design needs a model of each pool

Article	What it does	Needs a model?	Metrics	Similar to ours	Different from ours
				they are disturbances	
Nogueira and Pinho [2]	A nonlinear control law for reservoirs in cascade, with a proof that the level goes to the reference	Yes, the discrete water balance of the reservoirs	Simulations with 2 reservoirs	Steps in discrete time, inflow from rain only estimated and with noise, a minimum change of the flow (like a dead-band)	The control law is not a PID, and it uses the model
Wu et al. [3]	A target interval for the level, a feedforward schedule and a PI-based feedback, tested on a long canal (60 pools and 61 gates)	Yes, the volume balance and the delivery schedule	Number of gate operations, gate openings, levels	It wants fewer gate movements, and it keeps the level in an interval	It uses a schedule of the demand (feedforward), and it is for a real canal
Shahverdi et al. [4]	A PID controller in a hydraulic simulator (HEC-RAS), inside it and from MATLAB, tested on a canal	Yes, the hydraulic model of the simulator	MAE, IAE, efficiency, equity, adequacy	A PID with the weights found by trial and error, IAE as a metric	The process is a hydraulic model of a canal, the controller is a plain PID
Li et al. [5]	A hybrid controller: a feedforward part based on a model and an LQR feedback, on the ASCE Test Canal 2	Yes, a linear model of the canal	MAE, IAE, NIAQ, NIAW, transition time	Hybrid structure (feedforward and feedback), similar error indicators	It needs a model, and it is not a PID. The dead-band is zero in its tests

Table 2.1. The five articles about water-level control

The main difference is the same in all five articles: they use a model of the canal or of the reservoir, or a known or estimated flow. Our controller uses only the level and how it changes between two steps. This

is a possible advantage when the flows are unknown, but it also means that we cannot expect the precision of the controllers that use a model.