DENVER
THE MILE HIGH CITY

DEVELOPMENT SERVICES

Retail/Wholesale Food Establishment Plan Review Application

Application for Building Permits, Sewer Use and Drainage Permits (SUDP), and Health Plan Review for Food/Beverage, Marijuana Kitchens, and Dispensaries

Because all work at these locations must have a health review and inspections, all applications for building and SUDP permits must be logged in for review and cannot be reviewed at the permit counter. Plan reviewers may request additional information as necessary to complete the review.

Where to submit this application:

1) Fill out the included forms and compile the items listed on the checklist on either page 2 or 3.

2) Electronic Signatures. Apply seals and a valid electronic signature to any document (plans, reports, surveys, letters) prepared by an architect, engineer, or surveyor. Commercial building plans must be prepared by licensed architects and engineers. Ensure all documents are unlocked for editing so they can be reviewed.

    - Unsigned, unstamped, or invalidated electronic signatures cannot be accepted.
    - Download a guide with screenshots on how to create a valid electronic signature at www.denvergov.org/buildingcode.

3) Save all files as PDFs and name them: DocumentName_Address_Date.pdf (e.g., SitePlan_201WColfax_11-1-2017.pdf).

4) Submit all materials through e-permits at www.denvergov.org/epermits.

    a. Register for an e-permits account, then go to Development Services > Apply for a Permit and select the "building log" option to apply for a building permit online.

After submission:

Once the project is assigned a Log number, use www.denvergov.org/epermits to check review status and pay fees.

Resubmittals can be made through e-permits at www.denvergov.org/epermits using the same instructions as above.

Email resubmittals to PlanReview@denvergov.org only if the original submission was made via email.

Web Resource:

Visit the "Restaurants" webpage to learn more about what work needs reviews and building permits. Click at "Common Projects, needing permits" for more information.

Forms included in this application packet:

- Page 2 Submittal checklists (New buildings/additions/change of occupancy and tenant finish/remodel)
- Page 4 Plan review contact list
- Page 5 Health/SUDP plan review application

Submittal Checklist for New Buildings, Additions & Change of Occupancy

All documents must be original; copies will NOT be accepted.

Code References*	Items
	☐ Zoning permit (if required) or SDP approval to log in (Project Master #: _____) Or, for a simultaneous zoning and building code review… (not for SDP, landmark, design, or administrative reviews) ☐ Signed request form for a simultaneous review ☐ Zoning application and plans, including site plans, floor plans with mezzanines, elevations (if exterior improvements are proposed), and roof plans, as applicable. Find zoning applications at www.denvergov.org/commercialzoning.
DRMC 27-153	☐ Affordable Housing Fee Application
	☐ Plan Review Contact List
DBC Admin 133	☐ An official assigned address by Public Works (Include this address on all pages/documents submitted) DBC
Admin 133.2	☐ Construction drawings bearing the seal and valid electronic signature of the architect or engineer of record. ☐ Architectural/structural drawings ☐ Mechanical/Plumbing drawings ☐ Electrical drawings ☐ Energy code compliance sheets ☐ Plot plan locating all buildings relative to each other and to property lines
DBC Admin 133.2	☐ A complete 2015 IBC and 2016 DBC Code Analysis on the architectural plan that lists the following: ☐ Scope of Work ☐ Construction Type of Building ☐ Occupancy Classification ☐ Height of Building & Number of Stories ☐ IECC Compliance Method ☐ For Mixed Occupancy: Occupant load for each use ☐ Fire Alarm & Detection ☐ Gross Area in Sq. Ft. for Each Occupant
	☐ For SUDP: A Utility Site Plan showing the size, type, and location of water, storm sewer, and sanitary sewer lines
DBC Admin 133.4	☐ Survey, signed, dated, and with the seal of a registered land surveyor for New Buildings and Additions (Boundary survey including legal description and location of utilities.)
DBC Admin 133.2	☐ Project Specifications/Project Manual with architect and engineer seals, signatures & date of anyone of who helped with the design parameters
DBC Admin 133.2	☐ Structural Engineering Calculations, including a summary of design parameters with engineer's seal, signature, and date; a Table of Contents; and page numbers on calculations (required when structural sheets are submitted)
DBC Admin 133.2	☐ Soils Report, signed, sealed, and dated (see building code policy Admin 130.2A for reports older than 2 years)
DBC Admin 138	☐ Statement of Valuation Form
	☐ Asbestos Inspection Acknowledgement form to comply with state law (not required for new buildings)
DRMC 10-301	☐ Green Roof Declaration Form (only required for buildings over, or becoming over, 25,000 square feet in gross floor area). This is available to download at www.denvergov.org/greenroofs.
Additional items for restaurants, other food/ice	☐ Food and Beverage Menu, including all garnishes and desserts (or product list for marijuana facilities) ☐ Equipment Specifications for all food service equipment that identify the specific make/model to be used ☐ Floor Plan identifying the location, purpose, and size of kitchen equipment, food prep areas, and service areas ☐ Health Plan Review Application (starts on page 5)

Plans must be submitted separately by the applicant to the following, if applicable:

☐	Shoring & excavation – A separate log in submittal of shoring and excavation plans is required and a separate permit will be issued.	
☐	Landmark Commission	720-865-2709
☐	Zoning permit (if not applying with a building submittal) or project coordinator (PC) approval to log in	720-865-3000
☐	ROW Encroachment Permit, if a building encroachment into the ROW is proposed	720-865-3003

*DBC Admin is the Administrative Section of the 2016 Denver Building and Fire Code available at www.denvergov.org/buildingcode.

Submittal Checklist for Tenant Finishes & Remodels

All documents must be original; copies will NOT be accepted.

Code References*	Items
	☐ Zoning permit (if required) or SDP approval to log in Or, for a simultaneous zoning and building code review… (not for SDP, landmark, design, or administrative reviews) ☐ Signed request form for a simultaneous review ☐ Zoning application and plans, including site plans, floor plans with mezzanines, elevations (if exterior improvements are proposed), and roof plans, as applicable. Find zoning applications at www.denvergov.org/commercialzoning.
DRMC 27-153	☐ Affordable Housing Fee Application
	☐ Plan review Contact List
DBC Admin 133	☐ Building Address (must be provided on all pages of all plans and documents)
DBC Admin 133	☐ Construction drawings bearing the seal and valid electronic signature of the architect or engineer of record. ☐ Architectural/structural drawings ☐ Electrical drawings ☐ Mechanical/Plumbing drawings ☐ Plot plan locating all buildings relative to each other and to property lines
DBC Admin 133.2	☐ A complete 2015 IBC and 2016 DBC Code Analysis on the architectural plan that lists the following: ☐ Scope of Work ☐ IECC Compliance Method ☐ Construction Type of Building ☐ Occupancy Classification ☐ Number of Stories ☐ Automatic Sprinkler Systems ☐ Gross Area in Sq. Ft. for Each Occupancy ☐ Occupant Load for Each Use ☐ Allowable Area for Each Occupancy / Mixed Occupancy ☐ Fire Alarm & Detection
	☐ For SUDP: A Utility Site Plan showing the size, type, and location of water, storm sewer, and sanitary sewer lines
DBC Admin 133.2	☐ Project Specifications/Project Manual including a cover, title page, and table of contents, and it must be signed, sealed, and dated.
DBC Admin 133	☐ Structural Calculations with a summary of design parameters for structural changes including live load changes. It must be signed, sealed, and dated with a table of contents and page numbers on calculations.
DBC Admin 138	☐ Statement of Valuation form
	☐ Asbestos Inspection Acknowledgement form to comply with state law
Additional items for restaurant, other food/ice	☐ Food and Beverage Menu, including all garnishes and desserts (or product list for marijuana facilities) ☐ Equipment Specifications for all food service equipment that identify the specific make/model to be used ☐ Floor Plan identifying the location, purpose, and size of kitchen equipment, food prep areas, and service areas ☐ Health Plan Review Application (starts on page 5)

Plans must also be submitted separately by the applicant to the following, if applicable:

☐	Landmark Commission	720-865-2709
☐	Zoning permit (if not applying with a building submittal) or project coordinator (PC) approval to log in	720-865-3000

*DBC Admin is the Administrative Section of the 2016 Denver Building and Fire Code available at www.denvergov.org/buildingcode.

Date:

Project address and zip code:

Establishment Information	
Name of establishment:	Phone:
Email:	Cell:

Owner Information	
Individuals or corporate name:	Phone:
Email:	Cell:
Mailing address:	

Plan review comments will be sent to the email addresses listed below, so please write legibly and accurately.

Contact Information	
Name of primary contact:	Phone:
Company name:	Cell:
Email:	
Mailing address:	
Name of architect or engineer of record:	Phone:
Company name:	Cell:
Email:	
Mailing address:	
Name of contractor:	License #:
Company name:	Phone:
Email:	Cell:
Mailing address:	

Construction start date: Date of planned opening:

☐ By submitting this application, supporting documentation, and required plans, I certify that I am the property owner or authorized representative, that all statements on this submittal are true and accurate, and I agree to comply with all applicable laws and regulations of the City and County of Denver.

Please fill out this application in its entirety. If referring to "see plans" anywhere on this form, please specify the location on the plans where the related information can be found. A notation of "existing" will not be accepted and could delay plan review and/or approval.

Section I – General Information

Will the proposed operation take place in a:

☐ Institutional setting (examples include, but not limited to schools, hospitals, assisted living, etc.)

☐ Wholesales/manufacturing setting (examples include, but not limited to dairy factories, meat production, commercial bakeries, soda production, etc.)

☐ Retail setting (non-wholesale, non-production)

☐ Marijuana setting (dispensaries, MIP, hospitality operations, etc.)

Type of Establishment (Check all that apply):

☐ Animal Concept Facility
☐ Bakery
☐ Bar
☐ Brewery
☐ Commissary kitchen
☐ Other (please explain)

☐ Concession
☐ Convenience Store
☐ Distillery
☐ Fast Food
☐ Fish/Meat Market

☐ Food Court
☐ Full-Service Restaurant
☐ Ice Cream Shop
☐ Market (Grocery)
☐ Pet Food

Scope of Work (Check all that apply):

☐ Addition of seating (interior or exterior)
☐ Addition of equipment
☐ Change in plumbing fixtures and/or drains
☐ Change of ownership/business name
☐ Domestic water meter/tap change
☐ Change of use _____ to _____
☐ Other (please explain) _____

☐ Food concept and/or menu changes (ie. an ice cream shop to a burger joint)
☐ Interior remodel with no changes to equipment
☐ Pretreatment device (grease or solids interceptor)

MANUFACTURING/WHOLESALE: How much water will be used for your process including production _____ and clean up _____ (gallons/day)?

MANUFACTURING/WHOLESALE: What are the main ingredients used in your products (Please list. Do not specify quantities in order to respect trade secrets). _____

Is this a seasonal operation? ☐Yes ☐ No

If Yes, please specify how many months out of a year _____, days out of a week _____, and hours out of the day _____ this operation will take place?

Section II - Grease Interceptor (GI) Sizing

Before installing or replacing a GI, refer to Public Works' GI sizing worksheet available at www.denvergov.org/SUDP.

List cooking equipment and drainage fixtures with their respective quantities below:

Cooking Equipment with Quantities		Drainage Fixtures with Quantities			
		Kitchen (ware washing, food production/preparation)		Bar/Wait Station	
Stove	_____	Hand Sinks	_____	Hand Sinks	_____
Range*	_____	Preparation Sinks	_____	Dump Sinks	_____
Stove and Oven Combo	_____	Pot (pre rinse) Sinks	_____	2 or 3-Compartment Sinks	_____
Grills	_____	2 or 3-Compartment Sinks	_____	Dish Washers	_____
Griddles	_____	Garbage Disposals	_____	Floor Sinks	_____
Ovens	_____	Dish Washers	_____	Floor Drains	_____
Pizza Ovens	_____	Mop Sinks	_____		
Smokers	_____	Floor Sinks	_____		
Broilers	_____	Floor Drains	_____		
Salamanders	_____				
Fryers**	_____				
Woks	_____				
Tilt Kettles	_____				
Rice Cookers					

*A range = up to 6 burners **A fryer = 2 baskets *** See www.denvergov.org/sudp for more detailed information on how to categorize specific cooking equipment

Section III – Food Operation Information

Max. number of employees per shift: _____

Hours/days of operation	Restaurant seating capacity	Type of service (Check all that apply)	Max. # of meals
Sun: ____ to ____ Mon: ____ to ____ Tue: ____ to ____ Wed: ____ to ____ Thur: ____ to ____ Fri: ____ to ____ Sat: ____ to ____	# of indoor seats where meals are served: _____ # of outdoor seats where meals are served (include all dining and bar areas and not occupancy load): _____ Total square feet of the facility: _____ Total square feet where meals will be served: _____	☐ On-site consumption ☐ Off-site consumption ☐ Single-use utensils ☐ Multi-use utensils ☐ Other: _____	☐ Breakfast _____ ☐ Lunch _____ ☐ Dinner _____ Total/day: _____ Max/hour: _____ % that are carry-out: _____

Section IV – Food Handling Information

	Yes	No
Will food be held cold? (e.g., refrigeration, ice baths, etc.)	☐	☐
Will food be held hot? (e.g., steam tables)	☐	☐
Will fresh produce (including garnishes) be required for the menu?	☐	☐
Will food be cooled after cooking?	☐	☐
Will food be reheated after cooling?	☐	☐
Will food that is frozen need to be thawed?	☐	☐
Will proteins or vegetable foods be fully cooked from a raw state?	☐	☐
Will foods be prepared that will be sold to other establishments?	☐	☐
Will catering be conducted?	☐	☐
Will self-service foods (buffets, salad bars, etc.) be provided?	☐	☐
Will food items be sold in bulk to the public?	☐	☐
Will another facility, such as a commissary, be used to prepare food that is served here?	☐	☐

Section V – Marijuana Handling Procedures

Note: All marijuana facilities must submit with this application a detailed product list of all products that can be consumed orally, including extracted oils, candies, beverages, supplements, tinctures, etc.

	Yes	No
Will marijuana-infused products (MIPs) be manufactured, stored, or sold?	☐	☐
Will extractions be conducted onsite to produce infused edibles?	☐	☐
Will extracted oil be sold wholesale to other marijuana facilities?	☐	☐
Is trim from the facility (grinding, bagging, etc.) intended for use in any edible production?	☐	☐
Is commercial refrigeration** provided onsite?	☐	☐

Describe the tasks to occur in each extraction, processing, dishwashing, manufacturing, and packaging room:

*** Commercial refrigeration is required onsite for any edible product needing time/temperature safety controls to limit the growth or formation of pathogenic microorganisms or toxins ("potentially hazardous"). If refrigeration is not provided, please submit either shelf-stability documentation from the Department of Public Health and Environment or a letter from the owner verifying that no potentially hazardous edibles will be provided onsite.*

Section VI – Equipment

Please note, that all equipment shall be of a commercial design. Commercial Design means equipment that is certified or classified by an American National Standards Institute (ANSI) accredited certification program, such as the National Sanitation Foundation (NSF), Underwriters Laboratories (UL) sanitation standards, Environmental Testing Laboratories, Inc. (ETL) sanitation standards, Baking Industry Sanitation Standards Committee (BISSC), or other comparable design criteria as approved by the Executive Director during a standardized equipment review.

Section VII - Finishes

Please provide a finish floor plan, accompanied by a finish scheduled. Please note, that:

- In areas where food preparation, equipment washing, ware washing, and food storage occurs, floors, walls, and ceilings are required to be smooth, durable and easily cleanable. There shall be no exposed utility service lines, studs, joists, and rafters in these areas.
- A coved juncture shall be provided between the floor and wall in all food preparation, food storage, ware washing areas, utility sink areas, and toilet rooms.

Section VIII – Plumbing Information

Indicate whether the following plumbing fixtures/equipment will be directly connected to the sewer or indirectly drained (e.g., floor sink or air gap). Notations of "existing" will not be accepted. Ensure to provide plumbing plans for a review.

ID # on plans	# of Fixtures	Fixture or Equipment	Direct or Indirect Drainage

Are any of the following fixtures located onsite and equipped with hot water?

	Yes	No	# of Fixtures
Shower	☐	☐	_____
Clothes Washer	☐	☐	_____

Is a garbage disposal provided? ☐ ☐

If yes, please indicate the location(s):

Complete the following table for each food preparation sink provided in the facility.

Food Prep Sinks				
ID # on plans	Length of drainboard	Dimensions of sink compartments (L x W x D in inches)		

Section IX – Ware washing Information

Complete the following table for each *manual* ware washing sink. Ware washing sinks must be large enough to accommodate the largest equipment or utensils used.

Manual Ware washing Sinks						
ID # on plans	Length of soiled drainboard	Dimensions of sink compartment (L x W x D in inches)			Length of clean drainboard	Pre-rinse sprayer? (Y/N)

Soiled and clean drainboards for primary ware washing sinks must be at least 24". Drainboards for bar sinks must be at least 18". If these dimensions cannot be met, please detail what alternate equipment/methods will be used in place of traditional drainboards and include specification sheets with this application:

Complete the following table for each *mechanical* dish machine.

Mechanical Ware washing								
ID # on plans	Make	Model #	Heat/chemical sanitizing?	Drainboard length	Pre-rinse? (Y/N)	Utensil soak sink dimensions (L x W x D in inches)		

Section X - Water Heaters

How many water heaters service this facility? _____

Use the tables below to indicate the type of water heaters and heating systems in use.

Standard Tank Type Heater			
Make	Model #	kW/BTU rating	Recovery rate (GPH) @ 100°F rise

Instantaneous/Tankless Systems				
Make	Model #	BTU rating	Flow rate (GPM) @ 80°F or 100°F rise	Storage tank capacity (gallons), if applicable

Notes for Instantaneous Water Heaters

If a dishwashing machine is to be installed on an instantaneous water heater system, a storage tank is required. The storage tank size must be at least 25% of the gallons per hour (GPH) demand of the dishwashing machine(s), with a minimum tank size of 25 gallons. The storage tank must be installed in the hot water supply line located between the heater(s) and the hot water distribution line. It must have a recirculation line and aquastat (water thermostat) to ensure that the water in the tank remains at the appropriate temperature (120°F - 140°F). The line must connect between the tank and the cold-water supply line to the heater(s).
High-temperature, heat-sanitizing dishwashing machines must have a separate booster heater. An instantaneous unit cannot be used as a booster heater.
Electric units will only be approved as a dedicated supply to hand sinks.