

Soil Investigation & Compaction Test Report

Project: 26.P.001 | **Sketch ref:** 26-SB-001 (Case 25.S.101)

Client: Nasreen Abdul Rahim Shaikh (Civil No. 62898538)

Site: Plot 102/8, Al Mawaleh South, Wilayat Al Seeb — Survey Ref 1-35-055-01-585

Test	Result	Standard	Verdict
Bearing capacity	145 kPa at 1.5m depth	ASTM D1194	Pass
Standard Penetration Test (SPT)	N=22 (medium dense sand)	ASTM D1586	Pass
Compaction (Proctor)	96% MDD	ASTM D698	Pass
Sulphate content	0.11%	BS 1377	Pass — low sulphate exposure

Recommendation: conventional strip/pad foundations suitable for a G+1 residential villa, 1808 sqm plot, subject to structural engineer's final sizing.

Issued by: [Testing Laboratory Name] — Report No. GEO-2026-0918 — 16 Sept 2026