

FICTIONAL SAMPLE DOCUMENT - for testing retrieval only.
Not a real building code.

KESTREL COUNTY BUILDING CODE (KCBC)
Part 9 - Building Services
Revision 4.2, adopted 11 February 2029

9.1 SCOPE

This Part governs electrical distribution, mechanical ventilation and emergency systems. Where equipment serves a fire protection function, Part 5 also applies.

9.2 ELECTRICAL DISTRIBUTION

Clause 9.2.1. Working space in front of an electrical panel shall be not less than 1,000 millimetres deep and 750 millimetres wide, maintained clear to a height of 2,000 millimetres.

Clause 9.2.2. Receptacle outlets in habitable rooms shall be spaced so that no point along a wall is more than 1,800 millimetres from an outlet, giving a maximum spacing of 3,600 millimetres.

Clause 9.2.3. Branch circuits serving kitchen counter receptacles shall be rated not less than 20 amperes.

Clause 9.2.4. Arc fault protection is required on all branch circuits serving sleeping rooms and living areas.

Clause 9.2.5. The service disconnect shall be located within 3 metres of the point of entry of the service conductors.

9.3 MECHANICAL VENTILATION

Clause 9.3.1. Outdoor air shall be supplied at not less than 7.5 litres per second per person, plus 0.35 litres per second per square metre of floor area.

Clause 9.3.2. Exhaust rates shall be not less than:

Toilet room, per fixture	25 L/s
Kitchen, residential	50 L/s
Kitchen, commercial hood	300 L/s
Parking garage, per m2	3.7 L/s

Clause 9.3.3. Where a space is unoccupied for more than four consecutive hours, ventilation may be reduced to 30 percent of the design rate.

Clause 9.3.4. Ductwork penetrating a fire rated assembly shall be fitted with a fire damper rated to match the assembly.

9.4 EMERGENCY POWER AND LIGHTING

Clause 9.4.1. Emergency lighting shall provide an average illuminance of not less than 10 lux measured at floor level along the path of egress, with a maximum to minimum uniformity ratio not exceeding 40 to 1.

Clause 9.4.2. Emergency lighting shall operate for not less than 90 minutes following loss of normal power.

Clause 9.4.3. Standby generators serving essential facilities shall carry fuel for not less than 72 hours of operation at full load.

Clause 9.4.4. Exit signs shall be internally illuminated and legible from a distance of 30 metres.

9.5 PLUMBING FIXTURE COUNTS

Clause 9.5.1. The minimum number of plumbing fixtures shall be determined from the occupant load calculated under Part 5.

Clause 9.5.2. For business occupancies, water closets shall be provided at one per 25 occupants for the first 50 occupants, then one per 50 occupants thereafter.

Clause 9.5.3. Drinking fountains shall be provided at one per 100 occupants, with not fewer than one on each storey.

9.6 ENERGY PERFORMANCE

Clause 9.6.1. The maximum permitted lighting power density for office space is 8.5 watts per square metre.

Clause 9.6.2. Roof assemblies shall achieve a thermal resistance of not less than RSI 5.5. Above grade walls shall achieve not less than RSI 3.9.

Clause 9.6.3. Glazing shall not exceed 40 percent of the gross above grade wall area unless the design is demonstrated to comply by whole building energy modelling.

Clause 9.6.4. Buildings exceeding 4,000 square metres shall be commissioned by an independent commissioning authority prior to occupancy.