

Topic 21: AUG experiment KoM

N. Vianello

03 March 2017



This work has been carried out within the framework of the EUROfusion Consortium and has received funding from the Euratum research and training programme 2014-2018 under grant agreement No 633053. The views and opinions expressed herein do not necessarily reflect those of the European Commission.

# Cross-machine comparison



Brief summary of proposals done by N.Vianello and F. Militello who suggest the repetition of similar experiments in the 3 devices to provide appropriate comparison

### Cross-machine comparison



Brief summary of proposals done by N.Vianello and F. Militello who suggest the repetition of similar experiments in the 3 devices to provide appropriate comparison

#### √ L-Mode

- √ Current scan both at fixed and varied q95
- Equivalent density ramp in favorable/unfavorable  $B \times \nabla B$  direction
- Probe at a fixed position for long time statistics
- Parallel flow and modification accordingly to favorable/unfavorable direction

## Cross-machine comparison



Brief summary of proposals done by N. Vianello and F. Militello who suggest the repetition of similar experiments in the 3 devices to provide appropriate comparison

#### √ H-Mode

- ✓ H-Mode with density ramps/seeding proposed by all the proponents
- Similar density ramps/seeded experiments performed in LSN/USN/DN configuration and monitor of filaments at the target and at the midplane
- √ QH-mode or Type-III ELMy regime