

$$\Delta T_{\text{heating}} = 20 - (-4.8) = 24.8 \text{ }^{\circ}\text{C}$$

$$\text{DR} = 11.9 \text{ }^{\circ}\text{C}$$

WEST WINDOW (FIXED)

Cooling Load: Wooden Frame

$$\dot{q}_{\text{windowwest}} = A \times \text{CF}_{\text{windowwest}}$$

$$A = 14.4 \text{ m}^2$$

$$\text{CF}_{\text{windowwest}} = \text{CF}_{\text{windowwest_heattransfer}} + \text{CF}_{\text{windowwest_irradiation}}$$

$$\text{CF}_{\text{windowwest}} = U(\Delta T - 0.46\text{DR}) + \text{PXL} \times \text{SHGC} \times \text{IAC} \times \text{FF}_s$$

$$\text{CF}_{\text{windowwest_heattransfer}} = U(\Delta T - 0.46\text{DR})$$

$$U = 2.84$$

$$\text{CF}_{\text{windowwest_heattransfer}} = 2.84 (7.9 - (0.46)(11.9)) = 6.89 \frac{\text{W}}{\text{m}^2}$$

$$\text{CF}_{\text{windowwest_irradiation}} = \text{PXL} \times \text{SHGC} \times \text{IAC} \times \text{FF}_s$$

$$\text{PXL} = E_D - E_d = 559 + 188 = 747$$

$$\text{SHGC} = 0.54$$

$$\text{IAC} = 1$$

$$\text{FF}_s = 0.56$$

$$\text{CF}_{\text{windowwest_irradiation}} = 747 \times 0.54 \times 1 \times 0.56 = 225.89 \frac{\text{W}}{\text{m}^2}$$

$$\text{CF}_{\text{windowwest}} = \text{CF}_{\text{windowwest_heattransfer}} + \text{CF}_{\text{windowwest_irradiation}}$$

$$\text{CF}_{\text{windowwest}} = 6.89 + 225.89 = 232.78 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowwest}} = A \times \text{CF}_{\text{windowwest}} = 14.4 \times 232.78 = 3352.07 \text{ W}$$

Cooling Load: Aluminum Frame

$$\dot{q}_{\text{windowwest}} = A \times \text{CF}_{\text{windowwest}}$$

$$A = 14.4 \text{ m}^2$$

$$\text{CF}_{\text{windowwest}} = \text{CF}_{\text{windowwest_heattransfer}} + \text{CF}_{\text{windowwest_irradiation}}$$

$$\text{CF}_{\text{windowwest}} = U(\Delta T - 0.46\text{DR}) + \text{PXL} \times \text{SHGC} \times \text{IAC} \times \text{FF}_s$$

$$\text{CF}_{\text{windowwest_heattransfer}} = U(\Delta T - 0.46\text{DR})$$

$$U = 3.61$$

$$\text{CF}_{\text{windowwest_heattransfer}} = 3.61 (7.9 - (0.46)(11.9)) = 8.76 \frac{\text{W}}{\text{m}^2}$$

$$\text{CF}_{\text{windowwest_irradiation}} = \text{PXL} \times \text{SHGC} \times \text{IAC} \times \text{FF}_s$$

$$\text{PXL} = E_D - E_d = 559 + 188 = 747$$

$$\text{SHGC} = 0.56$$

$$\text{IAC} = 1$$

$$\text{FF}_s = 0.56$$

$$\text{CF}_{\text{windowwest_irradiation}} = 747 \times 0.56 \times 1 \times 0.56 = 234.26 \frac{\text{W}}{\text{m}^2}$$

$$\text{CF}_{\text{windowwest}} = 8.76 + 234.26 = 243.02 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowwest}} = A \times \text{CF}_{\text{windowwest}} = 14.4 \times 243.02 = 3499.47 \text{ W}$$

Heating Load: Wooden Frame

$$\dot{q}_{\text{windowwest}} = A \times \text{HF}_{\text{windowwest}}$$

$$A = 14.4 \text{ m}^2$$

$$\text{HF}_{\text{windowwest}} = U_{\text{windowwest}} \times \Delta T_{\text{heating}}$$

$$U = 2.84$$

$$\text{HF}_{\text{windowwest}} = 2.84 \times 24.8 = 70.43 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowwest}} = A \times HF_{\text{windowwest}} = 14.4 \times 70.43 = 1014.22 \text{ W}$$

Heating Load: Aluminum Frame

$$\dot{q}_{\text{windowwest}} = A \times HF_{\text{windowwest}}$$

$$A = 14.4 \text{ m}^2$$

$$HF_{\text{windowwest}} = U_{\text{windowwest}} \times \Delta T_{\text{heating}}$$

$$U = 3.61$$

$$HF_{\text{windowwest}} = 3.61 \times 24.8 = 89.53 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowwest}} = A \times HF_{\text{windowwest}} = 14.4 \times 89.53 = 1289.20 \text{ W}$$

Difference:

$$\text{Cooling Load} = 147.4 \text{ W}$$

$$\text{Heating Load} = 274.98 \text{ W}$$

SOUTH WINDOW (FIXED)

Cooling Load: Wooden Frame

$$\dot{q}_{\text{windowssouth}} = A \times CF_{\text{windowssouth}}$$

$$A = 3.6 \text{ m}^2$$

$$CF_{\text{windowssouth}} = CF_{\text{windowssouth_heattransfer}} + CF_{\text{windowssouth_irradiation}}$$

$$CF_{\text{windowssouth}} = U(\Delta T - 0.46DR) + PXI \times SHGC \times IAC \times FF_s$$

$$CF_{\text{windowssouth_heattransfer}} = U(\Delta T - 0.46DR)$$

$$U = 2.84$$

$$CF_{\text{windowssouth_heattransfer}} = 2.84 (7.9 - (0.46)(11.9)) = 6.89 \frac{\text{W}}{\text{m}^2}$$

$$CF_{\text{windowssouth_irradiation}} = PXI \times SHGC \times IAC \times FF_s$$

$$PXI = E_D - E_d = 348 + 209 = 557$$

$$SHGC = 0.54$$

$$IAC = 1$$

$$FF_s = 0.47$$

$$CF_{\text{windowssouth_irradiation}} = 557 \times 0.54 \times 1 \times 0.47 = 141.37 \frac{\text{W}}{\text{m}^2}$$

$$CF_{\text{windowssouth}} = CF_{\text{windowssouth_heattransfer}} + CF_{\text{windowssouth_irradiation}}$$

$$CF_{\text{windowssouth}} = 6.89 + 141.37 = 148.26 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowssouth}} = A \times CF_{\text{windowssouth}} = 3.6 \times 148.26 = 533.74 \text{ W}$$

Cooling Load: Aluminum Frame

$$\dot{q}_{\text{windowssouth}} = A \times CF_{\text{windowssouth}}$$

$$A = 3.6 \text{ m}^2$$

$$CF_{\text{windowssouth}} = CF_{\text{windowssouth_heattransfer}} + CF_{\text{windowssouth_irradiation}}$$

$$CF_{\text{windowssouth}} = U(\Delta T - 0.46DR) + PXI \times SHGC \times IAC \times FF_s$$

$$CF_{\text{windowssouth_heattransfer}} = U(\Delta T - 0.46DR)$$

$$U = 3.61$$

$$CF_{\text{windowssouth_heattransfer}} = 3.61 (7.9 - (0.46)(11.9)) = 8.76 \frac{\text{W}}{\text{m}^2}$$

$$CF_{\text{windowssouth_irradiation}} = PXI \times SHGC \times IAC \times FF_s$$

$$PXI = E_D - E_d = 348 + 209 = 557$$

$$SHGC = 0.56$$

$$IAC = 1$$

$$FF_s = 0.47$$

$$CF_{\text{windowssouth_irradiation}} = 557 \times 0.56 \times 1 \times 0.47 = 146.60 \frac{\text{W}}{\text{m}^2}$$

$$CF_{\text{windowssouth}} = 8.76 + 146.60 = 155.36 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowssouth}} = A \times CF_{\text{windowssouth}} = 3.6 \times 155.36 = 559.30 \text{ W}$$

Heating Load: Wooden Frame

$$\dot{q}_{\text{windowssouth}} = A \times HF_{\text{windowssouth}}$$

$$A = 3.6 \text{ m}^2$$

$$HF_{\text{windowssouth}} = U_{\text{windowssouth}} \times \Delta T_{\text{heating}}$$

$$U = 2.84$$

$$HF_{\text{windowssouth}} = 2.84 \times 24.8 = 70.43 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowssouth}} = A \times HF_{\text{windowssouth}} = 3.6 \times 70.43 = 253.08 \text{ W}$$

Heating Load: Aluminum Frame

$$\dot{q}_{\text{windowssouth}} = A \times HF_{\text{windowssouth}}$$

$$A = 3.6 \text{ m}^2$$

$$HF_{\text{windowssouth}} = U_{\text{windowssouth}} \times \Delta T_{\text{heating}}$$

$$U = 3.61$$

$$HF_{\text{windowssouth}} = 3.61 \times 24.8 = 89.53 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowssouth}} = A \times HF_{\text{windowssouth}} = 3.6 \times 89.53 = 322.31 \text{ W}$$

Difference:

$$\text{Cooling Load} = 25.56 \text{ W}$$

$$\text{Heating Load} = 69.23 \text{ W}$$

SOUTH WINDOW (OPERABLE)

Cooling Load: Wooden Frame

$$\dot{q}_{\text{windowssouth}} = A \times CF_{\text{windowssouth}}$$

$$A = 3.6 \text{ m}^2$$

$$CF_{\text{windowssouth}} = CF_{\text{windowssouth_heattransfer}} + CF_{\text{windowssouth_irradiation}}$$

$$CF_{\text{windowssouth}} = U(\Delta T - 0.46DR) + PXI \times SHGC \times IAC \times FF_s$$

$$CF_{\text{windowssouth_heattransfer}} = U(\Delta T - 0.46DR)$$

$$U = 2.87$$

$$CF_{\text{windowssouth_heattransfer}} = 2.87 (7.9 - (0.46)(11.9)) = 6.96 \frac{\text{W}}{\text{m}^2}$$

$$CF_{\text{windowssouth_irradiation}} = PXI \times SHGC \times IAC \times FF_s$$

$$PXI = E_D - E_d = 348 + 209 = 557$$

$$SHGC = 0.46$$

$$IAC = 1$$

$$FF_s = 0.47$$

$$CF_{\text{windowssouth_irradiation}} = 557 \times 0.46 \times 1 \times 0.47 = 120.42 \frac{\text{W}}{\text{m}^2}$$

$$CF_{\text{windowssouth}} = CF_{\text{windowssouth_heattransfer}} + CF_{\text{windowssouth_irradiation}}$$

$$CF_{\text{windowssouth}} = 6.96 + 120.42 = 127.38 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowssouth}} = A \times CF_{\text{windowssouth}} = 3.6 \times 127.38 = 458.57 \text{ W}$$

Cooling Load: Aluminum Frame

$$\dot{q}_{\text{windowssouth}} = A \times CF_{\text{windowssouth}}$$

$$A = 3.6 \text{ m}^2$$

$$CF_{\text{windowsouth}} = CF_{\text{windowsouth_heattransfer}} + CF_{\text{windowsouth_irradiation}}$$

$$CF_{\text{windowsouth}} = U(\Delta T - 0.46DR) + PXI \times SHGC \times IAC \times FF_s$$

$$CF_{\text{windowsouth_heattransfer}} = U(\Delta T - 0.46DR)$$

$$U = 4.62$$

$$CF_{\text{windowsouth_heattransfer}} = 4.62 (7.9 - (0.46)(11.9)) = 11.21 \frac{\text{W}}{\text{m}^2}$$

$$CF_{\text{windowsouth_irradiation}} = PXI \times SHGC \times IAC \times FF_s$$

$$PXI = E_D - E_d = 348 + 209 = 557$$

$$SHGC = 0.55$$

$$IAC = 1$$

$$FF_s = 0.47$$

$$CF_{\text{windowsouth_irradiation}} = 557 \times 0.55 \times 1 \times 0.47 = 143.98 \frac{\text{W}}{\text{m}^2}$$

$$CF_{\text{windowsouth}} = 11.21 + 143.98 = 155.19 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowsouth}} = A \times CF_{\text{windowsouth}} = 3.6 \times 155.19 = 558.68 \text{ W}$$

Heating Load: Wooden Frame

$$\dot{q}_{\text{windowsouth}} = A \times HF_{\text{windowsouth}}$$

$$A = 3.6 \text{ m}^2$$

$$HF_{\text{windowsouth}} = U_{\text{windowsouth}} \times \Delta T_{\text{heating}}$$

$$U = 2.87$$

$$HF_{\text{windowsouth}} = 2.87 \times 24.8 = 71.18 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowsouth}} = A \times HF_{\text{windowsouth}} = 3.6 \times 71.18 = 256.23 \text{ W}$$

Heating Load: Aluminum Frame

$$\dot{q}_{\text{windowsouth}} = A \times HF_{\text{windowsouth}}$$

$$A = 3.6 \text{ m}^2$$

$$HF_{\text{windowsouth}} = U_{\text{windowsouth}} \times \Delta T_{\text{heating}}$$

$$U = 4.62$$

$$HF_{\text{windowsouth}} = 4.62 \times 24.8 = 114.58 \frac{\text{W}}{\text{m}^2}$$

$$\dot{q}_{\text{windowsouth}} = A \times HF_{\text{windowsouth}} = 3.6 \times 114.58 = 412.47 \text{ W}$$

Difference:

$$\text{Cooling Load} = 100.11 \text{ W}$$

$$\text{Heating Load} = 156.24 \text{ W}$$