SECTION 08 11 13
HOLLOW METAL DOORS AND FRAMES

PART 1 - GENERAL

1.1 SUMMARY

A. Section includes hollow metal doors and frames.

B. Related sections: Section 08 71 00 "Door Hardware".

PART 2 - PRODUCTS

2.1 HOLLOW METAL DOORS

A. Interior doors: SDI A250.8 Level 2, 18 gauge, 1-3/4 inches thick, seamless edges.

B. Fire-rated doors: labeled assemblies rated 20, 45, 60 and 90 minutes and 3 hours as indicated.

2.2 FRAMES

A. Frames: 16 gauge, welded, with three silencers per strike jamb.

PART 3 - EXECUTION

3.1 INSTALLATION

A. Install doors and frames plumb, rigid and in true alignment.

END OF SECTION 08 11 13

SECTION 08 14 16
FLUSH WOOD DOORS

PART 1 - GENERAL

1.1 SUMMARY

A. Section includes solid-core flush wood doors with wood veneer faces.

PART 2 - PRODUCTS

2.1 FLUSH WOOD DOORS

A. Doors: solid core flush wood doors, 1-3/4 inches thick, WDMA I.S.1A Extra Heavy Duty.

B. Faces: rotary-cut red oak veneer, Grade A, for transparent finish.

C. Fire-rated doors: provide wood doors rated 20, 45 and 60 minutes where indicated. Wood doors rated more than 60 minutes are not permitted; use hollow metal doors.

D. Hollow-core doors are not permitted.

PART 3 - EXECUTION

3.1 INSTALLATION

A. Install doors in frames with uniform clearances of 1/8 inch at heads and jambs.

END OF SECTION 08 14 16

SECTION 08 41 13
ALUMINUM-FRAMED ENTRANCES AND STOREFRONTS

PART 2 - PRODUCTS

2.1 ENTRANCE DOORS

A. Entrance doors: medium stile aluminum, 1-3/4 inches thick, pairs as indicated, insulated glazing.

END OF SECTION 08 41 13

SECTION 08 71 00
DOOR HARDWARE

PART 1 - GENERAL

1.1 SUMMARY

A. Section includes door hardware for wood, hollow metal and aluminum doors.

PART 3 - EXECUTION

3.5 HARDWARE SETS

A. HW-1: Office lockset, three hinges, wall stop.

B. HW-2: Storeroom lockset, closer, three hinges, kick plate.

C. HW-3: Privacy set with occupancy indicator, closer, three hinges, coat hook.

D. HW-4: Exit devices (pair), closers, continuous hinges, threshold and weatherstripping.

END OF SECTION 08 71 00

SECTION 23 34 16
CENTRIFUGAL HVAC FANS

PART 2 - PRODUCTS

2.1 CEILING-MOUNTED EXHAUST FANS

A. Fans: direct drive, 120 V, 1 phase, 60 Hz, with backdraft damper and speed controller.

END OF SECTION 23 34 16

SECTION 23 36 00
AIR TERMINAL UNITS

PART 2 - PRODUCTS

2.1 SINGLE-DUCT VAV TERMINALS

A. Terminals: pressure independent, with DDC controls furnished under Division 23.

END OF SECTION 23 36 00

SECTION 23 74 13
PACKAGED OUTDOOR CENTRAL-STATION AIR-HANDLING UNITS

PART 2 - PRODUCTS

2.1 ROOFTOP UNITS

A. Units: factory-assembled rooftop units with gas heat and DX cooling, sized as scheduled.

B. Refrigerant: R-454B. R-410A is not permitted.

C. Electrical characteristics: 460 V, 3 phase, 60 Hz, single-point power connection.

D. Economizer: integrated, with barometric relief.

END OF SECTION 23 74 13