SYNTHETIC MAPLEWOOD ASSESSMENT

NursingUnit-B / Asset tracking infrastructure

Evaluation period: 2026-06-10 to 2026-06-11 (end exclusive) | Zone type: critical_care

This section summarizes the 3 evaluated tags assigned to NursingUnit-B. It describes measured checks and source-linked context; it does not select a final cause or certify readiness.

Results

3 affected tags produced 4 failed checks. Each failed check is a condition requiring investigation; it does not by itself establish an infrastructure fault or a shared cause.

MRW-TAG-0032 and MRW-TAG-0033 each had a longest interval without recorded updates of 5 hours (300 minutes). The configured limit is 15 minutes. During those separate intervals, the export does not demonstrate continuous visibility of either tag; matching durations do not establish that the interruptions had the same cause.

MRW-TAG-0030 was received by a median of 1 access point during the evaluation period; the configured requirement is 3 access points. This condition can limit the observations available to the location engine, but the available data does not establish why only one access point received the tag.

One additional failed engine-score check is retained in Supporting measurements. It is kept out of this stakeholder summary because the score is not a measurement of physical location accuracy.

Technician context

Technician note N-02, declared for NursingUnit-B, reports that night staff move pumps and monitors to a clean utility room at the end of shift and that access-point coverage in the room is poor.

> nursing B general: night staff confirmed they move pumps and monitors to the clean utility room at end of shift (~10pm). room is around the corner from main ward, APs dont cover it well. tickets: none open, verbal only

This note identifies a condition to investigate. It does not name MRW-TAG-0030, MRW-TAG-0032, or MRW-TAG-0033, and it does not establish that any of those tags were in the utility room when their measured failures occurred. The causes remain unconfirmed.

Next action

For MRW-TAG-0030, verify the tag's physical location and mounting condition, identify which access points received its transmissions, and measure reception along representative movement and storage routes. Retest until the median receiving-access-point count is at least 3.

For MRW-TAG-0032 and MRW-TAG-0033, identify the start and end of each missing-update interval and compare those separate intervals with documented equipment movement. Measure reception in the clean utility room described by N-02. After any verified corrective action, retest each tag against the 15-minute maximum interval without recorded updates.

These are proposed investigation and retest steps, not technician instructions, completed work, or confirmed fixes.

Supporting measurements

Engineering detail retains the saved measurement, configured limit, unit, internal check label, and source relationship for every failed check in this zone.

Affected tag	Measurement	Observed	Configured limit	Internal label / source
MRW-TAG-0030	Median receiving access-point count	1 access point	At least 3 access points	SINGLE_AP / telemetry aggregate
MRW-TAG-0030	Engine confidence score (not measured location accuracy)	0.4637 (0-1 score)	At least 0.8 (0-1 score)	LOW_CONFIDENCE / telemetry aggregate
MRW-TAG-0032	Longest interval without recorded updates	5 hours (300 minutes)	No more than 15 minutes	REPORT_GAP / telemetry aggregate
MRW-TAG-0033	Longest interval without recorded updates	5 hours (300 minutes)	No more than 15 minutes	REPORT_GAP / telemetry aggregate

Traceability

Telemetry and configured limits: review_20261013T182447032293Z.json. Technician context: note N-02, declared for NursingUnit-B. Source SHA-256: 6f1b821acf7b9196fa53f5d0f419330d3d4464aa3c71fce7da6232895901f5d3

Scope and limitations

The sample contains AP reception counts, RSSI, engine confidence, reporting gaps, and estimated-zone agreement. It does not contain surveyed coordinates, floor plans, measured location accuracy, or before/after calibration results. Results are synthetic and limited to the supplied evaluation window.