



CrossMark  
click for updates

Cite this: DOI: 10.1039/c5ee02950c

# Calcium looping with inherent energy storage for decarbonisation of coal-fired power plant†

Dawid P. Hanak,\* Chechet Biliyok and Vasilije Manovic\*

Implementation of carbon capture and storage, nuclear power stations and wide utilisation of renewable energy sources have been identified as capable of reducing around 42% of the energy sector's cumulative CO<sub>2</sub> emissions between 2009 and 2050. In scenarios assuming high shares of renewable energy sources in the energy portfolio, energy storage technologies and the remaining power generating assets would be required to flexibly balance energy supply and demand. With nuclear power plants operating at base load, this task would be handled by flexible fossil fuel power plants with CO<sub>2</sub> capture. However, mature CO<sub>2</sub> capture systems were shown to impose high efficiency penalties (8–12.5% points) and are better suited for base-load operation. An emerging calcium looping process, which has also been considered for energy storage, has been found to offer lower efficiency penalties (5–8% points). This study presents a concept of the calcium looping process with inherent energy storage for decarbonisation of the coal-fired power plant. Analysis has revealed that the possible routes for energy storage in this process include CaO/CaCO<sub>3</sub> solids storage, CaO/Ca(OH)<sub>2</sub> solids storage and cryogenic O<sub>2</sub> storage systems. Comparison of the CaO/CaCO<sub>3</sub> storage and cryogenic O<sub>2</sub> storage systems revealed that implementation of the latter would result in higher turndown of the entire system and would offer higher energy density. Also, the hydration reaction was found to improve the energy density of the CaO/CaCO<sub>3</sub> energy storage system by 57.4%, from 307.2 kW<sub>th</sub> h m<sup>−3</sup> to 483.6 kW<sub>th</sub> h m<sup>−3</sup>. Economic evaluation of the proposed concepts revealed that application of the cryogenic O<sub>2</sub> storage system in the calcium looping CO<sub>2</sub> capture process has the potential to increase the profitability of the integrated system, even over the reference coal-fired power plant without CO<sub>2</sub> capture.

Received 25th September 2015,  
Accepted 5th January 2016

DOI: 10.1039/c5ee02950c

www.rsc.org/ees

## Broader context

Fossil fuel power plants with CO<sub>2</sub> capture, nuclear power stations and renewable energy sources have been identified as capable of reducing around 42% of the energy sector's cumulative CO<sub>2</sub> emissions between 2009 and 2050. However, the increasing share of intermittent renewable energy sources in the energy portfolio will be a challenge for the balance of the energy network. Therefore, the fossil fuel power plants are expected to be decarbonised and to flexibly balance energy supply and demand to avoid energy wastage and shortages. Implementation of energy storage is seen as an alternative option to counterbalance the intermittent nature of renewables. In this study we present a concept of CO<sub>2</sub> capture systems based on calcium looping with inherent energy storage. We demonstrated that such systems, in addition to decarbonisation of power plants, can increase the degree of energy utilisation at very small additional capital costs. In the realistic future energy portfolio/policy scenarios, the fossil fuel energy systems based on the proposed concept can generate higher profit than current fossil fuel power plants without CO<sub>2</sub> capture. In other words, integration of carbon capture and storage with energy storage can enable decarbonisation of power and other carbon-intensive industries with no economic penalties.

## 1. Introduction

The International Energy Agency<sup>1,2</sup> has predicted that to limit the global mean temperature increase to 2 °C, around 42% of the cumulative CO<sub>2</sub> emission from the energy sector, between 2009

and 2050, can be mitigated through implementation of carbon capture and storage (CCS), nuclear power stations and utilisation of renewable energy sources. The greatest challenge of such a scenario is the intermittence of the renewable energy sources,<sup>3</sup> which would affect operation of the existing energy network,<sup>4,5</sup> especially in cases when their share in the energy portfolio exceeds 50%.<sup>1</sup> As the nuclear power plants operate at base load, fossil fuel power plants would need to flexibly balance energy supply and demand, so that neither energy produced from

Combustion and CCS Centre, Cranfield University, Bedford, Bedfordshire, MK43 0AL, UK. E-mail: d.p.hanak@cranfield.ac.uk, v.manovic@cranfield.ac.uk

† Electronic supplementary information (ESI) available. See DOI: 10.1039/c5ee02950c

renewable energy sources is wasted (high renewables generation period) nor energy shortages occur (low renewables generation period). Such periods of variable load operation or no operation would impose energy and economic penalties on the fossil fuel power systems, especially for plants with CCS that are better suited for base-load operation.<sup>6</sup>

Due to their capacity of decoupling energy supply and demand,<sup>7</sup> energy storage technologies can increase the degree of energy utilisation and should thus be widely deployed along with low-emission technologies. However, the energy storage could contribute to CO<sub>2</sub> emission reduction only in the scenario of wide renewables penetration.<sup>8,9</sup> Otherwise, energy storage may increase CO<sub>2</sub> emissions by an extent that depends on carbon prices and the share of coal-based power generation in the energy portfolio.<sup>1,8</sup> For this reason, a synergy between renewable energy sources, fossil fuel power generation and energy storage needs to be reached.

Presently about 145.8 GW of energy is stored globally, most of which as mechanical energy in pumped hydro storage plants (97.5%), and compressed air and flywheel energy storage techniques (1.0%). Interestingly, the share of thermal energy storage technologies surpassed electro-mechanical storage in 2013, and now accounts for 1.2% of the global energy storage capacity.<sup>10</sup> These technologies utilise media capable of storing thermal energy at low or high temperature, which can be recovered in the form of heat depending on the process demand.<sup>11,12</sup> Moreover, thermal energy storage systems are claimed to have the potential of improving the flexibility of the electricity grid, increasing the degree of the energy utilisation,<sup>13,14</sup> and balancing the mismatch between energy supply and demand.<sup>15</sup> These technologies do not have the disadvantages of pumped hydro storage and compressed air storage, such as requirements of specific site topology, and relatively high capital cost, which could have a negative environmental footprint.<sup>11,12</sup>

Thermal energy storage systems can be classified as sensible heat, latent heat, and thermochemical energy systems.<sup>13,16,17</sup> The last mechanism, in which heat is used to sustain an endothermic chemical reaction and is released in the reverse reaction, is claimed to offer high energy densities,<sup>13,18</sup> especially if one of the regeneration stage products is in the vapour phase.<sup>19</sup> Despite being proposed for energy storage in the mid-1970s,<sup>19,20</sup> the process involving either hydration or carbonation of CaO is still considered among the best candidates for energy storage.<sup>18</sup> A novel process design based on the reversible CaO hydration reaction for storing heat from a concentrated solar field has been recently analysed by Criado *et al.*<sup>21</sup> The proposed configuration comprises a single atmospheric pressure circulating fluidised bed, which can operate as hydrator and regenerator, and two silos for CaO and Ca(OH)<sub>2</sub> storage. This study revealed that, at maximum thermal output of 100 MW<sub>th</sub>, the system offered an energy storage density of 260 kW h<sub>th</sub> m<sup>-3</sup> and a round-trip efficiency of 63%. Edwards and Materić<sup>22</sup> proposed a process based on reversible carbonation of CaO in the calcium looping process (CaL) that comprised two independent reactors – atmospheric pressure calciner (solar tower receiver) and pressurised fluidised bed carbonator – and three reservoirs for CaO,

CaCO<sub>3</sub> and CO<sub>2</sub> storage. In addition, air leaving the carbonator was fed to a gas expander for power generation. The plant net thermal efficiency was found to be between 40–46%. Finally, Vandersickel *et al.*<sup>23</sup> proposed to integrate a similar process to the integrated gasification combined cycle power plant, with the difference being that only CaO and CaCO<sub>3</sub> are stored, and the heat for calcination is provided through oxy-combustion of syngas diverted from the gas turbine. In this system, the existing Selexol unit is by-passed and the carbonator is used to capture CO<sub>2</sub> from the syngas during the peak-demand period. Nevertheless, the primary function of this system is energy storage and unloading the existing CO<sub>2</sub> capture system. Such configuration was found to operate with a round-trip efficiency of 61%, and allowed for changing the power output by +25% (peak-load) and –20% (off-peak) with respect to a nominal 550 MW<sub>el</sub>. However, this study did not consider variability of the power generation system during part-load operation, which would lead to a further reduction of the power output during the calcination step.

Although the carbonation reaction offers nearly 50% higher theoretical energy density (1222 kW h m<sup>-3</sup>) compared to that of hydration (833 kW h m<sup>-3</sup>),<sup>13</sup> there are some concerns that need to be resolved prior to large-scale deployment. These include capability for electrical energy storage,<sup>12</sup> reduction of sorbent activity,<sup>19</sup> and requirement for temporary CO<sub>2</sub> storage.<sup>18</sup> Also, the CaL process was proposed by Shimizu *et al.*<sup>24</sup> for CO<sub>2</sub> capture from fossil fuel power plants. Not only has this process been proven to impose lower net efficiency penalty (5–8% points)<sup>25–28</sup> compared to more mature CO<sub>2</sub> capture technologies (8–12.5% points),<sup>29–32</sup> it also has the ability to increase the net power output of the integrated system by more than 50%.<sup>28,33,34</sup> More importantly, this system can accept an excess amount of electricity produced in the renewable energy sources to drive the air (for O<sub>2</sub> production) and CO<sub>2</sub> compressors and has a permanent source of CO<sub>2</sub> from the fossil fuel power plant. Finally, it can operate with higher carbonation conversions (higher energy density) when a hydration stage is employed.<sup>35</sup>

The CaL process can, therefore, be seen as a promising technology for decarbonisation of the power sector as it has the ability to both decarbonise the fossil fuel power plant in an efficient manner and increase power generation flexibility. Hence, the fossil fuel power plant would not only meet its emission reduction targets, but also operate efficiently even in the energy portfolio containing large shares of intermittent renewable energy sources. In this study, the concept of CaL with inherent energy storage for CO<sub>2</sub> capture from coal-fired power plants is proposed and possible routes for energy storage in the proposed concept are identified. Finally, techno-economic performance of the selected routes is evaluated to analyse their degree of energy utilisation and profitability compared to the system without energy storage.

## 2 Concept process description

### 2.1 Calcium looping process

A core of the proposed concept is the CaL process proposed by Shimizu *et al.*<sup>24</sup> for CO<sub>2</sub> capture, which comprises two interconnected fluidised bed reactors operating at atmospheric pressure.

In the first reactor, a carbonator,  $\text{CO}_2$  is removed from the flue gas stream *via* calcium-based sorbent. In the second reactor, a calciner, the sorbent is regenerated at a high temperature, provided through oxy-combustion of fuel. High-temperature operation of the CaL process allows for recovery of high-grade heat from the carbonator and the process streams. As a result high-pressure steam can be generated and utilised for power generation in a secondary steam cycle.

Yet, due to the decay of maximum sorbent conversion with the number of carbonation/calcination cycles,<sup>36</sup> which can drop to around 5–14% after 30 cycles depending on sulphur content in the flue gas and the fuel used in the calciner,<sup>37,38</sup> part of the sorbent needs to be replenished in the system. To achieve a higher conversion in the carbonator, the sorbent can be reactivated through hydration (CaL-HYD).<sup>35,39,40</sup> As a result of 60% sorbent hydration, the maximum sorbent conversion in the carbonator is about 55% after 15 cycles.<sup>41</sup> In the concept process proposed here, the low-pressure steam required for hydration can be extracted from the secondary steam cycle. Hydrated sorbent can be directed to either the carbonator or the calciner (Fig. 1). However, the latter route increases the calciner heat load, and although that heat can be regenerated, the need for a larger air separation unit and  $\text{CO}_2$  compression unit incurs higher

capital costs, making this route less attractive. In addition, around 4–10% of sorbent<sup>42</sup> could be elutriated due to attrition. As a result, a higher fresh limestone make-up rate would be required, leading to higher maximum sorbent conversions, at the expense of higher heat requirement in the calciner. Yet, a higher fresh limestone make-up rate would lead to higher average sorbent conversions in the carbonator, reducing the sorbent looping rate required for 90% capture and thus, the heat requirement in the calciner.

## 2.2 Routes for energy storage and $\text{CO}_2$ capture

Having analysed the process flow diagrams of the CaL process for  $\text{CO}_2$  capture, three viable options for energy storage have been identified (Fig. 1):

- cryogenic  $\text{O}_2$  storage,
- $\text{CaO}/\text{CaCO}_3$  solids storage,
- $\text{CaO}/\text{Ca}(\text{OH})_2$  solids storage.

During the off-peak period, any of the identified energy storage systems can operate in the charging mode, which means that liquid  $\text{O}_2$  is produced and/or the sorbent is regenerated in the calciner (in the CaL-HYD scenario reactivated sorbent is first fed to the carbonator). Under such operating mode, the air separation unit, the  $\text{CO}_2$  compression unit and the calciner operate at their




Fig. 1 Schematic of coal-fired power plant retrofitted with calcium looping process for  $\text{CO}_2$  capture and energy storage.

nominal capacity, while the power plant operates at its minimum load of 40%. This will lead to higher fuel consumption and higher power consumption for air separation and CO<sub>2</sub> compression compared to the system operating at 40% load without the energy storage. During the peak-demand period, the coal-fired power plant operates at its nominal capacity, while the stored O<sub>2</sub> and/or regenerated sorbent is utilised to unload the air separation unit and the CO<sub>2</sub> compression unit, reducing their power requirements, and to reduce the heat requirement of the calciner. Therefore, the proposed concept would benefit from using more fuel during off-peak periods, storing its chemical energy when the electricity price is low, and using this energy to reduce the fuel consumption and/or the system's power requirement during the peak periods characterised by higher market prices for electricity. Such operation is expected to increase the flexibility and the profitability of the integrated system.

It needs to be highlighted that the carbonator is assumed to follow the power plant load changes, maintaining 90% CO<sub>2</sub> capture. Also, the air separation unit compressors can operate with a minimum load of 75% without recycling or venting, while the cold box operates at a minimum load of 50%.<sup>45</sup> This implies the need for three compression trains and two air separation unit trains to reach the minimum load of around 40% for the entire system. Due to the same minimum constraint, three compression trains are required in the CO<sub>2</sub> compression unit. The calciner, on the other hand, can operate with a minimum load of 25%.<sup>46,47</sup> It is also assumed that liquid O<sub>2</sub> is stored in the cryogenic tank at 1.2 bar at around −182 °C, which is maintained by the waste N<sub>2</sub> leaving the air separation unit,<sup>43</sup> while the sorbent is stored at high temperature in the solid storage tanks. As claimed by Arias *et al.*,<sup>6</sup> the heat losses in the solid storage tanks, characterised by a low surface-to-volume ratio, are negligible. Ma *et al.*<sup>44</sup> showed that storing energy using solid materials, such as ash or sand, in the insulated tanks can reach thermal efficiencies exceeding 99%. Such low heat losses (<1%) are a result of combined effects of highly effective thermal insulation and self-insulation of the particles. Assuming short-term CaO/CaCO<sub>3</sub> solids storage (<12 h) in the tanks insulated with concrete walls and refractory lining, which was also considered by Ma *et al.*,<sup>44</sup> heat losses are not expected to affect the process performance by much and thus they are neglected in this concept study. Nevertheless, at the process design stage and for long-term storage (days to weeks), the effect of heat loss on process performance needs to be taken into account.

### 3 Proof of concept

#### 3.1 Considerations

After identifying possible routes for energy storage in the CaL plant integrated to the coal-fired power plant for CO<sub>2</sub> capture (Fig. 1), the performance of the following scenarios is evaluated:

- CaL (Case 1) and CaL-HYD (Case 4) systems without energy storage;

- CaL (Case 2) and CaL-HYD (Case 5) systems with cryogenic O<sub>2</sub> storage;

- CaL (Case 3) and CaL-HYD (Case 6) systems with CaO/CaCO<sub>3</sub> solids storage.

Although other routes for energy storage based on permutations of the identified systems could be analysed, these are unlikely to offer any practical benefit over the selected cases. This is because, in all possible cases for energy storage, the minimum operating load of the calciner is limited by the minimum operating load of the air separation unit and the CO<sub>2</sub> compression unit. Therefore, further reduction in the minimum load of these systems would require additional compressors, leading to higher capital costs. Nevertheless, implementation of the energy storage system utilising the CaO/Ca(OH)<sub>2</sub> reaction for energy storage has lower energy density compared to that based on CaO/CaCO<sub>3</sub>,<sup>13</sup> and thus the heat storage capacity of the system would be lower.

To evaluate performance of the proposed concept, a model of the entire process has been developed in Aspen Plus<sup>TM,32</sup> with the key assumptions presented in Table 1. In addition to modelling of the CaL or CaL-HYD system, the air separation unit and the CO<sub>2</sub> compression unit were modelled in detail, to reliably assess process performance. The CO<sub>2</sub> capture system was scaled to remove 90% of the flue gas from the reference 660 MW<sub>el</sub> coal-fired power plant, the process model of which has been described in detail elsewhere.<sup>48</sup> As opposed to the study by Vandersickel *et al.*,<sup>23</sup> the part-load performance of the coal-fired power plant and the secondary steam cycle was evaluated in detail using the framework for part-load modelling presented in Hanak *et al.*<sup>48</sup>

The capacity of energy storage technologies is usually characterised with energy density ( $D_v$ ) or a specific energy ( $D_m$ )

Table 1 Key process model assumptions

Parameter	Value
Carbonator	Temperature (°C)
	625
	Carbonation extent (–)
	0.70
	Stoichiometric reactor. Average conversion model by Rodríguez <i>et al.</i> <sup>49</sup> with deactivation curves derived from experimental data from Sánchez-Biezma <i>et al.</i> <sup>50</sup> (non-hydrated sorbent) and Grasa <i>et al.</i> <sup>41</sup> (hydrated sorbent)
Calciner	Temperature (°C)
	900
	Calcination extent (–)
	0.95
	Relative make up (fresh limestone/sorbent circulation rate) (–)
	0.04
Hydrator	O <sub>2</sub> concentration in the calciner fluidising gas (% <sub>vol,wet</sub> )
	40.0
	O <sub>2</sub> excess (% <sub>vol,dry</sub> )
	2.5
	Gibbs reactor. Gibbs free energy minimisation model
Secondary steam cycle	Design live/reheat steam temperature (°C)
	593.3/593.3
	Design live/reheat steam pressure (bar)
	242.3/49.0



defined in eqn (1) and (2) as the ratio of the energy stored ( $E_{\text{stored}}$ ) and the amount of storage media stored ( $m_{\text{storage media}}$ ), while performance of the power generation systems is characterised with net power output ( $W_{\text{net}}$ ) and net thermal efficiency ( $\eta_{\text{th}}$ ), which is defined in eqn (3) as the ratio of the net power output and the heat input from fuel combustion ( $Q_{\text{fuel}}$ ). Environmental performance is represented as the specific CO<sub>2</sub> emissions ( $e_{\text{CO}_2}$ ) defined in eqn (4) as the ratio of CO<sub>2</sub> emission rate ( $m_{\text{CO}_2}$ ) and the net power output.

$$D_V = \frac{\dot{E}_{\text{stored}}}{3.6 \times \dot{m}_{\text{storage media}}} \rho_{\text{storage media}} \quad (1)$$

$$D_m = 1000 \times \frac{\dot{E}_{\text{stored}}}{\dot{m}_{\text{storage media}}} \quad (2)$$

$$\eta_{\text{th}} = \frac{\dot{W}_{\text{net}}}{\dot{Q}_{\text{fuel}}} \quad (3)$$

$$e_{\text{CO}_2} = \frac{\dot{m}_{\text{CO}_2}}{\dot{W}_{\text{net}}} \quad (4)$$

Because energy can be stored in thermal (CaO/CaCO<sub>3</sub> solids) and electrical (cryogenic O<sub>2</sub> storage) forms in the proposed concept, the above metrics cannot fully represent the performance of the integrated system. Therefore, the degree of energy utilisation ( $\eta_u$ ), which is defined in eqn (5) as the ratio of useful energy and total energy input, is used as a measure of overall process performance. In eqn (5), the useful energy term comprises net power output ( $W_{\text{net}}$ ), electricity stored through cryogenic O<sub>2</sub> storage ( $W_{\text{storage,out}}$ ), and heat stored through CaO/CaCO<sub>3</sub> solids storage ( $Q_{\text{storage,out}}$ ), while the total energy input comprises the chemical energy input from fuel combustion ( $Q_{\text{fuel}}$ ), electricity input through utilisation of stored liquid O<sub>2</sub> ( $W_{\text{storage,in}}$ ), and heat input through utilisation of stored CaO/CaCO<sub>3</sub> solids ( $Q_{\text{storage,in}}$ ). Although the considered forms of energy differ in quality, similar metrics, called degree of fuel utilisation, have been widely applied to assess performance of combined heat and power generation systems.<sup>51</sup>

$$\eta_u = \frac{\dot{W}_{\text{net}} + \dot{Q}_{\text{storage,out}} + \dot{W}_{\text{storage,out}}}{\dot{Q}_{\text{fuel}} + \dot{Q}_{\text{storage,in}} + \dot{W}_{\text{storage,in}}} \quad (5)$$

To assess the profitability of the proposed concepts with respect to the reference coal-fired power plant without CO<sub>2</sub> capture, the levelised cost of electricity (LCOE) and the cost of CO<sub>2</sub> avoided (AC) are calculated according to eqn (6) and (7)<sup>52–54</sup> respectively.

$$\text{LCOE} = \frac{\text{TCR} \times \text{FCF} + \text{FOM}}{\dot{W}_{\text{net}} \times \text{CF} \times 8760} + \text{VOM} + \frac{\text{SFC}}{\eta} \quad (6)$$

$$\text{AC} = \frac{\text{LCOE}_{\text{capture}} - \text{LCOE}_{\text{ref}}}{e_{\text{CO}_2,\text{ref}} - e_{\text{CO}_2,\text{capture}}} \quad (7)$$

These parameters allow assessing the economic viability of the proposed concept through correlating thermodynamic performance indicators, such as net power output, net thermal efficiency ( $\eta$ ), capacity factor (CF) and specific emissions ( $E_{\text{CO}_2}$ ),

with economic performance, such as total capital requirement (TCR), variable (VOM) and fixed (FOM) operating costs, specific fuel cost (SFC), and the fixed charge factor (FCF), which considers the system's lifetime and project interest rate.

In addition, considering the average electricity prices in December 2014,<sup>55</sup> the daily profit is calculated. Using the approach employed by Mac Dowell and Shah,<sup>56</sup> eqn (8) allows calculating the daily short-run profit (SRP) as the difference between the daily revenue from electricity sales ( $R$ ) and daily operating costs associated with fuel consumption (FC), sorbent make-up (SC), CO<sub>2</sub> transport and storage (CTS), and CO<sub>2</sub> emissions (CE).

$$\text{SRP} = R - (\text{FC} + \text{SC} + \text{CTS} + \text{CE}) \quad (8)$$

The capital cost of the coal-fired power plant and storage equipment is determined using the exponential method function<sup>64</sup> with economic data presented in Table 2. Taking the capital cost for an oxy-fuel circulating-fluidised bed system ( $C_0$ ) as ref. 58, eqn (9) is employed to estimate the total capital cost of the CaL and CaL-HYD plants ( $C$ ), considering the volume of the reactors ( $V$ ) and the heat input to the calciner ( $Q_{\text{calc}}$ ) with the scaling factors of 0.67 and 0.9, respectively. Moreover, the parameter representing the fraction of the total cost of a circulating fluidised bed reactor associated with the heat transfer surfaces ( $\alpha$ ) is assumed to be 0.85. It needs to be highlighted that in the CaL cases, this equation reduces to the exponential function used by Romano *et al.*<sup>59</sup>

$$C = C_0 \left[ \alpha \left( \frac{\dot{Q}_{\text{calc}}}{\dot{Q}_0} \right)^{\text{SF},Q} + (1 - \alpha) \left( \frac{V_{\text{calc}}}{V_0} \right)^{\text{SF},V} + (1 - \alpha) \left( \frac{V_{\text{carb}}}{V_0} \right)^{\text{SF},V} + (1 - \alpha) \left( \frac{V_{\text{hyd}}}{V_0} \right)^{\text{SF},V} \right] \quad (9)$$

Fixed and variable operating and maintenance costs are calculated as fractions of total capital cost, while operating costs associated with fuel and sorbent consumption, and CO<sub>2</sub> storage, transport and emission are determined based on process simulation outputs using economic data from Table 2.

Finally, performance of the selected cases for the proposed concept is assessed in the following operating modes:

- Charging mode in which the power plant operates at 40% load, while the considered energy storage system operates at 100% load,
- Discharging mode in which the power plant operates at 100% load, while the considered energy storage system operates at 40% load,
- Daily variable load operation in which the system operates in the charging mode during the off-peak period (11.00 pm – 5.30 am), discharging mode during the morning and evening peak periods (6.00 am – 9.30 am and 4.30 pm – 7.30 pm), and CO<sub>2</sub> capture only mode (no energy storage) in the remaining periods (10:00 am – 4:00 pm and 8:00 pm – 10:30 pm).‡

‡ A hypothetical daily energy demand was adapted from Mac Dowell and Shah.<sup>56</sup>

Table 2 Economic model assumptions

Parameter		Value
Coal-fired power plant	Reference equipment capital cost (€ per kW <sub>el</sub> ) <sup>42,52,54,57</sup>	1100
	Reference power output (MW <sub>el</sub> ) <sup>42</sup>	575
Calcium looping plant	Reference equipment capital cost (€ per kW <sub>el</sub> ) <sup>58</sup>	1252.3
	Reference heat input (MW <sub>th</sub> ) <sup>58</sup>	534.0
	Reference reactor volume (m <sup>3</sup> ) <sup>58</sup>	1150.5
Cryogenic O <sub>2</sub> storage tank	Reference equipment capital cost (€ per m <sup>3</sup> ) <sup>43</sup>	800 000
	Reference volume (m <sup>3</sup> ) <sup>43</sup>	2500
Solid storage tank	Reference equipment capital cost (€ per MW <sub>th,sensible</sub> ) <sup>44</sup>	8.0
Other economic parameters	Variable cost as a fraction of total capital cost (%) <sup>54,60</sup>	2.0
	Fixed cost as a fraction of total capital cost (%) <sup>54,60</sup>	1.0
	Carbon tax (€ per tCO <sub>2</sub> ) <sup>54,60</sup>	0.0
	Raw sorbent cost (€ per t) <sup>54,60</sup>	6.0
	CO <sub>2</sub> transport and storage cost (€ per tCO <sub>2</sub> ) <sup>61</sup>	7.0
	Coal price (€ per t) <sup>60,62</sup>	40.6
	Natural gas price (€ per t) <sup>63</sup>	157.1
	Expected lifetime (years) <sup>54,60</sup>	25
	Project interest rate (%) <sup>54,60</sup>	8.78
	Capacity factor (%) <sup>54,60</sup>	80

### 3.2 Thermodynamic performance evaluation

A performance analysis conducted for the selected cases (Table 3) revealed that the turndown of the reference coal-fired power plant, which is a ratio of the maximum and minimum net power output reached by the system, was 2.56. Interestingly, similar turndown

values were estimated for Case 1 (2.62) and Case 4 (2.60), in which the power plant was retrofitted with the CaL and the CaL-HYD systems for CO<sub>2</sub> capture only, respectively. This is because integration of these systems resulted not only in increase of the maximum net power output by 51.7% and 33.7%, respectively, but it also caused increases in the minimum net power output of 48.3% and 32.0%, respectively. Results presented in Table 3 show also that turndown of the integrated system with cryogenic O<sub>2</sub> storage increased to 3.30 (Case 2) and 3.15 (Case 5), while for the integrated system with CaO/CaCO<sub>3</sub> solids storage it reduced to 2.54 (Case 3) and 2.44 (Case 6). It should be noted that in the discharge mode, a reduction in the calciner load to 40% led to reductions in fuel and O<sub>2</sub> requirements, and thus, less high-grade heat was available for recovery from the process streams. This, in turn, resulted in less high-pressure steam generation and a drop in its pressure, which has been estimated according to the Stodola ellipse law;<sup>65</sup> hence lower maximum net power output. Cryogenic O<sub>2</sub> energy storage, therefore, appears to be better suited to balance rapid changes of the energy demand, allowing for immediate increases of net power output by utilising O<sub>2</sub> produced in the air separation unit and stored in the cryogenic tank during the off-peak period. Importantly, a noticeable difference in net power output between the CaL and the CaL-HYD systems arose from differences in the amount of the high-grade heat available for recovery in these systems. Namely, the increase in the average sorbent conversion in the carbonator from 15.8% in the CaL system to 37.8% in the CaL-HYD system resulted in a lower solid looping rate required to achieve 90% CO<sub>2</sub> capture in the carbonator of the latter system. This, in turn, resulted in a

Table 3 Performance indicators for the considered energy storage and CO<sub>2</sub> capture routes<sup>a</sup> for the proposed process

	Reference power plant		Case 1		Case 2		Case 3		Case 4		Case 5		Case 6	
	C	D	C	D	C	D	C	D	C	D	C	D	C	D
Charging (C)/Discharging (D) performance indicators														
Net power output (MW <sub>el</sub> )	247.0	633.0	366.4	960.0	307.5	1019.5	370.3	941.5	326.1	846.6	282.4	890.8	338.3	824.8
Net thermal efficiency (% <sub>HHV</sub> )	34.5	38.8	25.7	30.1	21.6	32.0	16.3	40.2	26.2	30.4	22.7	32.0	18.1	38.2
Energy utilisation degree (%)	34.5	38.8	25.7	30.1	25.7	31.4	37.7	33.6	26.2	30.4	26.2	31.5	39.1	32.4
Net efficiency penalty (% <sub>HHV</sub> )	—	—	8.8	8.7	12.9	6.8	18.2	−1.5	8.3	8.4	11.8	6.8	16.4	0.6
Energy utilisation degree penalty (%)	—	—	8.8	8.7	8.8	7.4	−3.2	5.1	8.3	8.4	8.3	7.3	−4.6	6.3
CO <sub>2</sub> intensity factor (gCO <sub>2</sub> per kW <sub>el</sub> h)	969.0	835.0	65.3	55.0	77.8	51.8	64.6	56.1	73.4	62.4	84.8	59.3	70.7	64.1
Instantaneous performance indicators														
Net power generation turndown (—)	2.56	—	2.62	—	3.30	—	2.54	—	2.60	—	3.15	—	2.44	—
Energy density <sup>b</sup> (kW h m <sup>−3</sup> )	—	—	—	—	312.0	—	307.2	—	—	—	309.8	—	483.6	—
Specific energy (kJ kg <sup>−1</sup> )	—	—	—	—	900	—	700	—	—	—	900	—	1200	—
Daily average performance indicators														
Average daily net thermal efficiency (% <sub>HHV</sub> )	38.1	—	29.4	—	29.5	—	29.4	—	29.7	—	29.8	—	29.7	—
Average daily degree of energy utilisation (%)	38.1	—	29.4	—	29.9	—	33.0	—	29.7	—	30.1	—	33.0	—
Average daily CO <sub>2</sub> intensity factor (gCO <sub>2</sub> per kW <sub>el</sub> h)	853.6	—	56.4	—	56.3	—	56.8	—	63.9	—	63.8	—	64.2	—
Economic performance indicators														
Levelised cost of electricity (€ per MW <sub>el</sub> h)	37.2	—	82.7	—	82.7	—	82.7	—	74.2	—	74.2	—	74.2	—
Cost of CO <sub>2</sub> avoided (€ per tCO <sub>2</sub> )	—	—	58.2	—	58.3	—	58.3	—	47.8	—	47.8	—	47.8	—

<sup>a</sup> Case 1 – CaL with no ES, Case 2 – CaL with cryogenic O<sub>2</sub> storage, Case 3 – CaL with CaO/CaCO<sub>3</sub> solids storage, Case 4 – CaL-HYD with no ES, Case 5 – CaL-HYD with cryogenic O<sub>2</sub> storage, Case 6 – CaL-HYD with CaO/CaCO<sub>3</sub> solids storage. <sup>b</sup> The unit is kW<sub>el</sub> h m<sup>−3</sup> O<sub>2</sub> in Case 2 and Case 5, and kW<sub>th</sub> h m<sup>−3</sup> CaCO<sub>3</sub> in Case 3 and Case 6.

reduction of the heat requirement for sorbent regeneration in the calciner, reducing the amount of recoverable heat from the carbonator and the process streams; hence less high-pressure steam was generated and used for power generation in the secondary steam cycle. The results obtained for the integrated system without energy storage were found to be consistent with the predictions by Wang *et al.*,<sup>66</sup> who compared performance of the CaL and the CaL-HYD systems.

Further analysis of process performance revealed that the CaO/CaCO<sub>3</sub> solid storage system would yield higher net thermal efficiencies in the discharging mode (40.2%<sub>HHV</sub> in Case 3 and 38.2%<sub>HHV</sub> in Case 6), compared to cryogenic O<sub>2</sub> storage (32.0%<sub>HHV</sub> in both Case 2 and Case 5) and even compared to the reference power plant (38.8%<sub>HHV</sub>). Yet, this is achieved at the expense of much lower net thermal efficiencies in the charging mode (16.3%<sub>HHV</sub> in Case 3 and 18.1%<sub>HHV</sub> in Case 6), when the solids converted in the carbonator need to be regenerated. Net thermal efficiency for the cryogenic O<sub>2</sub> storage system operating in the charging mode would result in an even lower efficiency penalty.

Yet, it is important to highlight that in estimation of net thermal efficiency, the net power output was considered as the only source of useful work in the system, while energy stored in the form of heat or electricity has not been taken into account. This can also be seen as the main reason for high net thermal efficiencies estimated for the discharging mode, since the energy input from the energy storage system was not considered. Performance analysis of the proposed concept routes revealed that the system with CaO/CaCO<sub>3</sub> storage has 12–13% points higher degree of energy utilisation than the cryogenic O<sub>2</sub> storage system. Yet, this did not directly correlate to system storage capacity. Estimation of energy density for both systems did not give a clear answer as to which system has higher energy storage capacity; for the former it was estimated to be 307.2 and 483.6 kW<sub>th</sub> h m<sup>-3</sup> in Case 3 and Case 6, respectively, while for the latter it was 312.0 and 309.8 kW<sub>el</sub> h m<sup>-3</sup> in Case 2 and Case 5, respectively. However, direct comparison of these values cannot be used to determine which system has higher energy storage capacity, due to different forms of energy used in the energy density estimation. For cases with the cryogenic O<sub>2</sub> storage system, operation in the charging and discharging mode was found not to affect performance of the secondary steam cycle, compared to the system without energy storage. It can be claimed that changes in net power output in these operating modes were directly related to the amount of thermal energy input in the boiler. By using the gross thermal efficiency of the system operating in the discharging (38.4%<sub>HHV</sub>) and charging mode (34.5%<sub>HHV</sub>), the energy density of cryogenic O<sub>2</sub> storage is recalculated to be 812.4–897.9 kW<sub>th</sub> h m<sup>-3</sup>, which is higher than estimated values for the CaL and CaL-HYD with CaO/CaCO<sub>3</sub> storage. This implies that to store the same amount of fuel energy, cryogenic O<sub>2</sub> storage would require smaller volume than the CaO/CaCO<sub>3</sub> solids storage system, hence lower capital costs.

Incorporation of the sorbent regeneration step through hydration was found to result in a 57.4% increase in energy density and 71.4% increase in specific energy. This can be associated with the increase of average sorbent conversion in

the carbonator from 15.8% to 37.8%, resulting in a reduction of unconverted CaO in the stored solids. As a result, the fraction of total thermal energy stored in the form of sensible heat reduced from 39.0% (Case 3) to 24.9% (Case 6), revealing that increased sorbent conversion promotes energy storage through chemical reaction. Also, it was estimated here that, for each percent of sorbent conversion improvement, energy density and the specific energy can be increased by 8 kW<sub>th</sub> h m<sup>-3</sup> and 21.6 kJ<sub>th</sub> kg<sup>-1</sup>, respectively. Therefore, not only would the systems including reactivation steps, such as the investigated CaL-HYD system with CaO/CaCO<sub>3</sub> solids storage, or using more efficient sorbents,<sup>67,68</sup> require smaller reactors (hence lower capital cost), these would also achieve a higher degree of energy utilisation. Moreover, the CaO/Ca(OH)<sub>2</sub> step in the proposed concept was used to increase the energy storage capacity of the CaO/CaCO<sub>3</sub> system by increasing the average conversion of the sorbent, hence increasing the fraction of CaCO<sub>3</sub> in the stored solids. This approach differs from the system investigated by Criado *et al.*,<sup>21</sup> who proposed to use the CaO/Ca(OH)<sub>2</sub> system as the primary energy storage system. This approach was found to increase the energy density of the CaO/CaCO<sub>3</sub> system to 483.6 kW<sub>th</sub> h m<sup>-3</sup>; that is 57% higher than the energy density of the CaO/CaCO<sub>3</sub> system without sorbent reactivation (307.2 kW<sub>th</sub> h m<sup>-3</sup>) and 86% higher compared to the CaO/Ca(OH)<sub>2</sub> system (260 kW<sub>th</sub> h m<sup>-3</sup>) evaluated by Criado *et al.*<sup>21</sup> As a result, storage of the same amount of heat would require smaller volume in the CaO/CaCO<sub>3</sub> system with sorbent reactivation through hydration compared to the CaO/Ca(OH)<sub>2</sub> system, leading to lower capital cost of the entire CO<sub>2</sub> capture system with energy storage, which is proven in the economic analysis presented below. The only downside of using the CaL-HYD instead of the CaL system is marginally higher values for CO<sub>2</sub> intensity factor in most of the cases investigated (Table 3). This is a result of lower net power output for the regenerated system, caused by less high-grade heat available for recovery from the process streams.

Analysis of the hypothetical daily energy demand curve adapted from Mac Dowell and Shah<sup>56</sup> revealed that the daily average degree of energy utilisation in the systems containing CaO/CaCO<sub>3</sub> storage (around 33%) and cryogenic O<sub>2</sub> storage (around 30%) was higher than in systems without energy storage (29.4% for Case 1 and 29.7% for Case 4). This implies that the systems with energy storage capability would result in higher degrees of energy utilisation. More importantly, as the periods of charging and discharging were equal in the hypothetical operating schedule, the average daily net thermal efficiency and the average daily CO<sub>2</sub> intensity factor were not affected much compared to the system without energy storage. Finally, the process evaluated in this study can conceptually be integrated with a solar power plant or wind turbine farm to utilise excess energy for sorbent regeneration or for liquid O<sub>2</sub> production, which can be utilised later to increase net thermal efficiency and the degree of energy utilisation.

### 3.3 Economic performance evaluation

The specific capital costs of the reference coal-fired power plant, the CaL system (Case 1) and the CaL-HYD system (Case 4) have

been estimated to be 1206.5 € per kW<sub>el,gross</sub>, 2981.6 € per kW<sub>el,gross</sub> and 2776.4 € per kW<sub>el,gross</sub>, respectively. This is in agreement with other studies, which assumed the specific capital costs for coal-fired power plants of 1200 € per kW<sub>el,gross</sub> and for the CaL system of 2500–3000 € per kW<sub>el,gross</sub>.<sup>25,52–54</sup> Moreover, specific capital cost of the integrated CaL and CaL-HYD systems was estimated to be 2023.4 € per kW<sub>el,gross</sub> and 1799.1 € per kW<sub>el,gross</sub>, respectively, which is close to the range 1250–1740 € per kW<sub>el,gross</sub> estimated in other studies.<sup>42,52,54</sup> A slightly higher specific capital cost obtained in this study is caused by the assumption of maximising heat recovery for power generation in the CaL and CaL-HYD plants. Also, the higher energy density due to sorbent regeneration in Case 6, compared to Case 3, reduces the specific capital cost of the entire system. An additional capital cost associated with cryogenic O<sub>2</sub> storage and CaO/CaCO<sub>3</sub> solid storage increases the specific capital cost of the integrated CaL system only by 0.6 € per kW<sub>el,gross</sub> (Case 2) and 2.3 € per kW<sub>el,gross</sub> (Case 3), and of the CaL-HYD by 0.6 € per kW<sub>el,gross</sub> (Case 5) and 1.4 € per kW<sub>el,gross</sub> (Case 6). Hence, addition of energy storage capability does not change the levelised cost of electricity, the value of which is in agreement with results from Romano *et al.*<sup>59</sup> and Yang *et al.*,<sup>54</sup> and has a negligible effect on the cost of CO<sub>2</sub> avoided (Table 3). Therefore, the inherent energy storage ability of the CaL and CaL-HYD systems is available at a very low additional capital cost to the CO<sub>2</sub> capture system.

Implementation of the CaL (Case 1) and the CaL-HYD (Case 4) plants for CO<sub>2</sub> capture will reduce the daily short run profit by 15.0% and 17.2% (Fig. 2), respectively, regardless of the better thermodynamic performance of Case 4 identified previously. This is due to 7.2% lower net power output in Case 4 with respect to Case 1 and thus lower expected revenue from electricity sales. Furthermore, addition of the cryogenic O<sub>2</sub> storage was found to increase the daily short-run profit of the CaL (Case 2) and CaL-HYD (Case 5) plants by 2.3% and 2.2%, respectively. Conversely, addition of the CaO/CaCO<sub>3</sub> solid storage system was found to slightly reduce the daily short-run profit of the CaL (Case 3) and CaL-HYD (Case 6) by 0.1% and 0.2%, respectively; yet it will increase the plant flexibility. Therefore, it appears as if the cryogenic O<sub>2</sub> storage system was more economically substantiated. Yet, with the secondary steam cycle designed for normal

operating mode without energy storage, part-load operation of the calciner in discharging mode reduces the amount of recoverable heat that results in reduction of net power output in Case 3 and Case 6 by 0.2% and 0.3%, respectively.

As electricity prices are subject to annual fluctuations and to seasonal changes, the effect of the price difference, which is defined as change of the electricity price with respect to the reference value over the considered period, on the daily short-run profit, is evaluated. On increasing the daily price difference (Fig. 3a), it was found that the concepts proposed in Case 2 and Case 3 would generate the same daily short-run profit as the reference coal-fired power plant without CO<sub>2</sub> capture if the daily price of electricity increases by 12.5 € per MW<sub>el</sub> h and 14.8 € per MW<sub>el</sub> h, respectively, while the CaL plant without energy storage will break even at the 14.4 € per MW<sub>el</sub> h increase in price difference. For the cases with sorbent regeneration through hydration, higher daily short-run profit would be achieved on increased price difference of 22.6–26.0 € per MW<sub>el</sub> h, with the lowest increase associated to Case 5. Moreover, increased peak price difference (Fig. 3b) of more than 27.4 € per MW<sub>el</sub> h and 49.2 € per MW<sub>el</sub> h, would make the CaL (Case 2) and the CaL-HYD (Case 5) more economical than the reference coal-fired power plant. In addition, it was found that reduction of off-peak prices (Fig. 3c) will not bring any additional benefit, as the loss of profit in the charging mode during low electricity price periods outweighs the benefits of discharging mode operated at peak times with higher prices. Nevertheless, this analysis revealed that the proposed concept, in particular the CaL plant with cryogenic O<sub>2</sub> storage system (Case 2), could generate daily short-run profit higher than the reference coal-fired power plant depending on the daily spot prices of electricity. Further increase of the profit can be achieved on determination of the optimal charging and discharging times, using optimisation methodology developed by Barbour *et al.*<sup>69</sup>

Finally, economic performance of the proposed concepts is highly dependent upon the economic climate, as it is predicted that the carbon tax may vary between 10–150 € per tCO<sub>2</sub>.<sup>70,71</sup> Moreover, economic performance will vary depending on whether the produced CO<sub>2</sub> is transported and stored (the costs for which vary between 2.5–36 € per tCO<sub>2</sub>)<sup>62,72</sup> depending on the CO<sub>2</sub> transport




Fig. 2 Comparison of the daily short-run profit.






Fig. 3 Effect of a change in the (a) daily (b) peak and (c) off-peak price difference on daily short-run profit.

method and storage location), or used, for example, for enhanced oil recovery at a supply price of 12–15 € per tCO<sub>2</sub>.<sup>73,74</sup> Fig. 4a reveals that the daily short-run profit of the reference coal-fired power plant is highly affected by increases in the carbon tax, while it is hardly affected in the remaining cases with 90%

CO<sub>2</sub> capture. Importantly, when the carbon tax exceeds 8.3 € per tCO<sub>2</sub> for Case 2 (which is lower than the average price of 8.5 € per tCO<sub>2</sub> for the European emission allowances in November 2015<sup>75</sup>), and 11.1 € per tCO<sub>2</sub> for Case 6, the proposed concepts become more profitable than the reference coal-fired




Fig. 4 Effect of (a) carbon tax and (b) cost of CO<sub>2</sub> transport and storage/use on daily short-run profit.

power plant. This implies that the proposed concept (Case 2) is already more profitable than the reference coal-fired power plant without CO<sub>2</sub> capture.

Furthermore, it can be seen in Fig. 4b that for the specific cost for CO<sub>2</sub> capture and transport of 2.5 € per tCO<sub>2</sub>, the daily short-run profit for Case 2 is equal to that generated by the reference coal-fired power plant. On the other hand, for Case 6 to become more profitable than the reference coal-fired power plant, CO<sub>2</sub> would need to be sold for industrial use at prices higher than 0.3 € per tCO<sub>2</sub>, which corresponds to negative values in Fig. 4b. This shows that the profitability of the proposed concepts could greatly exceed that of the reference coal-fired power plant, if pure CO<sub>2</sub> produced in the proposed concepts is industrially utilised, even at low price.

## 4. Conclusions

In this study, a concept for the CO<sub>2</sub> capture plant based on CaL with inherent energy storage is proposed and evaluated in the coal-fired power plant retrofit scenario. The CaL was previously proposed for energy storage from solar power plants; however, challenges such as the requirement for temporary CO<sub>2</sub> storage and sorbent deactivation were identified. These were resolved in the proposed system as the power plant acts as a permanent source of CO<sub>2</sub> and hydration was used as a means for sorbent regeneration.

Analysis of the process revealed that possible routes for energy storage include CaO/CaCO<sub>3</sub> solids storage, CaO/Ca(OH)<sub>2</sub> solids storage and cryogenic O<sub>2</sub> storage systems. The comparison of CaO/CaCO<sub>3</sub> and cryogenic O<sub>2</sub> storage systems revealed that implementation of the latter would result in higher turndown of the entire system and offer higher energy density, hence requiring lower capital cost. Although performance of the integrated system with energy storage through a CaO/Ca(OH)<sub>2</sub> loop was not evaluated here due to the lower energy density of such system, the reactivation step was found critical in improving the performance of the CaO/CaCO<sub>3</sub> energy storage system. Not only did it increase

net thermal efficiency, it increased the energy density by 57.4% and specific energy by 71.4% leading to a higher degree of energy utilisation. Importantly, the proposed CaL-HYD system with CaO/CaCO<sub>3</sub> energy storage was found to offer 86% higher energy density than the conventional CaO/Ca(OH)<sub>2</sub> energy storage system. An increase in the energy density was found to be important from the economic perspective, as storing the same amount of heat in a lower volume would result in the specific capital cost of the CaL-HYD system lower by 6.8% compared to the CaL system.

The economic performance evaluation conducted revealed that the addition of energy storage capability to the CaL and the CaL-HYD plants for CO<sub>2</sub> capture from the coal-fired power plant has a low impact on the total capital cost and thus on the levelised cost of electricity and the cost of CO<sub>2</sub> avoided. Moreover, analysis of the daily short-run profit revealed that Case 2, in which the CaL plant was equipped with the cryogenic O<sub>2</sub> storage system, will reduce the daily short-run profit of the coal-fired power plant by 15.0%. This case was found to have the lowest impact on system profitability. Yet, the proposed concept (Case 2) can generate higher profit when the carbon tax exceeds 8.3 € per tCO<sub>2</sub>. As the price of the European emission allowances in November 2015 was 8.5 € per tCO<sub>2</sub>, the proposed concept is already more profitable than the reference coal-fired power plant without CO<sub>2</sub> capture.

Further studies will aim to provide a detailed design of the proposed concepts of CO<sub>2</sub> capture with inherent energy storage for decarbonisation and to optimise the charging and discharging times to maximise the daily short-run profit. Also, the applicability of the proposed concepts in natural gas combined cycle power plants will be assessed. Finally, the inherent energy storage capability of other clean power technologies, such as chemical looping combustion and oxy-combustion, will be assessed.

## Nomenclature

AC	Cost of CO <sub>2</sub> avoided, € per tCO <sub>2</sub>
C	Capital cost of calcium looping system, € per kW <sub>el</sub>

$C_0$	Reference capital cost of oxy-fuel circulating fluidised bed system, € per kW <sub>el</sub>
CE	CO <sub>2</sub> emission cost, €
CF	Capacity factor, —
CTS	CO <sub>2</sub> transport and storage cost, €
$D_V$	Energy density, kW h m <sup>-3</sup>
$D_m$	Specific energy, kJ kg <sup>-1</sup>
$e_{CO_2}$	Specific CO <sub>2</sub> emission, gCO <sub>2</sub> per kW <sub>el</sub> h
$\dot{E}_{stored}$	Rate of energy to storage, MW
FC	Fuel cost, €
FCF	Fixed charge factor, —
FOM	Fixed operating and maintenance cost, €
LCOE	Levelised cost of electricity, € per MW h
$\dot{m}_{CO_2}$	Rate of CO <sub>2</sub> emission, kg s <sup>-1</sup>
$\dot{m}_{storage, media}$	Rate of media to storage, kg s <sup>-1</sup>
$R$	Revenue from electricity sales, €
SC	Sorbent make-up cost, €
SCF	Specific fuel cost, € per MW h
SE, $q$	Scaling factor for reactor heat input, —
SE, $v$	Scaling factor for reactor volume, —
SRP	Daily short run profit, €
TCR	Total capital requirement, €
$\dot{Q}_0$	Reference heat input, MW <sub>th</sub>
$\dot{Q}_{calc}$	Heat input to the calciner, MW <sub>th</sub>
$\dot{Q}_{fuel}$	Chemical energy input from fuel combustion, MW
$\dot{Q}_{storage,in}$	Heat input from CaO/CaCO <sub>3</sub> solids storage, MW
$\dot{Q}_{storage,out}$	Heat stored through CaO/CaCO <sub>3</sub> solids storage, MW
$V$	Volume of reactors, m <sup>3</sup>
$V_0$	Reference volume of reactor, m <sup>3</sup>
VOM	Variable operating and maintenance cost, € per MW h
$\dot{W}_{net}$	Net power output of the integrated system, MW
$\dot{W}_{storage,in}$	Electricity input from cryogenic O <sub>2</sub> storage, MW
$\dot{W}_{storage,out}$	Electricity stored through cryogenic O <sub>2</sub> storage, MW
$\alpha$	Fraction of the total cost of a circulating fluidised bed reactor associated with the heat transfer surfaces, —
$\eta_{th}$	Net thermal efficiency, —
$\eta_u$	Degree of energy utilisation, —

## Abbreviations

CaL	Calcium looping process
CaL-HYD	Calcium looping process with sorbent reactivation step through hydration
CCS	Carbon capture and storage

## References

- 1 IEA, *Energy technology perspectives 2012: pathways to a clean energy system*, IEA Publications, Paris, France, 2012.
- 2 IEA, *Technology Roadmap: carbon capture and storage*, IEA Publications, Paris, France, 2013.
- 3 J. Twidell and A. D. Weir, *Renewable energy resources*, Taylor & Francis, London, UK and New York, USA, 2006, vol. 2.
- 4 R. Jiang, J. Wang and Y. Guan, Robust unit commitment with wind power and pumped storage hydro, *IEEE Trans. Power Appar. Syst.*, 2012, **27**, 800–810.
- 5 M. Singh, V. Khadkikar, A. Chandra and R. K. Varma, Grid interconnection of renewable energy sources at the distribution level with power-quality improvement features, *IEEE Trans. Power Delivery*, 2011, **26**, 307–315.
- 6 B. Arias, Y. A. Criado, A. Sanchez-Biezma and J. C. Abanades, Oxy-fired fluidized bed combustors with a flexible power output using circulating solids for thermal energy storage, *Appl. Energy*, 2014, **132**, 127–136.
- 7 IEA, *Technology Roadmap: Energy Storage*, IEA Publications, Paris, France, 2014.
- 8 B. C. Ummels, E. Pelgrum and W. L. Kling, Integration of large-scale wind power and use of energy storage in the Netherlands' electricity supply, *IET Renew. Power Gener.*, 2008, **2**, 34–46.
- 9 A. Tuohy and M. O'Malley, Pumped storage in systems with very high wind penetration, *Energy Policy*, 2011, **39**, 1965–1974.
- 10 DOE, *DOE Global Energy Storage Database*, 2015, available at: [www.energystorageexchange.org](http://www.energystorageexchange.org).
- 11 H. Chen, T. N. Cong, W. Yang, C. Tan, Y. Li and Y. Ding, Progress in electrical energy storage system: a critical review, *Prog. Nat. Sci.*, 2009, **19**, 291–312.
- 12 D. O. Akinyele and R. K. Rayudu, Review of energy storage technologies for sustainable power networks, *Sustain. Energy Technol. Assessments*, 2014, **8**, 74–91.
- 13 A. Gil, M. Medrano, I. Martorell, A. Lázaro, P. Dolado, B. Zalba and L. F. Cabeza, State of the art on high temperature thermal energy storage for power generation. Part 1-Concepts, materials and modellization, *Renewable Sustainable Energy Rev.*, 2010, **14**, 31–55.
- 14 T. M. I. Mahlia, T. J. Saktisahdan, A. Jannifar, M. H. Hasan and H. S. C. Matseelar, A review of available methods and development on energy storage: technology update, *Renewable Sustainable Energy Rev.*, 2014, **33**, 532–545.
- 15 P. Pardo, A. Deydier, Z. Anxionnaz-Minvielle, S. Rougé, M. Cabassud and P. Cognet, A review on high temperature thermochemical heat energy storage, *Renewable Sustainable Energy Rev.*, 2014, **32**, 591–610.
- 16 A. Sharma, V. V. Tyagi, C. R. Chen and D. Buddhi, Review on thermal energy storage with phase change materials and applications, *Renewable Sustainable Energy Rev.*, 2009, **13**, 318–345.
- 17 Y. Hou, R. Vidu and P. Stroeve, Solar energy storage methods, *Ind. Eng. Chem. Res.*, 2011, **50**, 8954–8964.
- 18 T. Yan, R. Z. Wang, T. X. Li, L. W. Wang and I. T. Fred, A review of promising candidate reactions for chemical heat storage, *Renewable Sustainable Energy Rev.*, 2015, **43**, 13–31.
- 19 G. Ervin, Solar heat storage using chemical reactions, *J. Solid State Chem.*, 1977, **22**, 51–61.
- 20 R. Baker, The reversibility of the reaction  $CaCO_3 \rightleftharpoons CaO + CO_2$ , *J. Appl. Chem. Biotechnol.*, 1973, **23**, 733–742.
- 21 Y. A. Criado, M. Alonso, J. C. Abanades and Z. Anxionnaz-Minvielle, Conceptual process design of a  $CaO/Ca(OH)_2$

- thermochemical energy storage system using fluidized bed reactors, *Appl. Therm. Eng.*, 2014, **73**, 1085–1092.
- 22 S. E. B. Edwards and V. Materic, Calcium looping in solar power generation plants, *Sol. Energy*, 2012, **86**, 2494–2503.
  - 23 A. Vandersickel, R. P. Field, W. Chen, N. D. Mancini and A. Mitsos, CaO-based energy and CO<sub>2</sub> storage system for the flexibilization of an IGCC plant with carbon capture, *Ind. Eng. Chem. Res.*, 2014, **53**, 12032–12043.
  - 24 T. Shimizu, T. Hiram, H. Hosoda, K. Kitano, M. Inagaki and K. Tejima, A Twin Fluid-Bed Reactor for Removal of CO<sub>2</sub> from Combustion Processes, *Chem. Eng. Res. Des.*, 1999, **77**, 62–68.
  - 25 L. M. Romeo, J. C. Abanades, J. M. Escosa, J. Paño, A. Giménez, A. Sánchez-Biezma and J. C. Ballesteros, Oxyfuel carbonation/calcination cycle for low cost CO<sub>2</sub> capture in existing power plants, *Energy Convers. Manage.*, 2008, **49**, 2809–2814.
  - 26 I. Martínez, R. Murillo, G. Grasa and J. Carlos Abanades, Integration of a Ca looping system for CO<sub>2</sub> capture in existing power plants, *AIChE J.*, 2011, **57**, 2599–2607.
  - 27 J. C. Abanades, E. J. Anthony, J. Wang and J. E. Oakey, Fluidized Bed Combustion Systems Integrating CO<sub>2</sub> Capture with CaO, *Environ. Sci. Technol.*, 2005, **39**, 2861–2866.
  - 28 I. Vorrias, K. Atsonios, A. Nikolopoulos, N. Nikolopoulos, P. Grammelis and E. Kakaras, Calcium looping for CO<sub>2</sub> capture from a lignite fired power plant, *Fuel*, 2013, **113**, 826–836.
  - 29 M. E. Boot-Handford, J. C. Abanades, E. J. Anthony, M. J. Blunt, S. Brandani, N. Mac Dowell, J. R. Fernandez, M. C. Ferrari, R. Gross, J. P. Hallett, R. S. Haszeldine, P. Heptonstall, A. Lyngfelt, Z. Makuch, E. Mangano, R. T. J. Porter, M. Pourkashanian, G. T. Rochelle, N. Shah, J. G. Yao and P. S. Fennell, Carbon capture and storage update, *Energy Environ. Sci.*, 2014, **7**, 130–189.
  - 30 H. M. Kvamsdal, M. C. Romano, L. van der Ham, D. Bonalumi, P. van Os and E. Goetheer, Energetic evaluation of a power plant integrated with a piperazine-based CO<sub>2</sub> capture process, *Int. J. Greenhouse Gas Control*, 2014, **28**, 343–355.
  - 31 K. Goto, K. Yogo and T. Higashii, A review of efficiency penalty in a coal-fired power plant with post-combustion CO<sub>2</sub> capture, *Appl. Energy*, 2013, **111**, 710–720.
  - 32 D. P. Hanak, C. Biliyok, E. J. Anthony and V. Manovic, Modelling and comparison of calcium looping and chemical solvent scrubbing retrofits for CO<sub>2</sub> capture from coal-fired power plant, *Int. J. Greenhouse Gas Control*, 2015, **42**, 226–236.
  - 33 L. M. Romeo, Y. Lara, P. Lisbona and J. M. Escosa, Optimizing make-up flow in a CO<sub>2</sub> capture system using CaO, *Chem. Eng. J.*, 2009, **147**, 252–258.
  - 34 J. Ströhle, A. Lasheras, A. Galloy and B. Eppe, Simulation of the carbonate looping process for post-combustion CO<sub>2</sub> capture from a coal-fired power plant, *Chem. Eng. Technol.*, 2009, **32**, 435–442.
  - 35 V. Manovic and E. J. Anthony, Steam reactivation of spent CaO-based sorbent for multiple CO<sub>2</sub> capture cycles, *Environ. Sci. Technol.*, 2007, **41**, 1420–1425.
  - 36 J. C. Abanades, The maximum capture efficiency of CO<sub>2</sub> using a carbonation/calcination cycle of CaO/CaCO<sub>3</sub>, *Chem. Eng. J.*, 2002, **90**, 303–306.
  - 37 G. S. Grasa, J. C. Abanades, M. Alonso and B. González, Reactivity of highly cycled particles of CaO in a carbonation/calcination loop, *Chem. Eng. J.*, 2008, **137**, 561–567.
  - 38 G. S. Grasa and J. C. Abanades, CO<sub>2</sub> capture capacity of CaO in long series of carbonation/calcination cycles, *Ind. Eng. Chem. Res.*, 2006, **45**, 8846–8851.
  - 39 W. Wang, S. Ramkumar, S. Li, D. Wong, M. Iyer, B. B. Sakadjian, R. M. Statnick and L.-S. Fan, Subpilot demonstration of the carbonation-calcination reaction (CCR) process: high-temperature CO<sub>2</sub> and sulfur capture from coal-fired power plants, *Ind. Eng. Chem. Res.*, 2010, **49**, 5094–5101.
  - 40 V. Materic, R. Symonds, D. Lu, R. Holt and V. Manovic, Performance of hydration reactivated Ca looping sorbents in a pilot-scale, oxy-fired dual fluid bed unit, *Energy Fuels*, 2014, **28**, 5363–5372.
  - 41 G. Grasa, R. Murillo, M. Alonso, B. González, N. Rodríguez and J. C. Abanades, Steam reactivation of CaO-based natural sorbents applied to a carbonation/calcination loop for CO<sub>2</sub> capture, in 4th International Conference on Clean Coal Technologies, Dresden, Germany, 2009.
  - 42 P. Lisbona, A. Martínez, Y. Lara and L. M. Romeo, Integration of carbonate CO<sub>2</sub> capture cycle and coal-fired power plants. A comparative study for different sorbents, *Energy Fuels*, 2010, **24**, 728–736.
  - 43 Y. Hu, X. Li, H. Li and J. Yan, Peak and off-peak operations of the air separation unit in oxy-coal combustion power generation systems, *Appl. Energy*, 2013, **112**, 747–754.
  - 44 Z. Ma, G. Glatzmaier and M. Mehos, Fluidized Bed Technology for Concentrating Solar Power With Thermal Energy Storage, *J. Sol. Energy Eng.*, 2014, **136**, 031014.
  - 45 N. Perrin, R. Dubettier, F. Lockwood, J.-P. Tranier, C. Bourhy-Weber and P. Terrien, Oxycombustion for coal power plants: advantages, solutions and projects, *Appl. Therm. Eng.*, 2014, **74**, 75–82.
  - 46 R. C. Brown and J. E. Foley, Method for improving load turndown in fluidised bed combustors, *Ind. Eng. Chem. Res.*, 1988, **27**, 24–30.
  - 47 H. Kobro and C. Brereton, Control and fuel flexibility of circulating fluidised bed, *Circ. Fluid. Bed Technol. Proc. First Int. Conf.*, 1986, p. 263.
  - 48 D. P. Hanak, C. Biliyok and V. Manovic, Evaluation and Modeling of Part-Load Performance of Coal-Fired Power Plant with Postcombustion CO<sub>2</sub> Capture, *Energy Fuels*, 2015, **29**, 3833–3844.
  - 49 N. Rodríguez, M. Alonso and J. C. Abanades, Average activity of CaO particles in a calcium looping system, *Chem. Eng. J.*, 2010, **156**, 388–394.
  - 50 A. Sánchez-Biezma, J. Paniagua, L. Diaz, M. Lorenzo, J. Alvarez, D. Martínez, B. Arias, M.E. Diego and J.C. Abanades, Testing postcombustion CO<sub>2</sub> capture with CaO in a 1.7 MWt pilot facility, GHGT-11, 2013, vol. 37, pp. 1–8.
  - 51 H. Rusinowski, *Diagnostyka cieplna eksploatacji w energetyce (thermal identification in power engineering)*, Polska Akademia Nauk, Katowice, Poland (in Polish), 2010.



- 52 J. C. Abanades, G. Grasa, M. Alonso, N. Rodriguez, E. J. Anthony and L. M. Romeo, Cost structure of a postcombustion CO<sub>2</sub> capture system using CaO, *Environ. Sci. Technol.*, 2007, **41**, 5523–5527.
- 53 M. Zhao, A. I. Minett and A. T. Harris, A review of techno-economic models for the retrofitting of conventional pulverised-coal power plants for post-combustion capture (PCC) of CO<sub>2</sub>, *Energy Environ. Sci.*, 2013, **6**, 25–40.
- 54 Y. Yang, R. Zhai, L. Duan, M. Kavosh, K. Patchigolla and J. Oakey, Integration and evaluation of a power plant with a CaO-based CO<sub>2</sub> capture system, *Int. J. Greenhouse Gas Control*, 2010, **4**, 603–612.
- 55 APX, APX Power UK Auction, <http://bit.ly/1RgNHui>, 2015.
- 56 N. Mac Dowell and N. Shah, The multi-period optimisation of an amine-based CO<sub>2</sub> capture process integrated with a super-critical coal-fired power station for flexible operation, *Comput. Chem. Eng.*, 2015, **74**, 169–183.
- 57 E. S. Rubin, C. Chen and A. B. Rao, Cost and performance of fossil fuel power plants with CO<sub>2</sub> capture and storage, *Energy Policy*, 2007, **35**, 4444–4454.
- 58 J. Marion, N. Nsakala and R. McWhinnie, *Greenhouse Gas Emissions Control By Oxygen Firing In Circulating Fluidized Bed Boilers: Phase 1-A Preliminary Systems Evaluation*, 2003, vol. 2.
- 59 M. C. Romano, M. Spinelli, S. Campanari, S. Consonni, G. Cinti, M. Marchi and E. Borgarello, The Calcium Looping Process for Low CO<sub>2</sub> Emission Cement and Power, *Energy Procedia*, 2013, **37**, 7091–7099.
- 60 A. Martínez, Y. Lara, P. Lisbona and L. M. Romeo, Operation of a mixing seal valve in calcium looping for CO<sub>2</sub> capture, *Energy Fuels*, 2014, **28**, 2059–2068.
- 61 M. C. Romano, I. Martínez, R. Murillo, B. Arstad, R. Blom, D. C. Ozcan, H. Ahn and S. Brandani, Process simulation of Ca-looping processes: review and guidelines, in 11th International Conference on Greenhouse Gas Control Technologies, GHGT 2012, 2013, vol. 37, pp. 142–150.
- 62 H. C. Mantripragada and E. S. Rubin, Calcium looping cycle for CO<sub>2</sub> capture – performance, cost and feasibility analysis, *Energy Procedia*, 2013, **63**, 2199–2206.
- 63 EIA, *Annual energy outlook 2015 with projections to 2040*, U.S. Energy Information Administration, Washington, DC, USA, 2015.
- 64 R. H. Perry, D. W. Green and J. O. Maloney, *Perry's chemical engineers' handbook*, McGraw-Hill, New York, 2007, vol. 796.
- 65 D. H. Cooke, *Modelling of off-design multistage turbine pressures by Stodola's ellipse*, Bechtel Power Corporation, 1983.
- 66 W. Wang, S. Ramkumar and L. Fan, Energy penalty of CO<sub>2</sub> capture for the Carbonation–Calcination Reaction (CCR) Process: Parametric Effects and Comparisons with Alternative Processes, 10th Japan/China Symp. Coal C1 Chem., 2013, vol. 104, pp. 561–574.
- 67 J. Blamey, E. J. Anthony, J. Wang and P. S. Fennell, The calcium looping cycle for large-scale CO<sub>2</sub> capture, *Prog. Energy Combust. Sci.*, 2010, **36**, 260–279.
- 68 A. M. Kierzkowska, R. Pacciani and C. R. Müller, CaO-based CO<sub>2</sub> sorbents: from fundamentals to the development of new, highly effective materials, *ChemSusChem*, 2013, **6**, 1130–1148.
- 69 E. Barbour, I. a. G. Wilson, I. G. Bryden, P. G. McGregor, P. a. Mulheran and P. J. Hall, Towards an objective method to compare energy storage technologies: development and validation of a model to determine the upper boundary of revenue available from electrical price arbitrage, *Energy Environ. Sci.*, 2012, **5**, 5425.
- 70 DECC, *Updated energy and emissions projections 2014*, Department of Energy and Climate Change, London, UK, 2014.
- 71 EIA, *Energy market and economic impacts of the American Power Act of 2010*, U.S. Energy Information Administration, Washington, DC, USA, 2010.
- 72 ZEP, *The costs of CO<sub>2</sub> capture, transport and storage*, Zero Emission Platform, 2011.
- 73 R. Mendelevitch, The role of CO<sub>2</sub>-EOR for the development of a CCTS infrastructure in the North Sea Region, *Int. J. Greenhouse Gas Control*, 2014, **20**, 132–159.
- 74 Gccsi, *Accelerating the uptake of CCS: industrial use of captured carbon dioxide*, Global Carbon Capture and Storage Institute, Parsons Brinckerhoff, Docklands, Australia, 2011.
- 75 EEX, *European Emission Allowances (EUA). Global Environmental Exchange*, European Energy Exchange, Leipzig, Germany, 2015.