

FORM PENGUKURAN (AUDIT)

01/MF-FCU/DASI/VI/2026

FORM PENGUKURAN (AUDIT)

HEALTH VITALITY SCORE

100%

Status: EXCELLENT

A. GENERAL DATA

Room / Tenant	CZARRE 002	Design Air Temp	N/A (°C)
Unit Tag Number	DKN001271	Design Cooling Cap.	0 (Btuh)
Machine Brand	MC QUAY (MCC 60)	Design Air Flow	0 (Cfm)
Machine Type	FCU/AHU	-	-

B. AIR SIDE MEASUREMENTS

Leaving Coil Temp.	19.9 (°C) DB	18.6 (°C) WB	88.9 % RH
Entering Coil Temp.	31.2 (°C) DB	26.5 (°C) WB	69.7 % RH

Cross-Section Area (m2)			Air Velocity (m/s) - 15 Points Matrix								
Supply	Return	Fresh Air	Supply			Return			Fresh Air		
80x17	145x30	N/A	1. 3.57	2. 3.49	3. 3.46	1. 1.16	2. 1.06	3. 1.14	1. 0	2. 0	3. 0
			4. 3.39	5. 3.41	6. 3.47	4. 1.09	5. 1.05	6. 0.93	4. 0	5. 0	6. 0
			7. 3.50	8. 3.48	9. 3.51	7. 0.95	8. 1.07	9. 0.95	7. 0	8. 0	9. 0
			10. 3.46	11. 3.43	12. 3.38	10. 1.04	11. 1.13	12. 1.08	10. 0	11. 0	12. 0
			13. 3.35	14. 3.40	15. 3.45	13. 1.10	14. 0.97	15. 1.04	13. 0	14. 0	15. 0
			Avg: 3.45 m/s			Avg: 1.05 m/s			Avg: 0.00 m/s		
TOTAL CALCULATED AIR FLOW (Cfm)			10			10			-		

C. WATER SIDE

CHWS Temp	9.3 °C	CHWS Press	0 Bar
CHWR Temp	15.5 °C	CHWR Press	0 Bar
Flow Rate	0 m3/h	Pipe Size	N/A mm

D. ELECTRICAL

Current (A)	R: 1.36	S: 0	T: 0
Voltage (V)	RS: 0	ST: 0	RT: 0
Elect. Info	P: 0 kW	V L-N	0 V

PREPARED BY AUDITOR,

Name: PAHRUDIN
Date: 9/4/2026

WITNESSED BY CUSTOMER,

Waiting for Signature

Name: -
Date: