

Consultation Reply Environmental Health

From: <redacted_name> <redacted_email> Sent: <redacted_date> 16:06:32 UTC+01:00 To: <redacted_name> <redacted_email> Cc: <redacted_name> <redacted_email> Subject: 93.51862.FUL: 17 Foundry Court, Doncaster, ZZ25 1WD Hi, I have assessed the proposal to convert a first-floor and attic level above a takeaway/restaurant into a self-contained flat. The location is in the City Centre and within an area where there are many licensed premises, comprising night clubs, pubs and food establishments. The area is therefore subject to considerable amenity degradation, predominantly due to noise and cooking odours. Noise impact will include structural transmission from the ground floor restaurant/takeaway below the site, patron noise and external noise from activities in the nearby licensed premises, at noise sensitive times, which is known to be extremely loud and with dominant levels at lower frequencies that are difficult to attenuate. The flat has no provision for waste storage, and no access into the rear courtyard where waste would be stored before collection, as the ground floor takeaway/restaurant has. Whilst the elevation shows two doors to the rear, the plan shows no access for the flat to the rear. Without direct access to the rear for the flat to access their waste bin, the proposal is unacceptable on the grounds of inadequate provision for waste storage/disposal. The attic bedroom of the flat has no natural light apart from an existing skylight. This is unlikely to provide suitable or sufficient glazing and is unlikely to be openable or adjustable to provide suitable ventilation, especially purge ventilation for overheating and without further details, is not considered acceptable. The size of the glazing area to the living room is likely to prevent adequate internal noise levels being achieved. The application does not consider the extremely high ambient noise levels nor any mitigation necessary that will ensure acceptable living conditions. At this stage, I recommend that the application be refused until such times as it can be demonstrated that:

1. There is adequate provision for waste storage and disposal.
2. There is adequate provision for natural light, view and ventilation to the attic bedroom.
3. Internal noise levels as below can be achieved (measured at times when typical external noise from the nearby licensed premises and the ground floor takeaway/restaurant is occurring): No more than 35 dB LAeq (0700-<redacted_date>) in the living & dining rooms during the daytime No more than 30 dB LAeq (<redacted_date>-0700) in the bedroom during the night-time 45 dB LAFmax not regularly exceeded in the bedroom during the night-time No more than 47 dB Leq in the 63 Hz frequency band (music noise) in the bedroom during the night-time (<redacted_date>-0700) No more than 41 dB Leq in the 125 Hz frequency band (music noise) in the bedroom during the night-time (<redacted_date>-0700). These requirements must be met with windows closed and alternative means of ventilation provided. I will be happy to reconsider the proposal upon receipt of the above information. Regards, <redacted_name> <redacted_email>, BSc (Hons), MCIEH, CEnvH Senior Environmental Health Practitioner Regulation & Enforcement Directorate of Place City of Doncaster Council