

Consultation Reply Waste And Recycling

PLANNING CONSULTATION RESPONSE Application No: 93.51862.FUL Proposal: Change of use of first-floor and attic level into a self-contained flat including alterations to ground floor to create access.
Address: Location 17 Foundry Court, Doncaster, ZZ25 1WD Consultee: Waste and Recycling Consultation assessment and justification: I have reviewed the documents associated with this application and I provide the following comments on behalf of Waste and Recycling. Ensuring there is suitable provision for the storage and collection of waste and recycling on new developments (and redevelopments) is a fundamental component of residential site design. Local Plan Policy 44b (10) notes that housing proposals will be supported where they make satisfactory arrangements for the storage and collection of waste and recycling. Doncaster Council operates a standard alternate weekly waste and recycling collection service whereby each residential dwelling liable for Council Tax is entitled to receive the same level of service.

Waste container provision is calculated on the basis that each dwelling receives the following bin storage capacity each fortnightly cycle: Table 1: Capacity Purpose 240 litre Non – recyclable waste 240 litre Mixed dry recyclables 240 litre* Garden waste 55 litre Glass bottles *excluded for flats/apartments without private gardens. The standard domestic service operates such that we collect non-recyclable waste on alternate weeks to recyclable / compostable waste. Households receive a Black 240 litre bin for the storage and collection of non-recyclable waste: - Food waste / soiled food packaging - Nappies and sanitary products - Plastic bags / film - Shredded paper and windowed envelopes - Broken / sheet glass Households receive a Blue 240 litre bin for the storage and collection of mixed dry recyclable materials (all items must be empty / clean / dry): - Plastic bottles - Plastic pots, tubs, trays - Cardboard, paper, newspapers, magazines - Steel and Aluminium cans, clean Aluminium foil, empty aerosols - Liquid food cartons (Tetra/Pure Pak) Households receive a Green 55 litre box for the storage and collection of container glass (all items must be empty / clean / dry): - Glass bottles - Glass jars Households (with private gardens) receive a Green 240 litre bin for the storage and collection of compostable garden waste: - Grass cuttings, leaf-fall - Hedge clippings, tree and shrub prunings - Flowers, small plants and non-invasive weeds Waste containers may not be stored permanently on the highway. A suitably sized storage location within the premise boundary is a pre-requisite for all new developments and redevelopment proposals Bin storage areas should be conveniently located for the occupants of the dwelling and should enable free movement of wheeled containers to the designated collection point over smooth continuous surfaces - gradients between the storage area and collection point should be no more than 1:12 with no steps, kerbs or obstructions along the route. For apartments and flats, communal bin stores may be utilised if necessary. Communal bin capacity can be provided using a mix of 240, 360, 660 and <redacted_date> litre wheeled bins, however, please note: - In Doncaster City Centre locations (such as this) the Council will implement a weekly collection service, therefore, bin capacity calculations should be reduced by 50% compared to the standard service provision shown in table 1. - Green bins should be excluded from calculations where occupants do not have their own private gardens and / or where communal grounds are managed by a contractor; - Communal glass collections (to replace recycling boxes) are limited to a maximum bin size of 240L (due to weight). - Bin stores should be sufficiently sized to accommodate the required number of bin(s) for the number of residential units in the development. For example, a city centre apartment scheme with 1 dwelling, will be expected to provide ample storage capacity to accommodate: - 1 x 120L = 140L waste bin for non-recyclable waste; - 1 x 120L = 140L waste bin for mixed dry recyclables; - 1 x 27.5L = 55L recycling box for glass only Service changes are inevitable from time-to-time, UK Government is committed to the development of a more 'circular economy', further separation of different waste types may become mandatory moving forward. Planners and developers are advised that redundancy should be factored into proposed bin storage areas to accommodate future changes and additional capacity provision. Bins / bin stores should be located within 30m of the building, in a position which is convenient and easily accessible for the occupants of the development. Consideration should also be given to the movement of bins (for collection) to a suitable location accessible by refuse collection vehicle (within 5m of the adopted highway). Where direct access to the bin / bin store by the collection vehicle is impracticable, the managing agent is responsible for arranging the movement of bins to a suitable collection point on collection day. Preferably in this instance to the rear of the property to fall in line with existing scheduled collections at neighbouring residential properties. Bins / bin stores should not be located in a position that would cause unacceptable fire hazard, noise, odour or any other nuisance. They should not be placed on fire escape routes and must not cause obstruction, nor be easily obstructed, preventing free movement of bins for collection purposes. Doorways of bin stores should have double doors opening outwards and provide a clearance of 1.54m minimum (including door thickness), positioned so as to enable the removal and replacement of bins without being obstructed. Bin stores should not be visually detrimental to the locality. External bin stores should be at least 1.8m high and can be a close boarded vertical (external treated) timber

fencing construction or brick wall (or similar). Bin stores should allow comfortable access to all bins inside it without needing to move one to access another. If the bin store is external, it should be accessed by a key / keypad to prevent unauthorised access. The location of any bin store must be within the ownership of the building owner (or if not, have a legal agreement drawn up to permit the use in perpetuity). Bin stores and access routes to them should be lit when dark and should include smooth impervious surfaces laid to an appropriate fall to a foul drain to enable cleansing. Bin stores integrated within the development building, should be accessed directly from outside in the open air, with appropriate fire separation from the building and means of escape, fire detection and be properly ventilated. Except where necessary, bin stores should not be accessed directly from the inside of a building (to ensure compliance with Building Regulations and fire safety requirements). If an internal bin store access is the only solution, this must be by way of a protected lobby (i.e. two sets of self-closing fire doors with sight panels) which is provided with not less than 0.2sqm of permanent ventilation. Specialist advice should be sought regarding fire risk assessment and internal bin store construction before any such work is undertaken. The plans provided do not show or indicate any storage or collection point for waste bins. Following our review and in agreement with the response provided by Environmental Health, we confirm that no approval for development should be granted until adequate provision is made for the storage and disposal of waste. We strongly recommend that, before any decision is made, the Applicant/Developer submit a documented Waste Management Plan as part of their planning application. This requirement is essential to ensure the development meets environmental and operational standards for waste management. Doncaster Council charges a fee for the delivery of bins to households, current Fees and Charges can be found on the Council's website [here](#). On behalf of Waste and Recycling. Regards <redacted_name> Waste Management Systems Development Officer Doncaster Council