

Consultation Reply 2

From: <redacted_name> <redacted_email> Sent: <redacted_date> 15:04:14 UTC+00:00 To: <redacted_name> <redacted_email> Subject: RE: FW: Planning Consultation for application 92.73914.FUL Hi <redacted_name>,

Good afternoon, and thank you for sharing the Yorkshire Water consultation doc again. Following my previous correspondence, please find below the LLFA's position regarding the applicant's drainage proposals: 1. Infiltration Rate: The calculated infiltration rate provided by the applicant, is not suitable for soakaways. On this basis, the LLFA accepts, in principle, the proposed strategy to discharge surface water to the public sewer. However, when submitting revised documentation, the applicant <redacted_name> completed. We assesses each proposal fairly on the merits and completeness of the submitted information. 2. Yorkshire Water Consent: Yorkshire Water's consultation response indicates, managing surface water through infiltration (soakaways). The applicant's current drainage strategy proposes discharge to the public sewer instead. Before the LLFA can support this application, the applicant must: • Demonstrate that Yorkshire Water accepts the revised proposal with discharge rate. • Provide formal written confirmation or a Section 106 agreement or consultation response from Yorkshire Water to the Local Planning Authority.

Until this consent is obtained and submitted, the LLFA will not be in a position to support this application.

Note: In page-7 (Drainage Strategy Report), the applicant mentioned –

The planning case officer may ask the applicant to submit the signed S106 agreement or alternatively YW need to be consulted on this, again.

Please let me know if you require any further clarification.

Kind Regards Md A U <redacted_name> Flood Risk Engineer (Engagement) Highway Infrastructure Directorate of Place City of Doncaster Council

Address: North Bridge Depot, North Bridge Road, Doncaster, DN5 9AN E-mail: <redacted_email> Telephone: <redacted_phone>

From: <redacted_name> <redacted_email> Sent: <redacted_date> 10:24 To: <redacted_name> <redacted_email> Subject: FW: FW: Planning Consultation for application 92.73914.FUL

Good morning <redacted_name>,

I hope that you are well.

Please see the response below from the agent for this planning application 92.73914.FUL.

I initially consulted Yorkshire Water who raised no objections subject to conditions (please see attached).

Please could you advise on how to proceed?

Kind regards,

<redacted_name> Senior Planning Officer Development Management Planning Services Development Management Directorate of Place City of Doncaster Council

Address: Civic Office, Waterdale, Doncaster, DN1 3BU E-mail: <redacted_email> Website: www.doncaster.gov.uk

Follow MyDoncaster on Twitter and Facebook for the latest news.

Planning enquiries? Please use our new online service: Planning General Enquiry - City of Doncaster Council
The Council have implemented a new practice for how we negotiate and accept amendments to all planning applications, which may affect you. We have also published a new series of Local Validation Requirements and would encourage you to familiarise yourself with these requirements, which will come into effect for all applications submitted on or after <redacted_date>. More information about this can be found here: How do I apply for planning permission? - City of Doncaster Council Pre-application advice - City of Doncaster Council

Please treat this email as confidential. If you have received this message and it is not addressed to you please accept my apologies and inform me as soon as possible.

Privacy Notice The Council is committed to meeting its data protection obligations and handling your information securely. You should make sure you read and understand the Planning Services privacy notice, which sets out what you need to know about how Doncaster Council will use your information in the course of our work as a Local Planning Authority.

<http://www.doncaster.gov.uk/services/the-council-democracy/planning-service-privacy-notice>

From: <redacted_name> <redacted_email> Sent: <redacted_date> 10:04 To: <redacted_name> <redacted_email> Subject: Fwd: FW: Planning Consultation for application 92.73914.FUL

<redacted_name>, I am forwarding the response from our drainage engineer to the latest consultation response you have received from your drainage engineers. Regards <redacted_name> ----- Forwarded message -- This sender is trusted. sophospmartbannerend <redacted_name>, I am forwarding the response from our drainage engineer to the latest consultation response you have received from your drainage engineers. Regards <redacted_name> ----- Forwarded message ----- From: <redacted_name> <redacted_email> Date: Mon, Nov 10, <redacted_date> at 9:44 AM Subject: RE: FW: Planning Consultation for application 92.73914.FUL To: <redacted_name> <redacted_email> Cc: <redacted_name> <redacted_email>

Hi <redacted_name>

In respect of the comments we have the following responses. 1. Infiltration Testing and Drainage Strategy : The drainage strategy report does not include the calculated infiltration rate. The applicant has stated that rapid infiltration was not achieved during testing, leading to the abandonment of percolation tests. However, this approach does not align with the methodology outlined in BRE Digest 365, the tests require to be carried out over a minimum of 6 hours, ideally up to 24 hours, to ensure robustness. There is no minimum time specified in BRE365, but we do like tests to be conducted over 24hours when appropriate. It's worth noting that if the infiltration rate is equal to or greater than 1×10^{-7} m/s, then a half-drain time of less than 24 hours for infiltration features may be acceptable to the Lead Local Flood Authority (LLFA). I would therefore request you to contact the applicant to request further clarification and, if possible, a revised infiltration assessment in accordance with BRE 365 standards. The general description of the ground below the made ground is firm to stiff silty Clay. Typically infiltration would not be expected to be viable in this type of strata due to the very low permeability usually encountered.

Test to BRE365 - TP03 the water level dropped 8mm in 4.5Hours (270mins). The infiltration rate 4.9×10^{-7} m/s which is not appropriate for soakaways as expected.

The first 4 hours of the test is where the water drops the fastest and then slows down. An experienced geotechnical engineer will know when it is worth continuing a percolation or not based on the first 4hours of the test. Anything less than 10mm per hour generally doesn't work for infiltration structures. 2. Groundwater Protection and Discharge Consent : The site lies within a Source Protection Zone 3 (SPZ3), which is sensitive to potential groundwater contamination. In such cases, it is important to understand the position of the Environmental Health / Pollution Control Team of CDC regarding the use of infiltration methods. If infiltration is deemed unsuitable due to contamination risk, the LLFA would accept the proposed alternative strategy to discharge surface water into the public sewer network. However, the applicant will be required obtaining formal written consent from Yorkshire Water, which must be submitted to the Local Planning Authority as part of the application documentation.

As Yorkshire Water are a consultee, the planning officer should re-consult YW with the drainage strategy presented for confirmation that they accept the flow rate off site.

Regards

<redacted_name> Managing Director Tel:- <redacted_phone> Mobile:- <redacted_phone>

J ROBERTS DESIGN LTD STRUCTURAL AND CIVIL ENGINEERING CONSULTANTS 11 The Point
Bradmarsh Business Park Rotherham S60 1BP www.jrobertsdesignltd.com

From: <redacted_name> <redacted_email> Sent: <redacted_date> 14:19 To: <redacted_name>
<redacted_email> Subject: Fwd: FW: Planning Consultation for application 92.73914.FUL

<redacted_name>, I am forwarding e-mail and attachment from Doncaster's Drainage Engineers regarding the proposal at 22 Market Lane, Bessacarr, Doncaster, ZZ29 6EP. Can you have a look and see what needs to be done? Regards <redacted_name> ----- Forwarded message ----- From: <redacted_name> <redacted_email> Date: Fri, Nov 7, <redacted_date> at 1:44 PM Subject: FW: Planning Consultation for application 92.73914.FUL To: <redacted_name> <redacted_email> Good afternoon <redacted_name>, Please find below comments from the Drainage team who are still requiring further information please. Kind regards, <redacted_name> Senior Planning Officer Development Management Planning Services Development Management Directorate of Place City of Doncaster Council Address: Civic Office, Waterdale, Doncaster, DN1 3BU E-mail: <redacted_email> Website: www.doncaster.gov.uk Follow MyDoncaster on Twitter and Facebook for the latest news. Planning enquiries? Please use our new online service: Planning General Enquiry - City of Doncaster Council The Council have implemented a new practice for how we negotiate and accept amendments to all planning applications, which may affect you. We have also published a new series of Local Validation Requirements and would encourage you to familiarise yourself with these requirements, which will come into effect for all applications submitted on or after <redacted_date>. More information about this can be found here: How do I apply for planning permission? - City of Doncaster Council Pre-application advice - City of Doncaster Council Please treat this email as confidential. If you have received this message and it is not addressed to you please accept my apologies and inform me as soon as possible. Privacy Notice The Council is committed to meeting its data protection obligations and handling your information securely. You should make sure you read and understand the Planning Services privacy notice, which sets out what you need to know about how Doncaster Council will use your information in the course of our work as a Local Planning Authority.

<http://www.doncaster.gov.uk/services/the-council-democracy/planning-service-privacy-notice> -----Original Message----- From: <redacted_name> <redacted_email> Sent: <redacted_date> 13:25 To: <redacted_name> <redacted_email> Subject: RE: Planning Consultation for application 92.73914.FUL Hi <redacted_name>, Good afternoon – I hope you're well. Following my review of the submitted planning application earlier today, I've noted a few points that require clarification or further information from the applicant: 1. Infiltration Testing and Drainage Strategy : The drainage strategy report does not include the calculated infiltration rate. The applicant has stated that rapid infiltration was not achieved during testing, leading to the abandonment of percolation tests. However, this approach does not align with the methodology outlined in BRE Digest 365, the tests require to be carried out over a minimum of 6 hours, ideally up to 24 hours, to ensure robustness. It's worth noting that if the infiltration rate is equal to or greater than 1×10^{-4} m/s, then a half-drain time of less than 24 hours for infiltration features may be acceptable to the Lead Local Flood Authority (LLFA). I would therefore request you to contact the applicant to request further clarification and, if possible, a revised infiltration assessment in accordance with BRE 365 standards. 2. Groundwater Protection and Discharge Consent : The site lies within a Source Protection Zone 3 (SPZ3), which is sensitive to potential groundwater contamination. In such cases, it is important to understand the position of the Environmental Health / Pollution Control Team of CDC regarding the use of infiltration methods. If infiltration is deemed unsuitable due to contamination risk, the LLFA would accept the proposed alternative strategy to discharge surface water into the public sewer network. However, the applicant will be required obtaining formal written consent from Yorkshire Water, which must be submitted to the Local Planning Authority as part of the application documentation. Please let me know if you need any further input from the LLFA on this matter. Kind Regards
Md A U <redacted_name> Flood Risk Engineer (Engagement) Highway Infrastructure Directorate of Place City of Doncaster Council Address: North Bridge Depot, North Bridge Road, Doncaster, DN5 9AN E-mail: <redacted_email> Telephone: <redacted_phone>