

Consultation Reply Yorkshire Water

Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ
Registered in England and Wales No. 2366682 www.yorkshirewater.com Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No. 2366682 www.yorkshirewater.com Director of Development and Planning Doncaster Metropolitan Borough Council Colonnades House Duke Street Doncaster DN1 1ER Your Ref: 92.73914.FUL Our Ref: A/01627
Yorkshire Water Services Developer Services Sewerage Technical Team PO BOX 52 Bradford BD3 7AY Tel: <redacted_phone> Email: <redacted_email> <redacted_date> Dear Sir/Madam, 22 Market Lane, Bessacarr, Doncaster, ZZ29 6EP - (DON) Erection of detached dwelling and garage following previous demolition of original dwelling Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments: Water Supply Any liquid storage tanks should be located within a bund with a capacity of not less than 110% of the largest tank or largest combined volume of connected tanks. (To ensure that there are no discharges to the public sewerage system which may injure the sewer, interfere with free flow or prejudicially affect the treatment and disposal of its contents) There shall be no construction of new buildings on site prior to the completion of a Construction Environmental Management Plan (CEMP) to understand the impact of planning permission on the principal aquifer. Furthermore, the findings and recommendations of the CEMP must be implemented. (To ensure that the development can be properly drained) 1.) The proposed development is 1.7km to the Rossington groundwater abstractions and sits inside Source Protection Zone (SPZ) 3. In accordance with the Environment Agency guidance, SPZ3 indicates that a pollutant will reach the groundwater abstraction if it infiltrates the ground. This presents a risk to the public water supply. a.) According to the BGS borehole records, there is the glaciofluvial deposits – consisting of sands and gravel. Underlying this is the Sherwood sandstone bedrock which is a principal aquifer that is described by the Environment Agency as “important rock units that have high permeability and water storage capacity”. Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No. 2366682 www.yorkshirewater.com Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No. 2366682 www.yorkshirewater.com 2.) A Construction Environmental Management Plan (CEMP) will be required. a.) This will detail storage and use of fuels and other chemicals must be managed to minimise the pollution risk. b.) Refuelling must be carried out in a designated area with an impermeable ground surface. c.) Fuels and other chemicals must be stored in a secure and suitably bunded location. Personnel must be trained in dealing with spillages with a procedure (Yorkshire Water and Environment Agency to be added to contacts if spills occur) and spill kits available on site. d.) Additionally, vehicles/machinery will be routinely checked for drips and spills. e.) A silt management plan (control of surface water flow into open excavations, holes only open for as long as strictly necessary). Waste Water If planning permission is to be granted, the following conditions should be attached in order to protect the local aquatic environment and Yorkshire Water infrastructure: The development shall be carried out in accordance with the details shown on the submitted plan, "SURFACE & FOUL WATER DRAINAGE DESIGN' 4555 prepared by J Roberts Design, dated <redacted_date>", unless otherwise agreed in writing with the Local Planning Authority. (In the interest of satisfactory and sustainable drainage) 1.) The submitted 'SURFACE & FOUL WATER DRAINAGE DESIGN' 4555 prepared by J Roberts Design, dated <redacted_date> is acceptable In summary, the report states that a.) Foul water will discharge to public foul water sewer b.) Sub-soil conditions do not support the use of soakaways c.) A watercourse is remote from the site d.) Surface water will discharge to public surface water sewer via storage with restricted discharge of 2 litres/second. Yours faithfully <redacted_name> Developer Services Team