

Consultation Reply Yorkshire Water 2

Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ
Registered in England and Wales No. 2366682 www.yorkshirewater.com Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No. 2366682 www.yorkshirewater.com Director of Development and Planning Doncaster Metropolitan Borough Council Colonnades House Duke Street Doncaster DN1 1ER Your Ref: 92.73914.FUL Our Ref: A/01627
Yorkshire Water Services Developer Services Sewerage Technical Team PO BOX 52 Bradford BD3 7AY Tel: <redacted_phone> Email: <redacted_email> <redacted_date> Dear Sir/Madam, 22 Market Lane, Bessacarr, Doncaster, ZZ29 6EP - (DON) Erection of detached dwelling and garage following previous demolition of original dwelling Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments/ conditions: Water Supply Any liquid storage tanks should be located within a bund with a capacity of not less than 110% of the largest tank or largest combined volume of connected tanks. (To ensure that there are no discharges to the public sewerage system which may injure the sewer, interfere with free flow or prejudicially affect the treatment and disposal of its contents) There shall be no construction of new buildings on site prior to the completion of a feasibility study to understand the impact of planning permission on the sewerage system. Furthermore, the findings and recommendations of the study must be implemented. (To ensure that the development can be properly drained) Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No. 2366682 www.yorkshirewater.com Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No. 2366682 www.yorkshirewater.com No development shall take place until details of the proposed means of disposal of foul water drainage for the whole site, including details of any balancing works, off-site works and phasing of the necessary infrastructure, have been submitted to and approved by the Local Planning Authority. Furthermore, unless otherwise approved in writing by the Local Planning Authority, no buildings shall be occupied or brought into use prior to completion of the approved foul drainage works. (To ensure that no foul water discharges take place until proper provision has been made for their disposal) 1.) The proposed development is 1.7km to the Rossington groundwater abstractions and situates inside Source Protection Zone (SPZ) 3. In accordance with the Environment Agency guidance, SPZ3 indicates that a pollutant will reach the groundwater abstraction if it infiltrates the ground. This presents a risk to the public water supply. a.) According to the BGS borehole records, there is the glaciofluvial deposits – consisting of sands and gravel. Underlying this is the Sherwood sandstone bedrock which is a principal aquifer that is described by the Environment Agency as “important rock units that have high permeability and water storage capacity”. 2.) There is no foul water drainage details shown. Please provide details. 3.) The surface water drainage proposal is to discharge to soakaway. Please provide soakaway design be provided. 4.) A Construction Environmental Management Plan (CEMP) will be required. a.) This will detail storage and use of fuels and other chemicals must be managed to minimise the pollution risk. b.) Refuelling must be carried out in a designated area with an impermeable ground surface. c.) Fuels and other chemicals must be stored in a secure and suitably bunded location. Personnel must be trained in dealing with spillages with a procedure (Yorkshire Water and Environment Agency to be added to contacts if spills occur) and spill kits available on site. d.) Additionally, vehicles/machinery will be routinely checked for drips and spills. e.) A silt management plan (control of surface water flow into open excavations, holes only open for as long as strictly necessary). Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No. 2366682 www.yorkshirewater.com Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No. 2366682 www.yorkshirewater.com

Waste Water

If planning permission is to be granted, the following conditions should be attached in order to protect the local aquatic environment and Yorkshire Water infrastructure: The site shall be developed with separate systems of drainage for foul and surface water on and off site. The separate systems should extend to the points of discharge to be agreed. (In the interest of satisfactory and sustainable drainage)

No piped discharge of surface water from the application site shall take place until works to provide a satisfactory outfall, other than the existing local public sewerage, for surface water have been completed in accordance with details submitted to and approved by the Local Planning Authority. (To ensure that the site is properly drained and in order to prevent overloading, surface water is not discharged to the public sewer network)

1.) It is noted from the submitted planning application that surface water is proposed to be drained to watercourse - Yorkshire water endorse this means of surface water disposal, provided designs are acceptable.

Yours faithfully

<redacted_name> Developer Services Team